



NRG Huntley Power, LLC  
3500 River Road  
Tonawanda, NY 14150

January 2019

Mr. David Vitale  
New York State Department of Environmental Conservation  
Division of Materials Management Director  
625 Broadway  
Albany, NY 12233-7250

RE: CCR Rule Notice

Dear Mr. Vitale:

Pursuant to the EPA's CCR Rule and sections 40 CFR Parts §257.105 - §257.107, Huntley Power LLC is notifying the New York State Department of Environmental Conservation per the Recordkeeping, Notification and Internet Requirements regarding the following operations for the Huntley Power LLC Generating Station.

In accordance with the requirements of Title 40 CFR §257.95, the station commenced and established an Assessment Monitoring Program in 2018 for the CCR impoundment and the CCR landfill. Based on the results, the facility has determined one or more SSL's (one) above the corresponding groundwater protection standard has occurred around the CCR impoundment. Notice of this determination is required to be entered into the facility operating record per §257.105(h)(8), noticed to the State Director per §257.106(h)(6) and posted to the publicly accessible website per §257.107(h)(6).

Additionally, this determination carries obligations to characterize the nature and extent of the SSL impacts per §257.95(g)(1)(i-iv), and to conduct an Assessment of Corrective Measures per §257.95(g)(3)(i) and §257.96(a) which will be initiated as required.

Information as required has or will be provided to public website <http://www.nrg.com/legal/coal-combustion-residuals/> within the timelines determined by the rule.

Should you require additional information, please contact George Streit at (716) 200-2797 or [George.Streit@NRG.com](mailto:George.Streit@NRG.com).

Sincerely,

A handwritten signature in black ink, appearing to read "George Streit", written over a circular scribble.

George T. Streit  
Environmental Coordinator

cc: Peter Grasso, P.E., 270 Michigan Ave., Buffalo, NY 14203