


CERTIFICATION

In accordance with Section 257.91(f) of the CCR Rule, I hereby certify based on review of the information contained within the CCR Compliance Monitoring, Sampling and Analysis Plan for Joliet #29 Station dated October 10, 2017, the groundwater monitoring system has been designed and constructed to satisfy the requirements of the Section. For this site the minimum number of wells required is deemed sufficient based on the following: 1) The number of wells, placement and screened intervals are based on a hydrogeologic assessment performed for the site; 2) hydrogeologic considerations included aquifer characteristics affecting flow velocity and physical transport processes; 3) available historical groundwater flow data indicate consistent flow conditions over time; 4) Illinois Environmental Protection Agency (IEPA) approved the overall hydrogeologic assessment as part of a larger study.

Certified by:



Date:

10-13-17

Joshua Davenport, P.E.

Professional Engineer Registration No.: 062.061945

KPRG and Associates, Inc.