

**WEEKLY QUALIFIED PERSON CHECK LIST FOR JOLIET 29 ASH PONDS**

**INSTRUCTIONS:**

- 1) An inspection of each ash pond and related embankments/berms at the Stations must be conducted **weekly and within 24 hours after a storm event greater or equal to 6.45 inches.**
- 2) The inspection must be conducted by a "qualified person" and the inspection records should be maintained at the Station for five years.
- 3) Every week, the qualified person must also inspect the CCR Unit Instrumentation.

**Date:** 12/29/24    **Time:** 10<sup>00</sup>Am    **Type of Inspection:**    Weekly     Storm Event

**GENERAL INFORMATION:**

	POND 1	POND 2	POND 3
1) Water Level in Pond	NORMAL <input type="checkbox"/> HIGH <input type="checkbox"/> LOW <input checked="" type="checkbox"/>	NORMAL <input type="checkbox"/> HIGH <input type="checkbox"/> LOW <input checked="" type="checkbox"/>	NORMAL <input checked="" type="checkbox"/> HIGH <input type="checkbox"/> LOW <input type="checkbox"/>
2) Is Ash Being Removed?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
3) In Service?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>

**PHYSICAL INSPECTION:**

1) Seepage from or through embankment? Includes roads around ponds and outside fence.	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
2) Sinkholes/Depressions/Bulges in Pond or embankments?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
3) Signs of Piping/Channels or other Internal Erosion on embankments?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
4) Cracking on Embankments/Berms?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
5) Animal Burrows on embankments?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
6) Excessive or Lacking Vegetative Cover on embankments? (should be normal growth)	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
7) Slope Erosion on berms or embankments?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
8) Debris on embankments/berms?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
9) Deterioration, malfunctions, or improper operation of overtopping control systems	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
10) Visible Releases	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>

11) If Yes to any of the above, or any other abnormalities are noted, please describe/explain: \_\_\_\_\_

12) Is there any damage to Pond Liner: YES  NO

If YES, answer questions below:

12.a) Describe in Detail: \_\_\_\_\_

12.b) Specific Location: \_\_\_\_\_

12.c) Is Water Level Below Damage? YES  NO

12.d) If No, Did You Reduce Pond Level? YES  N/A

12.e) Notified Shift Supervisor of Damage? YES  Date Notified: \_\_\_\_\_ N/A

12.f) Notified Station Management of Damage? YES  Date Notified: \_\_\_\_\_ N/A

12.g) Additional Comments: \_\_\_\_\_


**POND LEVEL INSTRUMENTATION**


POND 2 Gauge Marking (ft) 2.5 (In Tenth's of Feet)

Elevation FT/MSL 519.5

Gauge Marker Instrument is in good condition and readable YES  NO

*NOTE: Joliet 29 Pond 1 & Pond 3 are not CCR Surface Impoundments. Inspections are conducted as part of Operations Best Practices*

Inspector Name (Print):  \_\_\_\_\_

Inspector Signatur  \_\_\_\_\_

**WEEKLY QUALIFIED PERSON CHECK LIST FOR JOLIET 29 ASH PONDS**

**INSTRUCTIONS:**

- 1) An inspection of each ash pond and related embankments/berms at the Stations must be conducted **weekly and within 24 hours after a storm event greater or equal to 6.45 inches.**
- 2) The inspection must be conducted by a "qualified person" and the inspection records should be maintained at the Station for five years.
- 3) Every week, the qualified person must also inspect the CCR Unit Instrumentation.

**Date:** 1-1-25 **Time:** 9:30AM **Type of Inspection:** Weekly  Storm Event

**GENERAL INFORMATION:**

	POND 1	POND 2	POND 3
1) Water Level in Pond	NORMAL <input type="checkbox"/> HIGH <input type="checkbox"/> LOW <input checked="" type="checkbox"/>	NORMAL <input type="checkbox"/> HIGH <input type="checkbox"/> LOW <input checked="" type="checkbox"/>	NORMAL <input checked="" type="checkbox"/> HIGH <input type="checkbox"/> LOW <input type="checkbox"/>
2) Is Ash Being Removed?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
3) In Service?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>

**PHYSICAL INSPECTION:**

1) Seepage from or through embankment? Includes roads around ponds and outside fence.	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
2) Sinkholes/Depressions/Bulges in Pond or embankments?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
3) Signs of Piping/Channels or other Internal Erosion on embankments?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
4) Cracking on Embankments/Berms?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
5) Animal Burrows on embankments?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
6) Excessive or Lacking Vegetative Cover on embankments? (should be normal growth)	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
7) Slope Erosion on berms or embankments?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
8) Debris on embankments/berms?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
9) Deterioration, malfunctions, or improper operation of overtopping control systems	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
10) Visible Releases	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>

11) If Yes to any of the above, or any other abnormalities are noted, please describe/explain: \_\_\_\_\_

12) Is there any damage to Pond Liner: YES  NO

If YES, answer questions below:

12.a) Describe in Detail: \_\_\_\_\_

12.b) Specific Location: \_\_\_\_\_

12.c) Is Water Level Below Damage? YES  NO

12.d) If No, Did You Reduce Pond Level? YES  N/A

12.e) Notified Shift Supervisor of Damage? YES  Date Notified: \_\_\_\_\_ N/A

12.f) Notified Station Management of Damage? YES  Date Notified: \_\_\_\_\_ N/A

12.g) Additional Comments: \_\_\_\_\_

**POND LEVEL INSTRUMENTATION**

POND 2 Gauge Marking (ft) 2.0 (In Tenth's of Feet)

Elevation FT/MSL 519.5

Gauge Marker Instrument is in good condition and readable YES  NO

*NOTE: Joliet 29 Pond 1 & Pond 3 are not CCR Surface Impoundments. Inspections are conducted as part of Operations Best Practices*

Inspector Name (Print): \_\_\_\_\_

Inspector Signature: \_\_\_\_\_