INSTRUCTIONS:

- 1) An inspection must be conducted no less than <u>every 7 days and within 24 hours after a</u> <u>storm event greater than or equal to 6.45 inches</u>.
- 2) The inspection must be conducted by a "qualified person" and the inspection records should be maintained at the Station for five years. RETURN FORM to Env. Specialist.
- 3) <u>HIGHLIGHTED ANSWERS reflect immediate problems contact management.</u>

GENERAL INFORMATION:

1)	Date/Time Onsite	March 2, 2022/13:20 – 14:55			
2)	Pond Name	Lincoln Stone Quarry			
3)	Type of Inspection	7-day 🖂	Sto	rm Event 🛛	
4)	Water Level in Pond	NORMAL 🛛		HIGH 🗆	LOW 🗆
5)	Water Differential (Boyd's – LSQ) *	NORMAL (>5')	\boxtimes	YES 🖂	NO 🗆
* Differential notification on 03/02/22 was 8.44 ft.					

PHYSICAL INSPECTION:

Is the impoundment incised?	7	NO 🗆
-----------------------------	---	------

If yes, skip down to Question 9.

		YES	NO	N/A	CONDITION NOTES
1)	Seepage from or through embankment/berm?			\boxtimes	
2)	Sinkholes/Depressions/Bulges in Pond or embankments?			\boxtimes	
3)	Signs of Piping/Channels or other Internal Erosion on embankments?			\boxtimes	
4)	Cracking on Embankments/Berms?			\boxtimes	
5)	Animal Burrows on embankments?			\boxtimes	
6)	Excessive or Lacking Vegetative Cover on embankments?			\boxtimes	
7)	Slope Erosion on berms or embankments?			\boxtimes	
8)	Debris on embankments/berms?			\boxtimes	
9)	Deterioration, malfunctions, or improper operation of overtopping control systems		\boxtimes		<u>NE</u>
10)	Visible Releases		\boxtimes		<u>NE</u>
11)	Potential for Dusting?		\boxtimes		<u>NE</u>

12) If Yes to any of the above, or any other abnormalities are noted, please describe/explain:			
13) Notified Shift Supervisor of Damage? YES 🗌 Date Notified:	N/A 🗆		
14) Notified Station Management of Damage? YES 🗌 Date Notified:	N/A 🗆		
15) Additional Comments:			

30-DAY INSPECTION OF UNIT INSTRUMENTATION

HIGHLIGHT APPROPRIATE MONTH: JAN FEB MAR APR MAY JUN JUL AUG SEPT OCT NOV DEC

		GOOD	NEEDS REPAIR	N/A
1)	Level Instrumentation Verified Physically Intact	\boxtimes		
2)	Level Instrumentation Verified Communicating to Website	\boxtimes		
3)	Other Device(s) (<i>if applicable</i>)			\boxtimes
Desc	ribe any "Needs Repair" checked above:			

Verification contact/time:

Inspector: ____

CONDITION NOTES:

- NE No evidence of a problem
- GC Good condition
- MM Item needing minor maintenance and/or repairs within the year
- IM Item needing immediate maintenance to restore or ensure its safety or integrity
- EC Emergency condition which if not immediately repaired or other appropriate measures taken could lead to failure of the dam
- OB Condition requires regular observation to ensure that the condition does not become worse.