

Weekly CCR Inspection Checklist for Lincoln Stone Quarry (rev7 – 2021)

INSTRUCTIONS:

- 1) An inspection must be conducted no less than every 7 days and within 24 hours after a storm event greater than or equal to 6.45 inches.
- 2) The inspection must be conducted by a “qualified person” and the inspection records should be maintained at the Station for five years. RETURN FORM to Env. Specialist.
- 3) **HIGHLIGHTED ANSWERS reflect immediate problems – contact management.**

GENERAL INFORMATION:

- | | |
|--|---|
| 1) Date/Time Onsite | December 2, 2025/ 9:55 – 11:00 |
| 2) Pond Name | Lincoln Stone Quarry |
| 3) Type of Inspection | 7-day ☒ Storm Event ☐ |
| 4) Water Level in Pond | NORMAL ☒ HIGH ☐ LOW ☐ |
| 5) Water Differential (Boyd’s – LSQ) * | NORMAL (>5’) YES ☐ NO ☐ |

*Differential notification on 12/2/2025 was 8.52 ft.

PHYSICAL INSPECTION:

Is the impoundment incised? YES ☒ NO ☐ If yes, skip down to Question 9.

	YES	NO	N/A	CONDITION NOTES
1) Seepage from or through embankment/berm?	☐	☐	☒	_____
2) Sinkholes/Depressions/Bulges in Pond or embankments?	☐	☐	☒	_____
3) Signs of Piping/Channels or other Internal Erosion on embankments?	☐	☐	☒	_____
4) Cracking on Embankments/Berms?	☐	☐	☒	_____
5) Animal Burrows on embankments?	☐	☐	☒	_____
6) Excessive or Lacking Vegetative Cover on embankments?	☐	☐	☒	_____
7) Slope Erosion on berms or embankments?	☐	☐	☒	_____
8) Debris on embankments/berms?	☐	☐	☒	_____
9) Deterioration, malfunctions, or improper operation of overtopping control systems	☐	☒	☐	NE
10) Visible Releases	☐	☒	☐	NE
11) Potential for Dusting?	☐	☒	☐	NE

12) If Yes to any of the above, or any other abnormalities are noted, please describe/explain:

13) Notified Shift Supervisor of Damage? YES ☐ Date Notified: _____ N/A ☒

14) Notified Station Management of Damage? YES ☐ Date Notified: _____ N/A ☒

15) Additional Comments: _____

30-DAY INSPECTION OF UNIT INSTRUMENTATION

HIGHLIGHT APPROPRIATE MONTH: JAN FEB MAR APR MAY JUN JUL AUG SEPT OCT **NOV** DEC

	GOOD	NEEDS REPAIR	N/A
1) Level Instrumentation Verified Physically Intact	☒	☐	☐
2) Level Instrumentation Verified Communicating to Website	☒	☐	☐
3) Other Device(s) (<i>if applicable</i>)	☐	☐	☒

Describe any "Needs Repair" checked above: _____

Verification date/time: _____ Last verification on 11/11/2025 at 10:12 CT

Inspector: _____

CONDITION NOTES:

- NE No evidence of a problem
- GC Good condition
- MM Item needing minor maintenance and/or repairs within the year
- IM Item needing immediate maintenance to restore or ensure its safety or integrity
- EC Emergency condition which if not immediately repaired or other appropriate measures taken could lead to failure of the dam
- OB Condition requires regular observation to ensure that the condition does not become worse.