

Notice of Statistically Significant Levels – Powerton Generating Station – W1798010008

February 4, 2025

This notice is being provided as required by 40 CFR 257.95(g) for the Ash Surge Basin and the Bypass Basin at the Powerton Generating Station. The constituent listed below is listed in Appendix IV to 40 CFR Part 257 Subpart D and was detected and verified at statistically significant levels (SSL) at or above the established groundwater protection standards (GWPS).

- Molybdenum – 1 downgradient well

No other constituent listed in Appendix IV was detected at or above statistically significant levels of the established groundwater protection standards.

Accordingly, this notification is being made by Midwest Generation, LLC to satisfy the requirements of §257.95(g), including documented placement of this information into the facility's operating record [§257.105(h)(8)]. This notification is being further provided to the State to comply with the obligations of §257.106(h)(6) and will also be posted on the publicly accessible website per §257.107(h)(6). This posting will be available on our public website at <http://www.nrg.com/legal/coal-combustion-residuals>.