

## WEEKLY INSPECTION CHECKLIST FOR SURFACE IMPOUNDMENTS

### INSTRUCTIONS:

- 1) An inspection of each ash pond and related embankments/berms at the Station must be conducted:
  - a. Not less than every 7 days, and
  - b. Within 24 hours after a storm event greater than or equal to 6.20 inches.
- 2) The inspection must be conducted by a "qualified person" and the inspection records should be maintained at the Station for five years.
- 3) This is for all active and inactive ponds.
- 4) Not less than every 30 days, the qualified person must also inspect the CCR Unit Instrumentation.

### GENERAL INFORMATION:

- |  |   |
|--|---|
| 1) Date                                    | 08-10-22  |
| 2) Pond Name                               | Ash Surge Basin (ASB)   |
| 3) Type of Inspection                      | 7-day <input checked="" type="checkbox"/> Storm Event <input type="checkbox"/>                        |
| 4) General Condition                       | EMPTY <input type="checkbox"/> FULL <input checked="" type="checkbox"/>                               |
| 5) In Service                              | YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>                                   |
| 6) Is Ash Being Removed During Inspection? | YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>                                   |
| 7) Water Level in Pond                     | NORMAL <input checked="" type="checkbox"/> HIGH <input type="checkbox"/> LOW <input type="checkbox"/> |

### PHYSICAL INSPECTION:

Is the impoundment incised? YES  NO  If yes, skip down to Question 9.

- |   | YES                      | NO                                  |
|---|--------------------------|-------------------------------------|
| 1) Seepage from or through embankment?                                | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 2) Sinkholes/Depressions/Bulges in Pond or embankments?               | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 3) Signs of Piping/Channels or other Internal Erosion on embankments? | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 4) Cracking on Embankments/Berms?                                     | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 5) Animal Burrows on embankments?                                     | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 6) Excessive or Lacking Vegetative Cover on embankments?              | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 7) Slope Erosion on berms or embankments?                             | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 8) Debris on embankments/berms?                                       | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

9) Deterioration, malfunctions, or improper operation of  
overtopping control systems

10) Visible Releases

11) If Yes to any of the above, or any other abnormalities are noted, please describe/explain:

---

---

12) Is there any damage to Pond Liner: YES  NO  N/A

12.a) If YES, Describe in Detail: \_\_\_\_\_

---

12.b) Specific Location: \_\_\_\_\_

---

12.c) Is Water Level Below Damage? YES  NO  N/A

12.d) If No, Did You Reduce Pond Level? YES  N/A

12.e) Notified Shift Supervisor of Damage? YES  Date Notified: \_\_\_\_\_ N/A

12.f) Notified Station Management of Damage? YES  Date Notified: \_\_\_\_\_ N/A

12.g) Additional Comments: \_\_\_\_\_

---

**30-DAY INSPECTION OF UNIT INSTRUMENTATION**

	GOOD	NEEDS REPAIR	N/A
1) Pump Conditions	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2) Polymer System	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
3) Wetwell/Basin Level	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4) Freeboard Measuring Device(s)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5) Other Device(s) (pH meter)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Describe any "Needs Repair" checked above: \_\_\_\_\_

---

---

Inspector: \_\_\_\_\_

## WEEKLY INSPECTION CHECKLIST FOR SURFACE IMPOUNDMENTS

### INSTRUCTIONS:

- 1) An inspection of each ash pond and related embankments/berms at the Station must be conducted:
  - a. Not less than every 7 days, and
  - b. Within 24 hours after a storm event greater than or equal to 6.20 inches.
- 2) The inspection must be conducted by a "qualified person" and the inspection records should be maintained at the Station for five years.
- 3) This is for all active and inactive ponds.
- 4) Not less than every 30 days, the qualified person must also inspect the CCR Unit Instrumentation.

### GENERAL INFORMATION:

- |  |   |
|--|---|
| 1) Date                                    | 08-10-22  |
| 2) Pond Name                               | Ash Bypass Basin (ABB)  |
| 3) Type of Inspection                      | 7-day <input checked="" type="checkbox"/> Storm Event <input type="checkbox"/>                        |
| 4) General Condition                       | EMPTY <input checked="" type="checkbox"/> FULL <input type="checkbox"/>                               |
| 5) In Service                              | YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>                                   |
| 6) Is Ash Being Removed During Inspection? | YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>                                   |
| 7) Water Level in Pond                     | NORMAL <input checked="" type="checkbox"/> HIGH <input type="checkbox"/> LOW <input type="checkbox"/> |

### PHYSICAL INSPECTION:

Is the impoundment incised? YES  NO  If yes, skip down to Question 9.

- |   | YES                      | NO                                  |
|---|--------------------------|-------------------------------------|
| 1) Seepage from or through embankment?                                | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 2) Sinkholes/Depressions/Bulges in Pond or embankments?               | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 3) Signs of Piping/Channels or other Internal Erosion on embankments? | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 4) Cracking on Embankments/Berms?                                     | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 5) Animal Burrows on embankments?                                     | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 6) Excessive or Lacking Vegetative Cover on embankments?              | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 7) Slope Erosion on berms or embankments?                             | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 8) Debris on embankments/berms?                                       | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

9) Deterioration, malfunctions, or improper operation of overtopping control systems

10) Visible Releases

11) If Yes to any of the above, or any other abnormalities are noted, please describe/explain:

---

---

12) Is there any damage to Pond Liner: YES  NO  N/A

12.a) If YES, Describe in Detail: \_\_\_\_\_

---

12.b) Specific Location: \_\_\_\_\_

---

12.c) Is Water Level Below Damage? YES  NO  N/A

12.d) If No, Did You Reduce Pond Level? YES  N/A

12.e) Notified Shift Supervisor of Damage? YES  Date Notified: \_\_\_\_\_ N/A

12.f) Notified Station Management of Damage? YES  Date Notified: \_\_\_\_\_ N/A

12.g) Additional Comments: The Ash Bypass Basin has been closed off.

**30-DAY INSPECTION OF UNIT INSTRUMENTATION**

	GOOD	NEEDS REPAIR	N/A
1) Pump Conditions	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2) Polymer System	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
3) Wetwell/Basin Level	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4) Freeboard Measuring Device(s)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
5) Other Device(s) (pH meter)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Describe any "Needs Repair" checked above: \_\_\_\_\_

•

Inspector: \_\_\_\_\_  \_\_\_\_\_

## WEEKLY INSPECTION CHECKLIST FOR SURFACE IMPOUNDMENTS

### INSTRUCTIONS:

- 1) An inspection of each ash pond and related embankments/berms at the Station must be conducted:
  - a. Not less than every 7 days, and
  - b. Within 24 hours after a storm event greater than or equal to 6.20 inches.
- 2) The inspection must be conducted by a "qualified person" and the inspection records should be maintained at the Station for five years.
- 3) This is for all active and inactive ponds.
- 4) Not less than every 30 days, the qualified person must also inspect the CCR Unit Instrumentation.

### GENERAL INFORMATION:

- |  |   |
|--|---|
| 1) Date                                    | 08-10-22  |
| 2) Pond Name                               | Metal Cleaning Basin (MCB)  |
| 3) Type of Inspection                      | 7-day <input checked="" type="checkbox"/> Storm Event <input type="checkbox"/>                        |
| 4) General Condition                       | EMPTY <input type="checkbox"/> FULL <input checked="" type="checkbox"/>                               |
| 5) In Service                              | YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>                                   |
| 6) Is Ash Being Removed During Inspection? | YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>                                   |
| 7) Water Level in Pond                     | NORMAL <input type="checkbox"/> HIGH <input type="checkbox"/> LOW <input checked="" type="checkbox"/> |

### PHYSICAL INSPECTION:

Is the impoundment incised? YES  NO  If yes, skip down to Question 9.

- |   | YES                      | NO                                  |
|---|--------------------------|-------------------------------------|
| 1) Seepage from or through embankment?                                | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 2) Sinkholes/Depressions/Bulges in Pond or embankments?               | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 3) Signs of Piping/Channels or other Internal Erosion on embankments? | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 4) Cracking on Embankments/Berms?                                     | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 5) Animal Burrows on embankments?                                     | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 6) Excessive or Lacking Vegetative Cover on embankments?              | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 7) Slope Erosion on berms or embankments?                             | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 8) Debris on embankments/berms?                                       | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

9) Deterioration, malfunctions, or improper operation of overtopping control systems

10) Visible Releases

11) If Yes to any of the above, or any other abnormalities are noted, please describe/explain:

---

---

12) Is there any damage to Pond Liner: YES  NO  N/A

12.a) If YES, Describe in Detail: \_\_\_\_\_

---

12.b) Specific Location: \_\_\_\_\_

---

12.c) Is Water Level Below Damage? YES  NO  N/A

12.d) If No, Did You Reduce Pond Level? YES  N/A

12.e) Notified Shift Supervisor of Damage? YES  Date Notified: \_\_\_\_\_ N/A

12.f) Notified Station Management of Damage? YES  Date Notified: \_\_\_\_\_ N/A

12.g) Additional Comments: \_\_\_\_\_

### 30-DAY INSPECTION OF UNIT INSTRUMENTATION

	GOOD	NEEDS REPAIR	N/A
1) Pump Conditions	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2) Polymer System	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
3) Wetwell/Basin Level	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4) Freeboard Measuring Device(s)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
5) Other Device(s) (pH meter)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Describe any "Needs Repair" checked above: \_\_\_\_\_

---

Inspector: \_\_\_\_\_  \_\_\_\_\_

## WEEKLY INSPECTION CHECKLIST FOR SURFACE IMPOUNDMENTS (FAB)

### INSTRUCTIONS:

- 1) An inspection of each ash pond and related embankments/berms at the Stations must be conducted:
  - a. Not less than every 7 days, and
  - b. Within 24 hours after a storm event greater or equal to 6.20 inches.
- 2) The inspection must be conducted by a "qualified person" and the inspection records should be maintained at the Station for five years.
- 3) This is for all active and inactive ponds.
- 4) Not less than every 30 days, the qualified person must also inspect the CCR Unit Instrumentation.

### GENERAL INFORMATION:

1) Date	08-10-22		
2) Pond Name	Former Ash Basin (FAB)		
3) Type of Inspection	7-day <input checked="" type="checkbox"/>	Storm Event <input type="checkbox"/>	
4) General Condition	EMPTY <input checked="" type="checkbox"/>	FULL <input type="checkbox"/>	
5) In Service	YES <input type="checkbox"/>	NO <input checked="" type="checkbox"/>	
6) Is Ash Being Removed During Inspection?	YES <input type="checkbox"/>	NO <input checked="" type="checkbox"/>	
7) Water Level in Pond	NORMAL <input type="checkbox"/>	HIGH <input type="checkbox"/>	LOW <input checked="" type="checkbox"/>

### PHYSICAL INSPECTION:

Is the impoundment incised? YES  NO  If yes, skip down to Question 9.

	YES	NO
1) Seepage from or through embankment?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2) Sinkholes/Depressions/Bulges in Pond or embankments?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
3) Signs of Piping/Channels or other Internal Erosion on embankments?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4) Cracking on Embankments/Berms?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
5) Animal Burrows on embankments?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
6) Excessive or Lacking Vegetative Cover on embankments?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
7) Slope Erosion on berms or embankments?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
8) Debris on embankments/berms?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
9) Deterioration, malfunctions, or improper operation of overtopping control systems	<input type="checkbox"/>	<input checked="" type="checkbox"/>

10) Visible Releases

11) If Yes to any of the above, or any other abnormalities are noted, please describe/explain:

There are some large trees growing in the embankment and one area where the side of the embankment appears to have eroded. No significant changes in these conditions were observed.

---

12) Is there any significant damage to the embankment: YES  NO

12.a) If YES, Describe in Detail: \_\_\_\_\_

\_\_\_\_\_

12.b) Specific Location: \_\_\_\_\_

\_\_\_\_\_

12.c) Is Water Level Below Damage? YES  NO  N/A

12.d) If No, Did You Reduce Pond Level? YES  N/A

12.e) Notified Shift Supervisor of Damage? YES  Date Notified: \_\_\_\_\_ N/A

12.f) Notified Station Management of Damage? YES  Date Notified: \_\_\_\_\_ N/A

12.g) Additional Comments: \_\_\_\_\_

Inspector: \_\_\_\_\_  \_\_\_\_\_