

WEEKLY INSPECTION CHECKLIST FOR SURFACE IMPOUNDMENTS

INSTRUCTIONS:

- 1) An inspection of each ash pond and related embankments/berms at the Station must be conducted:
 - a. Not less than every 7 days, and
 - b. Within 24 hours after a storm event greater than or equal to 6.20 inches.
- 2) The inspection must be conducted by a “qualified person” and the inspection records should be maintained at the Station for five years.
- 3) This is for all active and inactive ponds.
- 4) Not less than every 30 days, the qualified person must also inspect the CCR Unit Instrumentation.

GENERAL INFORMATION:

1) Date	09-17-2025		
2) Pond Name	Ash Surge Basin (ASB)		
3) Type of Inspection	7-day ☒	Storm Event ☐	
4) General Condition	EMPTY ☐	FULL ☒	
5) In Service	YES ☐	NO ☒	
6) Is Ash Being Removed During Inspection?	YES ☐	NO ☒	
7) Water Level in Pond	NORMAL ☐	HIGH ☐	LOW ☒

PHYSICAL INSPECTION:

Is the impoundment incised? YES ☐ NO ☒ If yes, skip down to Question 9.

	YES	NO
1) Seepage from or through embankment?	☐	☒
2) Sinkholes/Depressions/Bulges in Pond or embankments?	☐	☒
3) Signs of Piping/Channels or other Internal Erosion on embankments?	☐	☒
4) Cracking on Embankments/Berms?	☐	☒
5) Animal Burrows on embankments?	☐	☒
6) Excessive or Lacking Vegetative Cover on embankments?	☐	☒
7) Slope Erosion on berms or embankments?	☐	☒
8) Debris on embankments/berms?	☐	☒

9) Deterioration, malfunctions, or improper operation of overtopping control systems ☐ ☒

10) Visible Releases ☐ ☒

11) If Yes to any of the above, or any other abnormalities are noted, please describe/explain:

12) Is there any damage to Pond Liner: YES ☐ NO ☒ N/A ☐

12.a) If YES, Describe in Detail: _____

12.b) Specific Location: _____

:

12.c) Is Water Level Below Damage? YES ☐ NO ☐ N/A ☒

12.d) If No, Did You Reduce Pond Level? YES ☐ N/A ☒

12.e) Notified Shift Supervisor of Damage? YES ☐ Date Notified: _____ N/A ☒

12.f) Notified Station Management of Damage? YES ☐ Date Notified: _____ N/A ☒

12.g) Additional Comments: _____

30-DAY INSPECTION OF UNIT INSTRUMENTATION

	GOOD	NEEDS REPAIR	N/A
1) Pump Conditions	☐	☐	☒
2) Aluminum Sulfate System	☐	☐	☒
3) Wetwell/Basin Level	☐	☐	☒
4) Freeboard Measuring Device(s)	☐	☐	☒
5) Other Device(s) (pH meter)	☐	☐	☒

Describe any "Needs Repair" checked above:

Inspector: Inspector: [REDACTED] _____

WEEKLY INSPECTION CHECKLIST FOR SURFACE IMPOUNDMENTS

INSTRUCTIONS:

- 1) An inspection of each ash pond and related embankments/berms at the Station must be conducted:
 - a. Not less than every 7 days, and
 - b. Within 24 hours after a storm event greater than or equal to 6.20 inches.
- 2) The inspection must be conducted by a “qualified person” and the inspection records should be maintained at the Station for five years.
- 3) This is for all active and inactive ponds.
- 4) Not less than every 30 days, the qualified person must also inspect the CCR Unit Instrumentation.

GENERAL INFORMATION:

1) Date	09-17-2025		
2) Pond Name	Ash Bypass Basin (ABB)		
3) Type of Inspection	7-day ☒	Storm Event ☐	
4) General Condition	EMPTY ☐	FULL ☒	
5) In Service	YES ☒	NO ☐	
6) Is Ash Being Removed During Inspection?	YES ☐	NO ☒	
7) Water Level in Pond	NORMAL ☒	HIGH ☐	LOW ☐

PHYSICAL INSPECTION:

Is the impoundment incised? YES ☐ NO ☒ If yes, skip down to Question 9.

	YES	NO
1) Seepage from or through embankment?	☐	☒
2) Sinkholes/Depressions/Bulges in Pond or embankments?	☐	☒
3) Signs of Piping/Channels or other Internal Erosion on embankments?	☐	☒
4) Cracking on Embankments/Berms?	☐	☒
5) Animal Burrows on embankments?	☐	☒
6) Excessive or Lacking Vegetative Cover on embankments?	☐	☒
7) Slope Erosion on berms or embankments?	☐	☒
8) Debris on embankments/berms?	☐	☒
9) Deterioration, malfunctions, or improper operation of overtopping control systems	☐	☒

10) Visible Releases

☐☒

If Yes to any of the above, or any other abnormalities are noted, please describe/explain:

1) Is there any damage to Pond Liner: YES ☐ NO ☒ N/A ☐

12.a) If YES, Describe in Detail:

12.b) Specific Location: _____

12.c) Is Water Level Below Damage? YES ☐ NO ☐ N/A ☒

12.d) If No, Did You Reduce Pond Level? YES ☐ N/A ☒

12.e) Notified Shift Supervisor of Damage? YES ☐ Date Notified: _____ N/A ☒

12.f) Notified Station Management of Damage? YES ☐ Date Notified: _____ N/A ☒

12.g) Additional Comments: _____

30-DAY INSPECTION OF UNIT INSTRUMENTATION

	GOOD	NEEDS REPAIR	N/A
1) Pump Conditions	☒	☐	☐
2) Polymer System	☒	☐	☐
3) Wetwell/Basin Level	☒	☐	☐
4) Freeboard Measuring Device(s)	☐	☐	☒
5) Other Device(s) (pH meter)	☒	☐	☐

Describe any "Needs Repair" checked above: _____

Inspector: Inspector: [REDACTED] _____

WEEKLY INSPECTION CHECKLIST FOR SURFACE IMPOUNDMENTS (FAB)

INSTRUCTIONS:

- 1) An inspection of each ash pond and related embankments/berms at the Stations must be conducted:
 - a. Not less than every 7 days, and
 - b. Within 24 hours after a storm event greater or equal to 6.20 inches.
- 2) The inspection must be conducted by a “qualified person” and the inspection records should be maintained at the Station for five years.
- 3) This is for all active and inactive ponds.
- 4) Not less than every 30 days, the qualified person must also inspect the CCR Unit Instrumentation.

GENERAL INFORMATION:

1) Date	09-17-2025		
2) Pond Name	Former Ash Basin (FAB)		
3) Type of Inspection	7-day ☒	Storm Event ☐	
4) General Condition	EMPTY ☒	FULL ☐	
5) In Service	YES ☐	NO ☒	
6) Is Ash Being Removed During Inspection?	YES ☐	NO ☒	
7) Water Level in Pond	NORMAL ☐	HIGH ☐	LOW ☒

PHYSICAL INSPECTION:

Is the impoundment incised? YES ☐ NO ☒ If yes, skip down to Question 9.

	YES	NO
1) Seepage from or through embankment?	☐	☒
2) Sinkholes/Depressions/Bulges in Pond or embankments?	☐	☒
3) Signs of Piping/Channels or other Internal Erosion on embankments?	☐	☒
4) Cracking on Embankments/Berms?	☐	☒
5) Animal Burrows on embankments?	☐	☒
6) Excessive or Lacking Vegetative Cover on embankments?	☒	☐
7) Slope Erosion on berms or embankments?	☒	☐
8) Debris on embankments/berms?	☐	☒
9) Deterioration, malfunctions, or improper operation of overtopping control systems	☐	☒

10) Visible Releases

☐☒

11) If Yes to any of the above, or any other abnormalities are noted, please describe/explain:

There are some large trees growing in the embankment and one area where the side of the embankment appears to have eroded. No significant changes in these conditions were observed.

12) Is there any significant damage to the embankment: YES ☐ NO ☒

12.a) If YES, Describe in Detail: _____

12.b) Specific Location: _____

12.c) Is Water Level Below Damage? YES ☐ NO ☐ N/A ☒

12.d) If No, Did You Reduce Pond Level? YES ☐ N/A ☒

12.e) Notified Shift Supervisor of Damage? YES ☐ Date Notified: _____ N/A ☒

12.f) Notified Station Management of Damage? YES ☐ Date Notified: _____ N/A ☒

12.g) Additional Comments: _____

Inspector: _____ 

WEEKLY INSPECTION CHECKLIST FOR SURFACE IMPOUNDMENTS

INSTRUCTIONS:

- 1) An inspection of each ash pond and related embankments/berms at the Station must be conducted:
 - a. Not less than every 7 days, and
 - b. Within 24 hours after a storm event greater than or equal to 6.20 inches.
- 2) The inspection must be conducted by a “qualified person” and the inspection records should be maintained at the Station for five years.
- 3) This is for all active and inactive ponds.
- 4) Not less than every 30 days, the qualified person must also inspect the CCR Unit Instrumentation.

GENERAL INFORMATION:

1) Date	09-17-2025		
2) Pond Name	Metal Cleaning Basin (MCB)		
3) Type of Inspection	7-day ☒	Storm Event ☐	
4) General Condition	EMPTY ☒	FULL ☐	
5) In Service	YES ☐	NO ☒	
6) Is Ash Being Removed During Inspection?	YES ☐	NO ☒	
7) Water Level in Pond	NORMAL ☐	HIGH ☐	LOW ☒

PHYSICAL INSPECTION:

Is the impoundment incised? YES ☐ NO ☒ If yes, skip down to Question 9.

	YES	NO
1) Seepage from or through embankment?	☐	☒
2) Sinkholes/Depressions/Bulges in Pond or embankments?	☐	☒
3) Signs of Piping/Channels or other Internal Erosion on embankments?	☐	☒
4) Cracking on Embankments/Berms?	☐	☒
5) Animal Burrows on embankments?	☐	☒
6) Excessive or Lacking Vegetative Cover on embankments?	☐	☒
7) Slope Erosion on berms or embankments?	☐	☒
8) Debris on embankments/berms?	☐	☒

- 9) Deterioration, malfunctions, or improper operation of overtopping control systems ☐ ☒
- 10) Visible Releases ☐ ☒

11) If Yes to any of the above, or any other abnormalities are noted, please describe/explain:

12) Is there any damage to Pond Liner: YES ☐ NO ☒ N/A ☐

12.a) If YES, Describe in Detail: _____

12.b) Specific Location: _____

12.c) Is Water Level Below Damage? YES ☐ NO ☒ N/A ☒

12.d) If No, Did You Reduce Pond Level? YES ☐ N/A ☒

12.e) Notified Shift Supervisor of Damage? YES ☐ Date Notified: _____ N/A ☒

12.f) Notified Station Management of Damage? YES ☐ Date Notified: _____ N/A ☒

12.g) Additional Comments: _____

30-DAY INSPECTION OF UNIT INSTRUMENTATION

	GOOD	NEEDS REPAIR	N/A
1) Pump Conditions	☐	☐	☒
2) Polymer System	☐	☐	☒
3) Wetwell/Basin Level	☐	☐	☒
4) Freeboard Measuring Device(s)	☐	☐	☒
5) Other Device(s) (pH meter)	☐	☐	☒

Describe any "Needs Repair" checked above: _____ Instrumentation is only used during wastewater treatment. Currently not treating so no instrumentation is in use.

Inspector: _____ [REDACTED] _____