




MEMORANDUM

DATE: December 14, 2024

TO: **Mr. Richard Gray**
Environmental Specialist
NRG Energy Services
Plum Point Entergy Station

FROM: **Jason J Ghidotti, PE** 
Olsson FTN

SUBJECT: 2024 Annual Inspection of CCR Dust Control System for PPES CCR Landfill
Olsson Project No. 024-07122

Olsson FTN (Olsson) has been contracted by Plum Point Services Company, LLC (PPSC) to prepare the 2024 annual Coal Combustion Residue (CCR) fugitive dust control report for the Plum Point Energy Station (PPES) CCR Landfill located in Osceola, Arkansas. This technical memorandum provides a summary of the assessment of the PPES plant fugitive dust control system from December 2023 through November 2024 and findings from an inspection by Olsson on December 13, 2024.

In accordance with §257.80(c), the purpose of the report is to provide a summary of the:

1. Actions taken by the Owner or Operator to control CCR fugitive dust,
2. Citizen complaints regarding fugitive dust, and
3. Any corrective measures taken during the reporting period.

The PPES facility has a Fugitive Dust Control Plan (FTN Associates, Ltd., October 2015) that provides information on potential sources of dust; fugitive dust control measures; methods for inspection, monitoring, and recordkeeping; and periodic assessment of the plan. A copy of the plan is kept in the office of the PPES Environmental Manager and the offices of the PPES CCR management company, Charah Solutions, Inc. (Charah).

Fugitive Dust Control Measures

NRG Energy Services (NRG), the power plant, and Charah manage fugitive dust at the PPES Landfill in accordance with the CCR Fugitive Dust Control Plan. These measures include:

1. Adhering to the speed limit posted on the haul road from the CCR loading station at the plant to the active disposal area.

2. Using adequate water to blend into the CCR materials in the pug mill to minimize fugitive dust during truck loading operations, but not too much to create excess free liquids.
3. Using a street sweeper with water spraying capability on the paved portion of the haul road at least once per shift. The frequency of sweeping/wetting activities is increased (drier conditions) or decreased (rain or snow) depending on the weather.
4. Applying water on the gravel portion of the haul road. Water is applied at a sufficient rate to control dust, but not to create excessive runoff. Water is applied more frequently in drier or windy conditions.
5. Cleaning out haul truck beds in the active disposal area on an as-needed basis to remove materials left in the truck bed.
6. Wetting ancillary gravel roads not used to haul ash material on an as-needed basis.
7. Wetting CCR material in the active disposal area if the material becomes too dry before grading of the waste.

Charah inspects the CCR loading area and the haul road at least twice daily during active hauling and disposal operations and keeps records of the sweeping and wetting operations. Copies of the records are included as Attachment 1. In addition, Charah performs the weekly inspection of the landfill, which includes assessing the condition of the CCR disposal and grading operations. Copies of these inspections during the reporting period are included as Attachment 2.

An inspection by an Olsson engineer on December 13, 2024, along with an interview of the Landfill Manger, confirmed usage of the fugitive dust control measures listed above. Attachment 3 provides photos of the landfill and haul roads taken during the inspection.

Citizen Complaints During the Reporting Period

There were no citizen complaints regarding fugitive dust from the PPES plant or the Landfill during the reporting period.

Corrective Measures Taken During the Reporting Period

There were no corrective measures implemented by NRG or Charah during the reporting period.

If you have any questions or comments regarding this memorandum, please feel free to contact me or Alex Krepps, PE, at (501) 225-7779.

ATTACHMENT 1

Logs of Sweeping and Wetting of CCR Haul Road

2023
DECEMBER

Plum Point

Dust Control Log

Date	Actively working? ¹	Weather ^{2, 7, 8}	Method(s) Used to Control Dust ³				*Is dust present? ⁴		*Is erosion present? ⁵		Preventative or Corrective Action	Initials
	Yes/No	Temperature range, rainfall data, wind speeds,	Currently Percipitating (Y/N)	Water Truck	Alternative Cover	Other	Yes	No	Yes	No	Examples: Added more water, applied additional alternative cover material.	
12/1/2023	YES	59 SW 9 MPH CLOUDY	NO	YES	N/A			N/O		N/O		EW
	YES	62 SW 11 MPH CLOUDY	NO	YES	N/A			N/O		N/O		EW
12/2/2023	YES	46 NNE 5 MPH CLOUDY	NO	YES	N/A			N/O		N/O		EW
	YES	56 NNE 7 MPH CLOUDY	NO	YES	N/A			N/O		N/O		EW
12/3/2023	YES	51 SW 7 MPH CLOUDY	NO	YES	N/A			N/O		N/O		EW
	YES	57 SSW 3 MPH CLEAR	NO	YES	N/A			N/O		N/O		EW
12/4/2023	YES	47 W 13 MPH CLEAR	NO	YES	N/A			N/O		N/O		EW
	YES	50 NW13 MPH CLOUDY	NO	YES	N/A			N/O		N/O		EW
12/5/2023	YES	54 WNW 9 MPH CLEAR	NO	YES	N/A			N/O		N/O		EW
	YES	58 WNW 18 MPH CLEAR	NO	YES	N/A			N/O		N/O		EW
12/6/2023	YES	44 NNW 3 MPH CLEAR	NO	YES	N/A			N/O		N/O		EW
	YES	49 NW 3 MPH CLEAR	NO	YES	N/A			N/O		N/O		EW
12/7/2023	YES	48 SSW 11 MPH CLEAR	NO	YES	N/A			N/O		N/O		EW
	YES	60 SSW 14 MPH CLEAR	NO	YES	N/A			N/O		N/O		EW
12/8/2023	YES	50 SW 7 MPH CLOUDY	NO	YES	N/A			N/O		N/O		JB
	YES	63 SSW 11 MPH CLOUDY	NO	YES	N/A			N/O		N/O		JB
12/9/2023	YES	61 SSW 11 MPH CLOUDY	NO	YES	N/A			N/O		N/O		JB
	YES	61 NW8 MPH RAIN	YES	NO	N/A			N/O		N/O		JB
12/10/2023	YES	40 NNW 12 MPH CLEAR	NO	YES	N/A			N/O		N/O		EW
	YES	46 NNW 11 MPH CLEAR	NO	YES	N/A			N/O		N/O		EW
12/11/2023	YES	43 SE 4 MPH CLEAR	NO	YES	N/A			N/O		N/O		EW
	YES	50 S 8 MPH CLEAR	NO	YES	N/A			N/O		N/O		EW
12/12/2023	YES	38 S3 MPH CLEAR	NO	YES	N/A			N/O		N/O		EW
	YES	55 S 5 MPH CLEAR	NO	YES	N/A			N/O		N/O		EW
12/13/2023	YES	50 N 4 MPH CLEAR	NO	YES	N/A			N/O		N/O		EW
	YES	57 NE 5 MPH CLEAR	NO	YES	N/A			N/O		N/O		EW
12/14/2023	YES	48 NE 3 MPH CLEAR	NO	YES	N/A			N/O		N/O		BM
	YES	54 NNE 5 MPH CLEAR	NO	YES	N/A			N/O		N/O		BM
12/15/2023	YES	40 ESE 5 MPH CLEAR	NO	YES	N/A			N/O		N/O		EW
	YES	58 SE 10 MPH CLOUDY	NO	YES	N/A			N/O		N/O		EW
12/16/2023	YES	49 S 6 MPH CLOUDY	NO	YES	N/A			N/O		N/O		EW
	YES	57 S 11 MPH RAIN	NO	YES	N/A			N/O		N/O		EW
12/17/2023	YES	44 N 4 MPH CLOUDY	NO	YES	N/A			N/O		N/O		EW
	YES	49 NW 7 MPH CLOUDY	NO	YES	N/A			N/O		N/O		EW
12/18/2023	YES	39 NW 7 MPH CLEAR	NO	YES	N/A			N/O		N/O		EW
	YES	48 NNW 15 CLEAR	NO	YES	N/A			N/O		N/O		EW
12/19/2023	YES	37 ESE 7 MPH CLEAR	NO	YES	N/A			N/O		N/O		EW
	YES	46 SE 6 MPH OVERCAST	NO	YES	N/A			N/O		N/O		EW
12/20/2023	YES	34 SSE 7 MPH CLEAR	NO	YES	N/A			N/O		N/O		EW
	YES	54 S 7 MPH CLOUDY	NO	YES	N/A			N/O		N/O		EW
12/21/2023	YES	50 S4 MPH CLEAR	NO	YES	N/A			N/O		N/O		EW
	YES	56 S 4 MPH CLEAR	NO	YES	N/A			N/O		N/O		EW
12/22/2023	YES	55 S 7 MPH CLOUDY	NO	YES	N/A			N/O		N/O		EW
	YES	59 S 6 MPH CLOUDY	NO	YES	N/A			N/O		N/O		EW
12/23/2023	YES	60 S 6 MPH CLOUDY	NO	YES	N/A			N/O		N/O		JB
	YES	64 S 7 MPH CLOUDY	NO	YES	N/A			N/O		N/O		JB
12/24/2023	YES	60 SE 13 MPH CLOUDY	NO	YES	N/A			N/O		N/O		EW
	YES	63 SE 14 MPH CLOUDY	NO	YES	N/A			N/O		N/O		EW
12/25/2023		CHRISTMAS									CHRISTMAS	
		CHRISTMAS									CHRISTMAS	
12/26/2023	YES	39 S 6 MPH CLEAR	NO	YES	N/A			NO		N/O		EW
	YES	49 SW 6 MPH CLEAR	NO	YES	N/A			NO		N/O		EW
11/27/2023	YES	40 W 9 MPH CLOUDY	NO	YES	N/A			NO		N/O		EW
	YES	45 W 8 MPH CLOUDY	NO	YES	N/A			NO		N/O		EW
11/28/2023	YES	36 NW 4 MPH CLOUDY	NO	YES	N/A			NO		N/O		EW
	YES	41 WNW 7 MPH CLOUDY	NO	YES	N/A			NO		N/O		EW
12/29/2023	YES	38 W 12 MPH CLOUDY	NO	YES	N/A			NO		N/O		EW
	YES	41 WNW 10 MPH CLOUDY	NO	YES	N/A			NO		N/O		EW
12/30/2023	YES	36 SW 6 MPH CLOUDY	NO	YES	N/A			NO		N/O		EW
	YES	47 SW 10 MPH CLEAR	NO	YES	N/A			NO		N/O		EW
31-Dec	YES	37 SSW 6 MPH CLEAR	NO	NO	N/A			NO		N/O		EW
	YES	49 NW 9 MPH CLOUDY	NO	NO	N/A			NO		N/O		EW

2024 Plum Point Dust Control Log
JANUARY

Date	Actively working? ¹ Yes/No	Weather ^{2, 7, 8}		Method(s) Used to Control Dust ³				*Is dust present? ⁴		*Is erosion present? ⁵		Preventative or Corrective Action Examples: Added more water, applied additional alternative cover material.	Initials
		Temperature range, rainfall data, wind speeds,	Currently Percipitating (Y/N)	Water Truck	Alternative Cover	Other	Yes	No	Yes	No			
1/1/2024													
1/2/2024	YES	40 SW 5 MPH CLOUDY	NO	YES	N/A			NO	NO				EW
1/3/2024	YES	43 WSW 4 MPH CLOUDY	NO	YES	N/A			NO	NO				EW
1/3/2024	YES	34 S 2 MPH CLOUDY	NO	YES	N/A			NO	NO				EW
1/3/2024	YES	46 WSW 5 MPH CLEAR	NO	YES	N/A			NO	NO				EW
1/4/2024	NO	36 NE 11 MPH CLOUDY	NO	NO	N/A			NO	NO				EW
1/4/2024	NO	44 NE 9 MPH CLEAR	NO	YES	N/A			NO	NO				EW
1/5/2024	YES	31 NNE 4 MPH CLOUDY	NO	NO	N/A			NO	NO				EW
1/5/2024	YES	38 NE 6 MPH CLOUDY	NO	YES	N/A			NO	NO				EW
1/6/2024	YES	39 W 7 MPH CLOUDY	NO	YES	N/A			NO	NO				JB
1/6/2024	YES	42 W 9 MPH CLOUDY	NO	YES	N/A			NO	NO				JB
1/7/2024	YES	35 SW 8 MPH CLOUDY	NO	YES	N/A			NO	NO				EW
1/7/2024	YES	49 W 9 MPH CLEAR	NO	YES	N/A			NO	NO				EW
1/8/2024	YES	39 ESE 11 MPH CLOUDY	NO	YES	N/A			NO	NO				EW
1/8/2024	YES	48 ESE 15 MPH CLOUDY	NO	YES	N/A			NO	NO				EW
1/9/2024	NO	46 SW 17 MPH RAIN	YES	NO	N/A			NO	NO				EW
1/9/2024	NO	40 WSW 24 MPH CLOUDY	YES	NO	N/A			NO	NO				EW
1/10/2024	YES	39 SW 7 MPH CLEAR	NO	YES	N/A			NO	NO				EW
1/10/2024	YES	47 SSW 13 CLEAR	NO	YES	N/A			NO	NO				EW
1/11/2024	YES	35 SSE 2 MPH CLEAR	NO	YES	N/A			NO	NO				EW
1/11/2024	YES	57 SE 9 MPH CLEAR	NO	YES	N/A			NO	NO				EW
1/12/2024	YES	48 SW 11 MPH CLOUDY	NO	YES	N/A			NO	NO				EW
1/12/2024	NO	52 SW 23 MPH CLOUDY	NO	YES	N/A			NO	NO				EW
1/13/2024	YES	37 SSW 4 MPH CLOUDY	NO	NO	N/A			NO	NO				EW
1/13/2024	YES	41 SSW 8 MPH CLOUDY	NO	YES	N/A			NO	NO				BM
1/14/2024	YES	17 N 11 MPH CLOUDY	NO	NO	N/A			NO	NO				BM
1/14/2024	YES	21 N 9 MPH CLOUDY	NO	NO	N/A			NO	NO				EW
1/15/2024	YES	10 N 12 MPH CLOUDY	NO	NO	N/A			NO	NO				EW
1/15/2024	YES	12 N 12 MPH CLOUDY	NO	NO	N/A			NO	NO				EW
1/16/2024	YES	9 W 9 MPH CLEAR	NO	NO	N/A			NO	NO				EW
1/16/2024	YES	15 W 7 MPH CLEAR	NO	NO	N/A			NO	NO				EW
1/17/2024	YES	22 SSW 14 MPH CLOUDY	NO	NO	N/A			NO	NO				EW
1/17/2024	YES	28 S 11 MPH CLOUDY	NO	NO	N/A			NO	NO				EW
1/18/2024	YES	32 S 3 MPH RAIN	YES	NO	N/A			NO	NO				EW
1/18/2024	YES	31 S 4 MPH RAIN	YES	NO	N/A			NO	NO				EW
1/19/2024	YES	21 NNW 16 PARTLY CLOUDY	NO	NO	N/A			NO	NO				EW
1/19/2024	YES	25 NNW 16 MPH CLEAR	NO	NO	N/A			NO	NO				EW
1/20/2024	YES	15 N 10 MPH CLEAR	NO	NO	N/A			NO	NO				JB
1/20/2024	YES	18 NNE 10 MPH CLEAR	NO	NO	N/A			NO	NO				JB
1/21/2024	YES	20 ESE 9 MPH CLOUDY	NO	NO	N/A			NO	NO				EW
1/21/2024	YES	30 SE 7 MPH CLOUDY	NO	NO	N/A			NO	NO				EW
1/22/2024	YES	38 SE 8 MPH CLOUDY	NO	NO	N/A			NO	NO				EW
1/22/2024	YES	43 SE 8 MPH CLOUDY	NO	NO	N/A			NO	NO				EW
1/23/2024	YES	48 SSE 7 MPH RAIN	YES	NO	N/A			NO	NO				EW
1/23/2024	YES	55 SE 8 MPH RAIN	YES	NO	N/A			NO	NO				EW
1/24/2024	YES	61 W 5 MPH CLOUDY	NO	NO	N/A			NO	NO				EW
1/24/2024	YES	59 W 9 W 5 MPH RAIN	YES	NO	N/A			NO	NO				EW
1/25/2024	YES	51 W 4 MPH RAIN	YES	NO	N/A			NO	NO				EW
1/25/2024	YES	57 W 4 MPH RAIN	YES	NO	N/A			NO	NO				EW
1/26/2024	YES	50 NNE 5 CLOUDY	NO	YES	N/A			NO	NO				EW
1/26/2024	YES	48 NNE 5 CLOUDY	NO	YES	N/A			NO	NO				EW
1/27/2024	NO	43 NNE 16 MPH RAIN	YES	NO	N/A			NO	NO				JB
1/27/2024	NO	42 N 17 MPH RAIN	YES	NO	N/A			NO	NO				JB
1/28/2024	NO	40 NW 12 MPH CLOUDY	NO	NO	N/A			NO	NO				EW
1/28/2024	NO	43 NW 11 MPH CLOUDY	NO	NO	N/A			NO	NO				EW
1/29/2024	YES	36 N4 MPH CLOUDY	NO	NO	N/A			NO	NO				EW
1/29/2024	YES	46 W2 MPH CLOUDY	NO	NO	N/A			NO	NO				EW
1/30/2024	YES	41 SSW 7 MPH CLEAR	NO	YES	N/A			NO	NO				EW
1/30/2024	YES	56 WNW 10 CLEAR	NO	YES	N/A			NO	NO				EW
1/31/2024	YES	49 NNW 4 MPH CLEAR	NO	YES	N/A			NO	NO				EW
1/31/2024	YES	52 NNW 4 MPH CLEAR	NO	YES	N/A			NO	NO				EW

2024

Plum Point

Dust Control Log

Month: FEBRUARY

Date	Actively working? ¹		Weather ^{2, 7, 8}	Method(s) Used to Control Dust ³				*Is dust present? ⁴		*Is erosion present? ⁵		Preventative or Corrective Action Taken	Initials
	Yes/No	Temperature range, rainfall data, wind speeds,	Currently Percipitating (Y/N)	Water Truck	Alternative Cover	Other	Yes	No	Yes	No	Examples: Added more water, applied additional alternative cover material,		
2/1/2024	YES	50 SSW 4 MPH CLEAR	NO	YES	N/A			NO		NO		BM	
2/1/2024	YES	58 S 9 MPH CLEAR	NO	YES	N/A			NO		NO		BM	
2/2/2024	YES	55 S5 MPH CLEAR	NO	YES	N/A			NO		NO		BM	
2/2/2024	YES	63 S 4 MPH PARTLY CLOUDY	NO	YES	N/A			NO		NO		BM	
2/3/2024	YES	57 ESE 7 MPH CLEAR	NO	YES	N/A			NO		NO		JB	
2/3/2024	YES	65 SE 9 MPH CLEAR	NO	YES	N/A			NO		NO		JB	
2/4/2024	NO	48 ENE 17 MPH RAIN	YES	NO	N/A			NO		NO		EW	
2/4/2024	NO	48 ENE 14 MPH RAIN	YES	NO	N/A			NO		NO		EW	
2/5/2024	YES	46 N 14 MPH CLOUDY	NO	NO	N/A			NO		NO		EW	
2/5/2024	YES	54 N 15 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
2/6/2024	YES	40 SE 2 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/6/2024	YES	57 SSE 4 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/7/2024	YES	51 SSE 4 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/7/2024	YES	62 SSE4 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/8/2024	YES	57 S 17 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/8/2024	YES	63 SSW 16 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
2/9/2024	YES	59 S 10 MPH RAIN	YES	NO	N/A			NO		NO		EW	
2/9/2024	YES	64 SSW 13 MPH RAIN	YES	NO	N/A			NO		NO		EW	
2/10/2024	YES	47 NNE 23 MPH RAIN	YES	NO	N/A			NO		NO		EW	
2/10/2024	YES	49 NNE 13 MPH RAIN	YES	NO	N/A			NO		NO		EW	
2/11/2024	YES	44 NNE 12 MPH RAIN	YES	NO	N/A			NO		NO		EW	
2/11/2024	YES	48 NE 12 MPH RAIN	YES	NO	N/A			NO		NO		EW	
2/12/2024	YES	45 WSW 4 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
2/12/2024	YES	53 W 6 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
2/13/2024	YES	48 WSW 4 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/13/2024	YES	51 WSW 6 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/14/2024	YES	53 S 5 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/14/2024	YES	63 SSW 8 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/15/2024	YES	54 SW 4 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/15/2024	YES	65 WSW 6 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/16/2024	YES	54 SSE 9 MPH CLOUDY	NO	YES	N/A			NO		NO		BM	
2/16/2024	NO	60 SW 11 MPH RAIN	YES	NO	N/A			NO		NO		BM	
2/17/2024	YES	32 N 15 MPH CLOUDY	NO	YES	N/A			NO		NO		JB	
2/17/2024	YES	39 N 10 MPH CLEAR	NO	YES	N/A			NO		NO		JB	
2/18/2024	YES	40 SW 10 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/18/2024	YES	44 WSW 10 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/19/2024	YES	52 SSW 5 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/19/2024	YES	57 SSW 8 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/20/2024	YES	41 S 2 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/20/2024	YES	63 SSW 5 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/21/2024	YES	44 SSE 8 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/21/2024	YES	70 SSW 15MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
2/22/2024	YES	60 SSW 16 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
2/22/2024	YES	64 SW 16 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
2/23/2024	YES	61 NW 14 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/23/2024	YES	63 WNW 13 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/24/2024	YES	48 N 8 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/24/2024	YES	54 N 8 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/25/2024	YES	61 S 17 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/25/2024	YES	71 SSW 17 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/26/2024	YES	69 SSW 16 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
2/26/2024	YES	72 SSW 17MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
2/27/2024	NO	69 SSW 17 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/27/2024	NO	77 SSW 23 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/28/2024	YES	45 NNW 16 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
2/28/2024	YES	44 NNW 15 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
2/29/2024	YES	42 S 7 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
2/29/2024	YES	49 SSW6 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	

2024

Plum Point

Dust Control Log

Month: MARCH

Date	Actively working? ¹		Weather ^{2,7,8}	Method(s) Used to Control Dust ³				*Is dust present? ⁴		*Is erosion present? ⁵		Preventative or Corrective Action Taken	Initials
	Yes/No	Temperature range, rainfall data, wind speeds,	Currently Percipitating (Y/N)	Water Truck	Alternative Cover	Other	Yes	No	Yes	No	Examples: Added more water, applied additional alternative cover material,		
3/1/2024	YES	45 S7 MPH CLOUDY	NO	YES	N/A			NO		NO		BM	
	YES	47 S 6 MPH CLOUDY	NO	YES	N/A			NO		NO		BM	
3/2/2024	YES	58 SSE 9 MPH CLEAR	NO	YES	N/A			NO		NO		JB	
	YES	63 SSE 11 MPH CLEAR	NO	YES	N/A			NO		NO		JB	
3/3/2024	YES	66 SSW 14 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
	YES	72 SSW 14 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
3/4/2024	YES	77 S 14 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
	YES	80 S 16 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
3/5/2024	YES	70 S 10 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
	YES	71 SSW 5 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
3/6/2024	YES	57 NNE 11 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
	YES	64 N 7 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
3/7/2024	YES	54 ESE 4 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
	YES	65 SW6 MPH RAIN	YES	NO	N/A			NO		NO		EW	
3/8/2024	YES	60 S 7 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
	YES	64 S 7 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
3/9/2024	YES	48 NNW 15 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
	YES	52 NW 11 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
3/10/2024	YES	38 N 6 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
	YES	52 NNW 8 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
3/11/2024	YES	49 S 6 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
	YES	60 SSW 10 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
3/12/2024	YES	44 SSE 6 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
	YES	67 SSW 12 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
3/13/2024	YES	66 SSW 11 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
	YES	78 SSW 13 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
3/14/2024	YES	68 S15 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
	YES	75 SSW 16 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
3/15/2024	YES	53 N15 MPH RAIN	YES	NO	N/A			NO		NO		BM	
	YES	53 N 9 MPH CLOUDY	NO	YES	N/A			NO		NO		BM	
3/16/2024	YES	57 W 3 MPH CLEAR	NO	YES	N/A			NO		NO		JB	
	YES	63 SW8 MPH CLOUDY	NO	YES	N/A			NO		NO		JB	
3/17/2024	YES	54 N13 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
	YES	57 NNW 9 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
3/18/2024	YES	40 NNW2 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
	YES	44 NW 17 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
3/19/2024	YES	40 WSW 16 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
	YES	55 SW 17 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
3/20/2024	YES	49 SW 6 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
	YES	67 WNW 5 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
3/21/2024	YES	50 ENE 7 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
	YES	67 E 8 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
3/22/2024	YES	67 ESE 4 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
	YES	66 SW 4 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
3/23/2024	YES	40 N 18 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
	YES	55 NNE 15 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
3/24/2024	YES	50 SE4 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
	YES	58 SE 8 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
3/25/2024	YES	63 SSW 22 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
	YES	66 SE 24 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
3/26/2024	YES	46 WSW 16 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
	YES	53 WSW15 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
3/27/2024	YES	53 N 6 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
	YES	56 N 9 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
3/28/2024	YES	37 SSW 1 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
	YES	62 WSW 5 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
3/29/2024	YES	45 S 3 MPH CLEAR	NO	YES	N/A			NO		NO		BM	
	YES	70 SSW 18 MPH CLEAR	NO	YES	N/A			NO		NO		BM	
3/30/2024	YES	59 SSW 12 MPH CLEAR	NO	YES	N/A			NO		NO		JB	
	YES	75 SW 17 MPH CLEAR	NO	YES	N/A			NO		NO		JB	
3/31/2024	YES	69 SSW 15 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
	YES	76 SSW 18 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	

2024

Plum Point

Dust Control Log

Month: APRIL

Date	Actively working? ¹		Weather ^{2, 7, 8}	Method(s) Used to Control Dust ³				*Is dust present? ⁴		*Is erosion present? ⁵		Preventative or Corrective Action Taken	Initials
	Yes/No	Temperature range, rainfall data, wind speeds,	Currently Percipitating (Y/N)	Water Truck	Alternative Cover	Other	Yes	No	Yes	No	Examples: Added more water, applied additional alternative cover material,		
4/1/2024	YES	73 SSW 13 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
4/1/2024	YES	78 SSW 14 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
4/2/2024	YES	72 WSW 21 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
4/2/2024	YES	75 W 20 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
4/3/2024	YES	51 NW 17 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
4/3/2024	NO	53 NNW 22 MPH CLOUDY	NO	NO	N/A			NO		NO		EW	
4/4/2024	YES	46 N 7 MPH CLOUDY	NO	YES	N/A			NO		NO		BM	
4/4/2024	YES	56 NE 12 MPH CLOUDY	NO	YES	N/A			NO		NO		BM	
4/5/2024	YES	55 NNW 7 MPH CLEAR	NO	YES	N/A			NO		NO		BM	
4/5/2024	YES	61 N 6 MPH CLEAR	NO	YES	N/A			NO		NO		BM	
4/6/2024	YES	46 E 7 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
4/6/2024	YES	60 ESE 8 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
4/7/2024	YES	66 S 20 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
4/7/2024	NO	75 SSW 21 CLOUDY	NO	YES	N/A			NO		NO		EW	
4/8/2024	YES	66 S 20 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
4/8/2024	YES	71 SSW 20 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
4/9/2024	YES	59 ESE 10 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
4/9/2024	YES	63 ESE 12 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
4/10/2024	YES	60 E 6 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
4/10/2024	YES	66 E 6 MPH CLOUDY	NO	YES	N/A			NO		NO		EW	
4/11/2024	YES	59 WNW 20 MPH RAIN	YES	NO	N/A			NO		NO		EW	
4/11/2024	YES	68 WNW 16 MPH CLEAR	NO	YES	N/A			NO		NO		EW	
4/12/2024	YES	46 W9 MPH SUNNY	NO	YES	N/A			NO		NO		BM	
4/12/2024	YES	66 WNW 16 MPH CLEAR	NO	YES	N/A			NO		NO		BM	
4/13/2024	NO	55 SSW 3 MPH CLEAR	NO	YES	N/A			NO		NO		JB	
4/13/2024	NO	77 SW 13 MPH CLEAR	NO	YES	N/A			NO		NO		JB	
4/14/2024	NO	74 SSW 20 MPH CLEAR	NO	NO	N/A			NO		NO		EW	
4/14/2024	NO	79 SSW 19 MPH CLEAR	NO	NO	N/A			NO		NO		EW	
4/15/2024	NO	78 SSW 10 MPH CLEAR	NO	NO	N/A			NO		NO		EW	
4/15/2024	NO	82 SSW 12 MPH CLEAR	NO	NO	N/A			NO		NO		EW	
4/16/2024	NO	70 S 8 MPH CLEAR	NO	NO	N/A			NO		NO		EW	
4/16/2024	NO	82 S 20 MPH CLEAR	NO	NO	N/A			NO		NO		EW	
4/17/2024	NO	77 WSW 7 MPH CLOUDY	NO	NO	N/A			NO		NO		EW	
4/17/2024	NO	83 WSW 10 MPH CLOUDY	NO	NO	N/A			NO		NO		EW	
4/18/2024	NO	80 SSW 14 MPH CLOUDY	NO	NO	N/A			NO		NO		EW	
4/18/2024	NO	82 SSW 14 MPH CLOUDY	NO	NO	N/A			NO		NO		EW	
4/19/2024	NO	54 N 14 MPH CLOUDY	NO	NO	N/A			NO		NO		EW	
4/19/2024	NO	64 NNE 12 CLOUDY	NO	NO	N/A			NO		NO		EW	
4/20/2024	NO	53 NNE 9 MPH CLOUDY	NO	NO	N/A			NO		NO		JB	
4/20/2024	NO	63 NE 10 MPH CLOUDY	NO	NO	N/A			NO		NO		JB	
4/21/2024	NO	55 N 15 MPH CLEAR	NO	NO	N/A			NO		NO		EW	
4/21/2024	NO	59 NNW 11 MPH CLEAR	NO	NO	N/A			NO		NO		EW	
4/22/2024	NO	40 CALM CLEAR	NO	NO	N/A			NO		NO		EW	
4/22/2024	NO	66 SSW 6 MPH CLEAR	NO	NO	N/A			NO		NO		EW	
4/23/2024	NO	71 SW 10 MPH CLEAR	NO	NO	N/A			NO		NO		EW	
4/23/2024	NO	75 SSW 17 MPH CLEAR	NO	NO	N/A			NO		NO		EW	
4/24/2024	NO	71 NNW 4 MPH CLEAR	NO	NO	N/A			NO		NO		EW	
4/24/2024	NO	76 NNW 9 MPH CLEAR	NO	NO	N/A			NO		NO		EW	
4/25/2024	NO	65 E 9 MPH CLOUDY	NO	NO	N/A			NO		NO		EW	
4/25/2024	NO	ESE 4 MPH RAIN	YES	NO	N/A			NO		NO		EW	
4/26/2024	NO	64 SSE 12 MPH CLOUDY	NO	NO	N/A			NO		NO		JB	
4/26/2024	NO	78 S 21 MPH CLOUDY	NO	NO	N/A			NO		NO		JB	
4/27/2024	NO	72 S 16 MPH CLOUDY	NO	NO	N/A			NO		NO		JB	
4/27/2024	NO	83 S 22 MPH CLOUDY	NO	NO	N/A			NO		NO		JB	
4/28/2024	NO	77 S 16 MPH CLOUDY	NO	NO	N/A			NO		NO		EW	
4/28/2024	NO	80 S 16 MPH CLOUDY	NO	NO	N/A			NO		NO		EW	
4/29/2024	NO	70 S 8 MPH RAIN	YES	NO	N/A			NO		NO		EW	
4/29/2024	NO	73 S 8 MPH CLOUDY	NO	NO	N/A			NO		NO		EW	
4/30/2024	NO	80 N 3 MPH CLEAR	NO	NO	N/A			NO		NO		EW	
4/30/2024	NO	83 N 3 MPH CLEAR	NO	NO	N/A			NO		NO		EW	

Month: MAY

2024

Plum Point

Dust Control Log

Date	Actively working? ¹		Weather ^{2, 7, 8}	Method(s) Used to Control Dust ³				*Is dust present? ⁴		*Is erosion present? ⁵		Preventative or Corrective Action Taken	Initials
	Yes/No	Temperature range, rainfall data, wind speeds,	Currently Percipitating (Y/N)	Water Truck	Alternative Cover	Other	Yes	No	Yes	No	Examples: Added more water, applied additional alternative cover material,		
5/1/2024													
5/1/2024	NO	77 N 3 MPH CLEAR	NO	NO				NO		NO			EW
	NO	83 N 3 MPH CLEAR	NO	NO				NO		NO			EW
5/2/2024	NO	78 SW 1 MPH CLOUDY	NO	NO				NO		NO			EW
	NO	86 SSW 8 MPH CLOUDY	NO	NO				NO		NO			EW
5/3/2024	NO	79 WSW 7 CLOUDY	NO	NO				NO		NO			EW
	NO	68 WSW 9 RAIN	YES	NO				NO		NO			EW
5/4/2024	NO	66 N 1 MPH CLOUDY	NO	NO				NO		NO			EW
	NO	77 SW 8 MPH CLOUDY	NO	NO				NO		NO			EW
5/5/2024	NO	78 ESE 4 MPH CLOUDY	NO	NO				NO		NO			EW
	NO	80 S 3 CLOUDY	NO	NO				NO		NO			EW
5/6/2024	NO	77 SW 8 MPH CLEAR	NO	NO				NO		NO			EW
	YES	82 SW 8 MPH CLEAR	NO	YES				NO		NO			EW
5/7/2024	YES	82 SSW 17 MPH CLOUDY	NO	YES				NO		NO			EW
	YES	84 SW 15 MPH CLOUDY	NO	YES				NO		NO			EW
5/8/2024	YES	79 SSW 12 MPH CLOUDY	NO	YES				NO		NO			EW
	YES	82 SSW 14 MPH CLOUDY	NO	YES				NO		NO			EW
5/9/2024	YES	79 WNW 8 MPH CLEAR	NO	YES				NO		NO			EW
	YES	80 WNW 11 MPH CLEAR	NO	YES				NO		NO			EW
5/10/2024	YES	61 N 8 MPH CLEAR	NO	YES				NO		NO			BM
	YES	73 N 12 MPH CLEAR	NO	YES				NO		NO			BM
5/11/2024	YES	62 W 4 MPH CLEAR	NO	YES				NO		NO			JB
	YES	79 WNW 8 MPH CLEAR	NO	YES				NO		NO			JB
5/12/2024	YES	60 E 1 MPH CLEAR	NO	YES				NO		NO			EW
	YES	79 SSW 5 MPH OVERCAST	NO	YES				NO		NO			EW
5/13/2024	YES	70 WSW 9 MPH CLOUDY	NO	YES				NO		NO			EW
	YES	75 WSW 9 MPH CLOUDY	NO	YES				NO		NO			EW
5/14/2024	YES	69 SW 7 MPH CLOUDY	NO	YES				NO		NO			EW
	YES	73 SW 11 MPH CLOUDY	NO	YES				NO		NO			EW
5/15/2024	YES	68 NNW 8 MPH CLOUDY	NO	YES				NO		NO			EW
	YES	77 NW 9 MPH CLOUDY	NO	YES				NO		NO			EW
5/16/2024	YES	68 S 3 MPH CLEAR	NO	YES				NO		NO			EW
	YES	81 SSW 6 MPH CLOUDY	NO	YES				NO		NO			EW
5/17/2024	YES	67 ENE 6 MPH CLOUDY	NO	YES				NO		NO			EW
	YES	77 ENE 3 MPH CLOUDY	NO	YES				NO		NO			EW
5/18/2024	YES	74 N 4 MPH RAIN	YES	NO				NO		NO			EW
	YES	80 NNW 5 MPH CLOUDY	NO	YES				NO		NO			EW
5/19/2024	YES	71 S SW 8 MPH CLOUDY	NO	YES				NO		NO			EW
	YES	83 SW 11 MPH CLEAR	NO	YES				NO		NO			EW
5/20/2024	YES	80 S 5 MPH CLEAR	NO	YES				NO		NO			EW
	YES	89 S 7 MPH CLEAR	NO	YES				NO		NO			EW
5/21/2024	YES	79 S 12 MPH CLEAR	NO	YES				NO		NO			EW
	YES	89 SSW 16 MPH CLEAR	NO	YES				NO		NO			EW
5/22/2024	YES	73 SW 5 MPH CLOUDY	NO	YES				NO		NO			EW
	YES	76 SW 5 MPH RAIN	YES	NO				NO		NO			EW
5/23/2024	YES	73 SW 5 MPH CLOUDY	NO	YES				NO		NO			BM
	YES	77 SSW 5 MPH CLEAR	NO	YES				NO		NO			BM
5/24/2024	YES	72 SSW 7 MPH CLEAR	NO	YES				NO		NO			BM
	YES	81 SSW 10 MPH CLEAR	NO	YES				NO		NO			BM
5/25/2024	YES	71 SSW 4 MPH CLEAR	NO	YES				NO		NO			JB
	YES	83 SSW 6 MPH CLEAR	NO	YES				NO		NO			JB
5/26/2024	YES	84 SSW 18 MPH CLOUDY	NO	YES				NO		NO			EW
	YES	87 SSW 21 MPH CLOUDY	NO	YES				NO		NO			EW
5/27/2024		MEMORIAL DAY											
		MEMORIAL DAY											
5/28/2024	YES	70 W 1 MPH CLEAR	NO	YES				NO		NO			BM
	YES	85 NW 9 MPH CLEAR	NO	YES				NO		NO			BM
5/29/2024	YES	76 NE 7 MPH CLEAR	NO	YES				NO		NO			EW
	YES	82 N 3 5 MPH OVERCAST	NO	YES				NO		NO			EW
5/30/2024	YES	73 E 8 MPH CLEAR	NO	YES				NO		NO			EW
	YES	81 ESE 7 MPH CLEAR	NO	YES				NO		NO			EW
31-May	YES	75 SW 9 MPH CLOUDY	NO	YES				NO		NO			EW
	YES	80 WSW 9 MPH CLOUDY	NO	YES				NO		NO			EW

Month: JUNE

2024

Plum Point

Dust Control Log

Date	Actively working? ¹		Weather ^{2, 7, 8}	Method(s) Used to Control Dust ³				*Is dust present? ⁴		*Is erosion present? ⁵		Preventative or Corrective Action Taken	Initials
	Yes/No		Temperature range, rainfall data, wind speeds,	Currently Percipitating (Y/N)	Water Truck	Alternative Cover	Other	Yes	No	Yes	No	Examples: Added more water, applied additional alternative cover material,	
6/1/2024	YES		75 SW 9 MPH CLOUDY	NO	YES				NO		NO		EW
	YES		80 WSW 9 MPH CLOUDY	NO	YES				NO		NO		EW
6/2/2024	YES		83 SW 3 MPH CLEAR	NO	YES				NO		NO		EW
	YES		84 SW 4 MPH CLEAR	NO	YES				NO		NO		EW
6/3/2024	YES		80 S 8 MPH CLEAR	NO	YES				NO		NO		EW
	YES		85 SSW 12 CLOUDY	NO	YES				NO		NO		EW
6/4/2024	YES		80 SW 16 MPH CLOUDY	NO	YES				NO		NO		EW
	YES		83 SW 16 MPH CLOUDY	NO	YES				NO		NO		EW
6/5/2024	YES		76 S 10 MPH CLOUDY	NO	YES				NO		NO		EW
	YES		82 ssw 11 mph cloudy	NO	YES				NO		NO		BM
6/6/2024	YES		83 NE 2 MPH CLEAR	NO	YES				NO		NO		BM
	YES		87 NE 4 MPH CLEAR	NO	YES				NO		NO		BM
6/7/2024	YES		76 NE 2 MPH CLEAR	NO	YES				NO		NO		JB
	YES		88 ENE 5 MPH CLEAR	NO	YES				NO		NO		JB
6/8/2024	NO		75 S6 MPH RAIN	YES	NO				NO		NO		EW
	NO		77 S 9 MPH CLOUDY	NO	YES				NO		NO		EW
6/9/2024	YES		75 N 7 MPH CLOUDY	NO	YES				NO		NO		EW
	NO		83 N 8 MPH PARTLY CLOUDY	NO	NO				NO		NO		EW
6/10/2024	YES		81 NNW 5 MPH SUNNY	NO	YES				NO		NO		EW
	YES		84 NNW 9 MPH SUNNY	NO	YES				NO		NO		EW
6/11/2024	YES		71 S 5 MPH SUNNY	NO	YES				NO		NO		EW
	YES		80 NE 7 MPH SUNNY	NO	YES				NO		NO		EW
6/12/2024	YES		78 NE 5 MPH SUNNY	NO	YES				NO		NO		EW
	YES		83 ENE 5 MPH SUNNY	NO	YES				NO		NO		EW
6/13/2024	YES		76 SE 2 MPH SUNNY	NO	YES				NO		NO		EW
	YES		89 S 2 MPH SUNNY	NO	YES				NO		NO		EW
6/14/2024	YES		90 SE 5 MPH CLOUDY	NO	YES				NO		NO		EW
	YES		93 SE 5 MPH CLOUDY	NO	YES				NO		NO		EW
6/15/2024	YES		92 SSE 4 MPH CLOUDY	NO	YES				NO		NO		EW
	YES		95 SSE 6 MPH CLOUDY	NO	YES				NO		NO		EW
6/16/2024													
6/17/2024	YES		80 S 10 MPH CLOUDY	NO	YES				NO		NO		EW
	YES		80 S 9 MPH CLOUDY	NO	YES				NO		NO		EW
6/18/2024	YES		79 ESE 6 MPH CLOUDY	NO	YES				NO		NO		EW
	YES		81 ESE 6 MPH CLOUDY	NO	YES				NO		NO		EW
6/19/2024	YES		81 SE 7 MPH CLOUDY	NO	YES				NO		NO		EW
	YES		85 ESE 7 MPH CLOUDY	NO	YES				NO		NO		EW
6/20/2024	YES		75 E 3 MPH SUNNY	NO	YES				NO		NO		EW
	YES		90 ESE 4 MPH SUNNY	NO	YES				NO		NO		EW
6/21/2024	YES		89 SE 4 MPH CLOUDY	NO	YES				NO		NO		EW
	YES		93 SE 4 MPH SUNNY	NO	YES				NO		NO		EW
6/22/2024	YES		75 WSW 3 MPH CLOUDY	NO	YES				NO		NO		EW
	YES		85 WSW 8 MPH CLOUDY	NO	YES				NO		NO		EW
6/23/2024	YES		89 WSW 9 CLOUDY	NO	YES				NO		NO		EW
	YES		91 WSW 11 MPH CLOUDY	NO	YES				NO		NO		EW
6/24/2024	YES		92 E 4 MPH SUNNY	NO	YES				NO		NO		EW
	YES		95 ESE 4MPH SUNNY	NO	YES				NO		NO		EW
6/25/2024	YES		94 WSW 4 MPH SUNNY	NO	YES				NO		NO		EW
	YES		97 WSW 7 MPH SUNNY	NO	YES				NO		NO		EW
6/26/2024	YES		78 SSW 11 MPH RAIN	YES	YES				NO		NO		EW
	NO		75 WSW 9 MPH CLOUDY	NO	YES				NO		NO		EW
6/27/2024	YES		76 NNE 12 MPH CLOUDY	NO	YES				NO		NO		EW
	YES		86 NE 10 MPH CLOUDY	NO	YES				NO		NO		EW
6/28/2024	YES		87 SW 6 MPH CLOUDY	NO	YES				NO		NO		EW
	YES		89 SW6 MPH CLOUDY	NO	YES				NO		NO		EW
6/29/2024	YES		90 WSW 9 MPH SUNNY	NO	YES				NO		NO		EW
	YES		94 WSW9 MPH SUNNY	NO	YES				NO		NO		EW
6/30/2024	YES		88 NNW 2 MPH SUNNY	NO	YES				NO		NO		EW
	YES		92 NW 12 CLOUDY	NO	YES				NO		NO		EW

2024

Plum Point

Dust Control Log

JULY

Date	Actively working? ¹	Weather ^{2, 7, 8}	Method(s) Used to Control Dust ³				*Is dust present? ⁴		*Is erosion present? ⁵		Preventative or Corrective Action	Initials
	Yes/No	Temperature range, rainfall data, wind speeds,	Currently Percipitating (Y/N)	Water Truck	Alternative Cover	Other	Yes	No	Yes	No	Examples: Added more water, applied additional alternative cover material.	
7/1/2024	YES	76 NE 8 MPH SUNNY	NO	YES				NO		NO		EW
	YES	82 NE 8 MPH SUNNY	NO	YES				NO		NO		EW
7/2/2024	YES	90 S 6 MPH SUNNY	NO	YES				NO		NO		EW
	YES	92 S 6 MPH SUNNY	NO	YES				NO		NO		EW
7/3/2024	YES	83 S 7 MPH SUNNY	NO	YES				NO		NO		EW
	YES	97 SSW 9 MPH SUNNY	NO	YES				NO		NO		EW
7/4/2024											HOLIDAY	
7/5/2024	YES	86 NE 4 MPH CLOUDY	NO	YES				NO		NO		BM
	YES	93 NE 6 MPH CLOUDY	NO	YES				NO		NO		BM
7/6/2024	YES	74 N 3 MPH SUNNY	NO	YES				NO		NO		EW
	NO	86 NE 7 MPH PARTLY CLOUDY	NO	NO				NO		NO		EW
7/7/2024	YES	84 NE 4 MPH SUNNY	NO	YES				NO		NO		EW
	NO	89 ENE 6 MPH SUNNY	NO	NO				NO		NO		EW
7/8/2024	YES	81 SSW 2 MPH CLOUDY	NO	YES				NO		NO		EW
	YES	83 SSW 7 MPH CLOUDY	NO	YES				NO		NO		EW
7/9/2024	YES	73 SSW 12 MPH RAIN	YES	NO				NO		NO		EW
	YES	74 SSW 13 MPH CLOUDY	NO	YES				NO		NO		EW
7/10/2024	YES	78 NW 6 MPH SUNNY	NO	YES				NO		NO		EW
	YES	84 WNW 6 MPH SUNNY	NO	YES				NO		NO		EW
7/11/2024	YES	77 SSW 1 MPH SUNNY	NO	YES				NO		NO		EW
	YES	90 W 3 MPH SUNNY	NO	YES				NO		NO		EW
7/12/2024	YES	86 WNW 7 MPH SUNNY	NO	YES				NO		NO		EW
	YES	91 WNW 7 MPH SUNNY	NO	YES				NO		NO		EW
7/13/2024	YES	91 WSW 7 MPH SUNNY	NO	YES				NO		NO		EW
	YES	93 SW 6 MPH SUNNY	NO	YES				NO		NO		EW
7/14/2024	YES	91 WSW 4 MPH SUNNY	NO	YES				NO		NO		EW
	YES	92 SSW 7 MPH SUNNY	NO	YES				NO		NO		EW
7/15/2024	YES	90 SSW 8 MPH SUNNY	NO	YES				NO		NO		EW
	YES	94 SW 10 MPH SUNNY	NO	YES				NO		NO		EW
7/16/2024	YES	88 SSW 11 MPH SUNNY	NO	YES				NO		NO		EW
	YES	91 SSW 11 MPH SUNNY	NO	YES				NO		NO		EW
7/17/2024	YES	76 N 5 MPH CLOUDY	NO	YES				NO		NO		EW
	YES	78 N 5 MPH RAIN	YES	NO				NO		NO		EW
7/18/2024	YES	78 N 10 MPH SUNNY	NO	YES				NO		NO		EW
	YES	86 N 10 MPH SUNNY	NO	YES				NO		NO		EW
7/19/2024	YES	73 NE 7 MPH CLOUDY	NO	YES				NO		NO		EW
	YES	84 NNE 9 MPH CLOUDY	NO	YES				NO		NO		EW
7/20/2024	YES	81 NW 7 MPH CLOUDY	NO	YES				NO		NO		EW
	YES	84 NNW 7 MPH CLOUDY	NO	YES				NO		NO		EW
7/21/2024	YES	73 N 3 MPH SUNNY	NO	YES				NO		NO		EW
	YES	84 N 6 MPH CLOUDY	NO	YES				NO		NO		EW
7/22/2024	YES	75 NE 4 MPH CLOUDY	NO	YES				NO		NO		EW
	YES	82 NE 8 MPH CLOUDY	NO	YES				NO		NO		EW
7/23/2024	YES	74 SE 4 MPH RAIN	YES	NO				NO		NO		BM
	YES	80 SSE 6 MPH CLOUDY	NO	YES				NO		NO		BM
7/24/2024	YES	77 S1 MPH PARTLY CLOUDY	NO	YES				NO		NO		BM
	YES	86 S3 MPH PARTLY CLOUDY	NO	YES				NO		NO		BM
7/25/2024	YES	81 ESE 5 MPH CLOUDY	NO	YES				NO		NO		EW
	YES	86 ESE 5 MPH CLOUDY	NO	YES				NO		NO		EW
7/26/2024	YES	74 SSE 5 MPH CLOUDY	NO	YES				NO		NO		EW
	YES	76 SSE 5 MPH RAIN	YES	NO				NO		NO		EW
7/27/2024	YES	75 S 5 MPH RAIN	YES	NO				NO		NO		EW
	YES	78 SSE 7 MPH CLOUDY	NO	YES				NO		NO		EW
7/28/2024	YES	77 S 4 MPH CLOUDY	NO	YES				NO		NO		EW
	YES	80 S 9 MPH CLOUDY	NO	YES				NO		NO		EW
7/29/2024	YES	88 SW 11 MPH CLOUDY	NO	YES				NO		NO		EW
	YES	91 SW 11 MPH CLOUDY	NO	YES				NO		NO		EW
7/30/2024	YES	89 WSW 12 MPH SUNNY	NO	YES				NO		NO		EW
	YES	93 WSW 11 MPH SUNNY	NO	YES				NO		NO		EW
7/31/2024	YES	78 S 7 MPH SUNNY	NO	YES				NO		NO		BM
	YES	96 SW 9 MPH SUNNY	NO	YES				NO		NO		BM

2024

Plum Point

Dust Control Log

Month: August

Date	Actively working? ¹		Weather ^{2, 7, 8}	Method(s) Used to Control Dust ³				*Is dust present? ⁴		*Is erosion present? ⁵		Preventative or Corrective Action Taken	Initials
	Yes/No	Temperature range, rainfall data, wind speeds,	Currently Percipitating (Y/N)	Water Truck	Alternative Cover	Other	Yes	No	Yes	No	Examples: Added more water, applied additional alternative cover material,		
8/1/2024	YES	78 SSW 8 MPH SUNNY	NO	YES				NO		NO		EW	
8/2/2024	YES	82 WSW 13 MPH SUNNY	NO	YES				NO		NO		EW	
8/2/2024	YES	88 NNW 9 MPH SUNNY	NO	YES				NO		NO		EW	
8/3/2024	YES	92 NNW 9 MPH SUNNY	NO	YES				NO		NO		EW	
8/3/2024	YES	87 NNE 5 MPH SUNNY	NO	YES				NO		NO		EW	
8/3/2024	YES	90 NNE 5 MPH SUNNY	NO	YES				NO		NO		EW	
8/4/2024	YES	74 WNW 1 MPH SUNNY	NO	YES				NO		NO		EW	
8/4/2024	YES	91 ENE 7 MPH SUNNY	NO	YES				NO		NO		EW	
8/5/2024	YES	92 N 3 MPH SUNNY	NO	YES				NO		NO		EW	
8/5/2024	YES	96 N 3 MPH SUNNY	NO	YES				NO		NO		EW	
8/6/2024	YES	95 WNW 9 MPH SUNNY	NO	YES				NO		NO		EW	
8/6/2024	YES	98 WNW 10 MPH SUNNY	NO	YES				NO		NO		EW	
8/7/2024	YES	74 NNW 9 MPH CLOUDY	NO	YES				NO		NO		EW	
8/7/2024	YES	80 N 10 MPH CLOUDY	NO	YES				NO		NO		EW	
8/8/2024	YES	82 NNE 8MPH SUNNY	NO	YES				NO		NO		EW	
8/8/2024	YES	87 NNE 8 MPH SUNNY	NO	YES				NO		NO		EW	
8/9/2024	YES	80 N 8 MPH SUNNY	NO	YES				NO		NO		EW	
8/9/2024	YES	87 N 8 MPH SUNNY	NO	YES				NO		NO		EW	
8/10/2024	YES	74 ENE 10 MPH CLOUDY	NO	YES				NO		NO		EW	
8/10/2024	YES	79 NNE 7 MPH CLOUDY	NO	YES				NO		NO		EW	
8/11/2024	YES	70 NE 6 MPH CLOUDY	NO	YES				NO		NO		EW	
8/11/2024	YES	82 SSW 7 MPH CLOUDY	NO	YES				NO		NO		EW	
8/12/2024	YES	74 E 6 MPH CLOUDY	NO	YES				NO		NO		EW	
8/12/2024	YES	82 SE 6 MPH CLOUDY	NO	YES				NO		NO		EW	
8/13/2024	YES	86 SE 6 MPH CLOUDY	NO	YES				NO		NO		EW	
8/13/2024	YES	91 S 6 MPH CLOUDY	NO	YES				NO		NO		EW	
8/14/2024	YES	76 ESE 4 MPH RAIN	YES	NO				NO		NO		EW	
8/14/2024	YES	80 ESE 5 MPH RAIN	YES	NO				NO		NO		EW	
8/15/2024	YES	88 SSW 12 MPH SUNNY	NO	YES				NO		NO		BM	
8/15/2024	YES	96 S 10 MPH SUNNY	NO	YES				NO		NO		BM	
8/16/2024	YES	87 WSW 9 MPH CLOUDY	NO	YES				NO		NO		BM	
8/16/2024	YES	93 WSW 9 MPH CLOUDY	NO	YES				NO		NO		BM	
8/17/2024	YES	84 WNW 9 MPH SUNNY	NO	YES				NO		NO		EW	
8/17/2024	YES	88 W 9 MPH SUNNY	NO	YES				NO		NO		EW	
8/18/2024	YES	87 NW9 MPH SUNNY	NO	YES				NO		NO		EW	
8/18/2024	YES	90 NW 9 MPH SUNNY	NO	YES				NO		NO		EW	
8/19/2024	YES	82 NNE 9 MPH SUNNY	NO	YES				NO		NO		EW	
8/19/2024	YES	86 NNE 9 MPH SUNNY	NO	YES				NO		NO		EW	
8/20/2024	YES	78 NE 12 MPH SUNNY	NO	YES				NO		NO		EW	
8/20/2024	YES	82 NE 12 MPH SUNNY	NO	YES				NO		NO		EW	
8/21/2024	YES	79 NNE 11 MPH SUNNY	NO	YES				NO		NO		EW	
8/21/2024	YES	81 NE 10 MPH SUNNY	NO	YES				NO		NO		EW	
8/22/2024	YES	78 NNE 7 MPH SUNNY	NO	YES				NO		NO		EW	
8/22/2024	YES	84 NE 10 MPH SUNNY	NO	YES				NO		NO		EW	
8/23/2024	NO	89 SE 9 MPH SUNNY	NO	NO				NO		NO		EW	
8/23/2024	NO	97 SSE 9 MPH SUNNY	NO	NO				NO		NO		EW	
8/24/2024	NO	88 SSE 6 MPH SUNNY	NO	NO				NO		NO		EW	
8/24/2024	NO	91 S 6 MPH SUNNY	NO	NO				NO		NO		EW	
8/25/2024	NO	88 S 6 MPH SUNNY	NO	NO				NO		NO		EW	
8/25/2024	NO	93 SSE 6 MPH SUNNY	NO	NO				NO		NO		EW	
8/26/2024	NO	90 SE 2 MPH SUNNY	NO	NO				NO		NO		EW	
8/26/2024	NO	97 S 2 MPH SUNNY	NO	NO				NO		NO		EW	
8/27/2024	NO	91 SW 7 MPH SUNNY	NO	NO				NO		NO		BM	
8/27/2024	NO	96 SSW 7 MPH SUNNY	NO	NO				NO		NO		BM	
8/28/2024	NO	96 SW 7 MPH SUNNY	NO	NO				NO		NO		BM	
8/28/2024	NO	98 SSW6 MPH SUNNY	NO	NO				NO		NO		BM	
8/29/2024	YES	81 ENE 3 MPH SUNNY	NO	YES				NO		NO		EW	
8/29/2024	YES	97 SSE 5 MPH SUNNY	NO	YES				NO		NO		EW	
8/30/2024	YES	82 SW 5 MPH CLOUDY	NO	YES				NO		NO		EW	
8/30/2024	YES	86 SW 5 MPH CLOUDY	NO	YES				NO		NO		EW	
31-Aug	YES	74 SE 1 MPH CLOUDY	NO	YES				NO		NO		EW	
31-Aug	YES	83 SSE 5 MPH CLOUDY	NO	YES				NO		NO		EW	

Month: SEPTEMBER

2024

Plum Point

Dust Control Log

Date	Actively working? ¹		Weather ^{2, 7, 8} Temperature range, rainfall data, wind speeds,	Method(s) Used to Control Dust ³				*Is dust present? ⁴		*Is erosion present? ⁵		Preventative or Corrective Action Taken Examples: Added more water, applied additional alternative cover material,	Initials
	Yes/No			Currently Percipitating (Y/N)	Water Truck	Alternative Cover	Other	Yes	No	Yes	No		
9/1/2024	10:00 AM	YES	74 NE 6 MPH RAIN	YES	NO				NO		NO		EW
	2:00 PM	YES	79 NE 6 MPH RAIN	YES	NO				NO		NO		EW
9/2/2024				HOLIDAY									
				HOLIDAY									
9/3/2024	10:00	YES	72 NNE 5 MPH CLOUDY	NO	YES				NO		NO		EW
	2:00 PM	YES	84 NNE 9 MPH CLOUDY	NO	YES				NO		NO		EW
9/4/2024	1:00 AM	YES	77 SE 7 MPH CLOUDY	NO	YES				NO		NO		EW
	11:00	YES	77 ESE 3 MPH RAIN	YES	NO				NO		NO		EW
9/5/2024	1:00 AM	YES	81 SSE 5 MPH CLOUDY	NO	YES				NO		NO		EW
	2:30 PM	YES	88 ESE 4 MPH SUNNY	NO	NO				NO		NO		EW
9/6/2024	11:00 AM	YES	82 NE 1 MPH SUNNY	NO	YES				NO		NO		EW
	2:00 PM	YES	86 E 10 MPH RAIN	YES	NO				NO		NO		EW
9/7/2024	10:00 AM	YES	75 NNE 17 MPH SUNNY	NO	YES				NO		NO		EW
	2:00 PM	YES	77 NNE 17 MPH SUNNY	NO	YES				NO		NO		EW
9/8/2024	7:30 AM	YES	55 NNE 7 MPH SUNNY	NO	YES				NO		NO		EW
	1:30 PM	YES	76 N 10 MPH SUNNY	NO	YES				NO		NO		EW
9/9/2024	7:30 AM	YES	54 NNE 6 MPH SUNNY	NO	YES				NO		NO		EW
	2:42 PM	YES	81 NE 8 MPH SUNNY	NO	YES				NO		NO		EW
9/10/2024	10:AM	YES	80 ESE 1 MPH SUNNY	NO	YES				NO		NO		EW
	2PM	YES	85 ESE 1 MPH SUNNY	NO	YES				NO		NO		EW
9/11/2024	10:AM	YES	84 SE 9 MPH SUNNY	NO	YES				NO		NO		EW
	1:30PM	YES	87 SE 9 MPH SUNNY	NO	YES				NO		NO		EW
9/12/2024	11:AM	YES	66 NE 9 MPH RAIN	YES	NO				NO		NO		EW
	2PM	YES	69 NE 20 MPH RAIN	YES	NO				NO		NO		EW
9/13/2024	10PM	YES	67 SSE 6 MPH RAIN	YES	NO				NO		NO		EW
	2PM	NO	69 SSE 6 MPH RAIN	YES	NO				NO		NO		EW
9/14/2024	7:16 AM	YES	70 ENE 4 MPH RAIN	YES	NO				NO		NO		EW
	1:30 PM	YES	73 E 11 MPH RAIN	YES	NO				NO		NO		EW
9/15/2024	11:00	YES	71 ENE 7 MPH RAIN	YES	NO				NO		NO		EW
	2:30	YES	73 E 6 MPH RAIN	YES	NO				NO		NO		EW
9/16/2024	11:00	YES	76 E 13 MPH CLOUDY	NO	YES				NO		NO		EW
	11:30	YES	78 E 13 MPH CLOUDY	NO	YES				NO		NO		EW
9/17/2024	1:00 AM	YES	85 NE 7 MPH CLOUDY	NO	YES				NO		NO		BM
	2:00 PM	YES	88 NE 7 MPH CLOUDY	NO	YES				NO		NO		BM
9/18/2024	1:00 AM	YES	77 NE 1 MPH SUNNY	NO	YES				NO		NO		EW
	2:00 PM	YES	84 NNE 4 MPH SUNNY	NO	YES				NO		NO		EW
9/19/2024	10:00 AM	YES	80 S 5 MPH SUNNY	NO	YES				NO		NO		BM
	2:00 PM	YES	87 SW 5 MPH SUNNY	NO	YES				NO		NO		BM
9/20/2024	1:00 AM	YES	79 SSW 6 MPH SUNNY	NO	YES				NO		NO		EW
	2:30 PM	YES	88 SSW 4 MPH SUNNY	NO	YES				NO		NO		EW
9/21/2024	7:30 AM	YES	74 SSE 4 MPH CLOUDY	NO	YES				NO		NO		EW
	2:00 PM	YES	87 WSW 8 MPH CLOUDY	NO	YES				NO		NO		EW
9/22/2024	7:30 AM	YES	72 SE 3 MPH SUNNY	NO	YES				NO		NO		EW
	2:30 PM	YES	90 WSW 8 MPH SUNNY	NO	YES				NO		NO		EW
9/23/2024	11:30 AM	YES	85 W 9 MPH CLOUDY	NO	YES				NO		NO		EW
	1:30 PM	YES	87 WSW 8 MPH CLOUDY	NO	YES				NO		NO		EW
9/24/2024	11:00 AM	YES	77 W 5 MPH CLOUDY	NO	YES				NO		NO		EW
	1:00 PM	YES	78 W 5 MPH CLOUDY	NO	YES				NO		NO		EW
9/25/2024	11:00 AM	YES	75 NNE 6 MPH SUNNY	NO	YES				NO		NO		EW
	1:00 PM	YES	78 NNE 6 MPH SUNNY	NO	YES				NO		NO		EW
9/26/2024	11:30 AM	YES	80 NNE 12 MPH CLOUDY	NO	YES				NO		NO		EW
	2:30 PM	YES	83 NNE 12 MPH CLOUDY	NO	YES				NO		NO		EW
9/27/2024	11:30 AM	NO	66 NW 13 MPH RAIN	YES	NO				NO		NO		EW
	2:30 PM	NO	65 NW 15 MPH RAIN	YES	NO				NO		NO		EW
9/28/2024	11:30 AM	YES	72 SW 13 MPH CLOUDY	NO	YES				NO		NO		EW
	1:00 PM	YES	72 NNW 6 MPH CLOUDY	NO	YES				NO		NO		EW
9/29/2024	1:00 AM	YES	68 NNW 7 MPH CLOUDY	NO	YES				NO		NO		EW
	1:00 PM	YES	74 N 9 MPH CLOUDY	NO	YES				NO		NO		EW
9/30/2024	11:00 AM	YES	76 NNW 3 MPH CLOUDY	NO	YES				NO		NO		EW
	2:00 PM	YES	78 N 4 MPH CLOUDY	NO	YES				NO		NO		EW

2024

Plum Point

Dust Control Log

Month: OCTOBER

Actively working? ¹		Weather ^{2, 7, 8}		Method(s) Used to Control Dust ³				*Is dust present? ⁴		*Is erosion present? ⁵		Preventative or Corrective Action Taken	
Date	Yes/No	Temperature range, rainfall data, wind speeds,	Currently Percipitating (Y/N)	Water Truck	Alternative Cover	Other	Yes	No	Yes	No	Examples: Added more water, applied additional alternative cover material,		Initials
10/1/2024	11:00 AM	YES	78 NNW 8 MPH CLOUDY	NO	YES			NO		NO			EW
	2:00 PM	YES	82 N 10 MPH CLOUDY	NO	YES			NO		NO			EW
10/2/2024	11:00 AM	YES	75 N 4 MPH SUNNY	NO	YES			NO		NO			EW
	2:00 PM	YES	77 N 4 MPH SUNNY	NO	YES			NO		NO			EW
10/3/2024	11:00 AM	YES	80 SW3 MPH SUNNY	NO	YES			NO		NO			EW
	2PM	YES	82 SE 3 MPH SUNNY	NO	YES			NO		NO			EW
10/4/2024	11:00 AM	YES	85 NE 5 MPH SUNNY	NO	YES			NO		NO			EW
	2PM	YES	87 ENE 5 MPH SUNNY	NO	YES			NO		NO			EW
10/5/2024	11:00 AM	YES	88 SE 2 MPH SUNNY	NO	YES			NO		NO			EW
	1:00 PM	YES	90 SE 2 MPH SUNNY	NO	YES			NO		NO			EW
10/6/2024	11:00 AM	YES	86 NW 4 MPH SUNNY	NO	YES			NO		NO			EW
	1:00 PM	YES	90 NW 5 MPH SUNNY	NO	YES			NO		NO			EW
10/7/2024	11:00 AM	YES	73 N 13 MPH SUNNY	NO	YES			NO		NO			EW
	2PM	YES	76 N 13 MPH SUNNY	NO	YES			NO		NO			EW
10/8/2024	11:00 AM	YES	68 NE 7 MPH SUNNY	NO	YES			NO		NO			EW
	1:00 PM	YES	73 NE 9 MPH SUNNY	NO	YES			NO		NO			EW
10/9/2024	11:00 AM	YES	71 NE 7 MPH SUNNY	NO	YES			NO		NO			EW
	1:00 PM	YES	77 NE 8 MPH SUNNY	NO	YES			NO		NO			EW
10/10/2024	11:00 AM	YES	53 S4 MPH SUNNY	NO	YES			NO		NO			EW
	1:00 PM	YES	81 S 4 MPH SUNNY	NO	YES			NO		NO			EW
10/11/2024	11:00 AM	YES	56 S 4 MPH SUNNY	NO	YES			NO		NO			EW
	1:00 PM	YES	84 S 4 MPH SUNNY	NO	YES			NO		NO			EW
10/12/2024	10:00 AM	YES	68 SSW 7 MPH CLOUDY	NO	YES			NO		NO			EW
	1:00 PM	YES	83 SW 9 MPH SUNNY	NO	YES			NO		NO			EW
10/13/2024	11:00 AM	YES	67 SW 8 MPH SUNNY	NO	YES			NO		NO			BM
	1:00 PM	YES	85 W 10 MPH SUNNY	NO	YES			NO		NO			BM
10/14/2024	10:00 AM	YES	58 N 11 MPH SUNNY	NO	YES			NO		NO			EW
	2:00 PM	YES	65 N 9 MPH SUNNY	NO	YES			NO		NO			EW
10/15/2024	1:00	YES	58 N 12 MPH CLOUDY	NO	YES			NO		NO			EW
	2PM	YES	63 N 18 MPH CLOUDY	NO	YES			NO		NO			EW
10/16/2024	10:00 AM	YES	41 NNE 7 MPH SUNNY	NO	YES			NO		NO			EW
	1:PM	YES	57 NNE 7 MPH SUNNY	NO	YES			NO		NO			EW
10/17/2024	10AM	YES	51 E 3 MPH SUNNY	NO	YES			NO		NO			EW
	2PM	YES	67 ESE 5 MPH SUNNY	NO	YES			NO		NO			EW
10/18/2024	10:00 AM	NO	52 ESE 3 MPH SUNNY	NO	NO			NO		NO			EW
	1:00 PM	NO	69 SE 5 MPH SUNNY	NO	NO			NO		NO			EW
10/19/2024	10:00 AM	YES	68 ESE 4 MPH SUNNY	NO	YES			NO		NO			EW
	2:00 PM	YES	75 ESE 4 MPH SUNNY	NO	YES			NO		NO			EW
10/20/2024	10AM	YES	45 ENE 1 MPH SUNNY	NO	YES			NO		NO			EW
	2PM	YES	75 NNE 2 MPH SUNNY	NO	YES			NO		NO			EW
10/21/2024	11:00 AM	YES	68 SE 3 MPH SUNNY	NO	YES			NO		NO			EW
	2PM	YES	77 SSE 4 MPH SUNNY	NO	YES			NO		NO			EW
10/22/2024	10AM	YES	57 S 5 MPH SUNNY	NO	YES			NO		NO			EW
	2PM	YES	81 SSW 13 MPH SUNNY	NO	YES			NO		NO			EW
10/23/2024	11AM	YES	76 WSW 8 MPH SUNNY	NO	YES			NO		NO			EW
	2PM	YES	85 W 6 MPH SUNNY	NO	YES			NO		NO			EW
10/24/2024	10AM	YES	61SE 5 MPH SUNNY	NO	YES			NO		NO			EW
	2PM	YES	83 SSE 5 MPH SUNNY	NO	YES			NO		NO			EW
10/25/2024	10:00 AM	YES	79 SSW 9 MPH SUNNY	NO	YES			NO		NO			EW
	2PM	YES	87 SSW 11 MPH SUNNY	NO	YES			NO		NO			EW
10/26/2024	10:00 AM	YES	61 N 9 MPH CLOUDY	NO	YES			NO		NO			EW
	2PM	YES	70 NNE 10 MPH CLOUDY	NO	YES			NO		NO			EW
10/27/2024	11AM	YES	72 NE 7 MPH CLOUDY	NO	YES			NO		NO			EW
	2PM	YES	74 NE 7 MPH CLOUDY	NO	YES			NO		NO			EW
10/28/2024	11AM	YES	82 S 13 MPH SUNNY	NO	YES			NO		NO			EW
	2PM	YES	85 S 13 MPH SUNNY	NO	YES			NO		NO			EW
10/29/2024	10AM	YES	64 S 7 MPH SUNNY	NO	YES			NO		NO			EW
	1:00 PM	YES	81 SSW 15 MPH SUNNY	NO	YES			NO		NO			EW
10/30/2024	2PM	YES	68 SW 8 MPH SUNNY	NO	YES			NO		NO			EW
	2:00 PM	YES	83 SSW 12 MPH SUNNY	NO	YES			NO		NO			EW
31-Oct	10AM	YES	60 ENE 12 MPH CLOUDY	NO	YES			NO		NO			EW
	2PM	YES	71 NE 14 MPH RAIN	YES	NO			NO		NO			EW

2024

Plum Point

Dust Control Log

Month: NOVEMBER

Date	Actively working? ¹		Weather ^{2, 7, 8}	Method(s) Used to Control Dust ³				*Is dust present? ⁴		*Is erosion present? ⁵		Preventative or Corrective Action Taken	Initials
	Yes/No	Temperature range, rainfall data, wind speeds,	Currently Percipitating (Y/N)	Water Truck	Alternative Cover	Other	Yes	No	Yes	No	Examples: Added more water, applied additional alternative cover material,		
11/1/2024	11AM	YES	61 NE 10 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	67 NE 8 MPH CLOUDY	NO	YES			NO		NO		EW	
11/2/2024	1130 AM	YES	68 E 8 MPH CLOUDY	NO	YES			NO		NO		EW	
	200PM	YES	71 E 8 MPH CLOUDY	NO	YES			NO		NO		EW	
11/3/2024	10:00	YES	72 SSE 12 MPH CLOUDY	NO	YES			NO		NO		EW	
	230 PM	YES	79 SE 3 MPH CLOUDY	NO	YES			NO		NO		EW	
11/4/2024	11:00	YES	73 SSE 17 CLOUDY	NO	YES			NO		NO		EW	
	230 PM	YES	78 SSE 17 CLOUDY	NO	YES			NO		NO		EW	
11/5/2024	1100 AM	YES	66 NE 6 MPH CLOUDY	NO	YES			NO		NO		EW	
	2:00 PM	YES	67 NE 8 MPH CLOUDY	NO	YES			NO		NO		EW	
11/6/2024	10:00 AM	YES	64 NNE 3 MPH CLOUDY	NO	YES			NO		NO		EW	
	2:00 PM	YES	69 NNE 4 MPH CLOUDY	NO	YES			NO		NO		EW	
11/7/2024	11:30 PM	YES	59 NNE 12 CLOUDY	NO	YES			NO		NO		EW	
	1:00 PM	YES	61 NNE 12 CLOUDY	NO	YES			NO		NO		EW	
11/8/2024	1130 AM	YES	60 NE 11 MPH CLOUDY	NO	YES			NO		NO		EW	
	1:00 PM	YES	61 NE 11 MPH CLOUDY	NO	YES			NO		NO		EW	
11/9/2024	9:30 AM	YES	60 E 4 MPH RAIN	YES	NO			NO		NO		EW	
	1:00 PM	YES	65 E 4 MPH RAIN	YES	NO			NO		NO		EW	
11/10/2024	9:00 AM	YES	68 SW 7 MPH CLOUDY	NO	YES			NO		NO		EW	
	1:00 PM	YES	72 WSW 10 CLOUDY	NO	YES			NO		NO		EW	
11/11/2024	9:00 AM	YES	55 N 4 MPH SUNNY	NO	YES			NO		NO		EW	
	2:00 PM	YES	68 N 7 MPH SUNNY	NO	YES			NO		NO		EW	
11/12/2024	7:30 AM	YES	53 NE 4 MPH SUNNY	NO	YES			NO		NO		EW	
	1:00 PM	YES	68 NE 9 MPH SUNNY	NO	YES			NO		NO		EW	
11/13/2024	10:00 AM	YES	55 S 5 MPH RAIN	YES	NO			NO		NO		EW	
	2:00 PM	YES	61 S 5 MPH RAIN	YES	NO			NO		NO		EW	
11/14/2024	10:00 AM	YES	55 NW 7 MPH SUNNY	NO	YES			NO		NO		EW	
	1:00 PM	YES	60 NW 7 MPH SUNNY	NO	YES			NO		NO		EW	
11/15/2024	1:00	YES	41 WSW 2 CLOUDY	NO	YES			NO		NO		EW	
	3PM	YES	60 NE 7 MPH SUNNY	NO	YES			NO		NO		EW	
11/16/2024	10:00	YES	60 S 5 MPH SUNNY	NO	YES			NO		NO		EW	
	1:30 PM	YES	63 S 5 MPH SUNNY	NO	YES			NO		NO		EW	
11/17/2024	11:30 AM	YES	70 S 9 MPH CLOUDY	NO	YES			NO		NO		EW	
	2:30 PM	YES	72 S 8 MPH CLOUDY	NO	YES			NO		NO		EW	
11/18/2024	10:00 AM	YES	70 SSE 15 MPH CLOUDY	NO	YES			NO		NO		EW	
	1:00 PM	YES	75 SSE 17 MPH CLOUDY	NO	YES			NO		NO		EW	
11/19/2024	11:00 AM	YES	69 WNW 3 MPH SUNNY	NO	YES			NO		NO		EW	
	2:00 PM	YES	71 WNW 3 MPH SUNNY	NO	YES			NO		NO		EW	
11/20/2024	9:00 AM	YES	50 NNW 14 MPH SUNNY	NO	YES			NO		NO		EW	
	3PM	YES	59 NNW 15 MPH SUNNY	NO	YES			NO		NO		EW	
11/21/2024	11:00 AM	YES	52 NW 19 MPH SUNNY	NO	YES			NO		NO		EW	
	1:00 PM	YES	53 NW 20 MPH SUNNY	NO	YES			NO		NO		EW	
11/22/2024	11AM	YES	48 NNW 7 MPH SUNNY	NO	YES			NO		NO		EW	
	3PM	YES	52 NW 7 MPH SUNNY	NO	YES			NO		NO		EW	
11/23/2024	11:00 AM	YES	55 WSW 4 MPH SUNNY	NO	YES			NO		NO		EW	
	3PM	YES	57 WSW 4 MPH SUNNY	NO	YES			NO		NO		EW	
11/24/2024	1130AM	YES	64 S 13 MPH SUNNY	NO	YES			NO		NO		EW	
	2:00 PM	YES	67 S 13 MPH SUNNY	NO	YES			NO		NO		EW	
11/25/2024	7:30 AM	YES	63 SSW 13 MPH CLOUDY	NO	YES			NO		NO		EW	
	1:00 PM	YES	68 SW 68 MPH CLOUDY	NO	YES			NO		NO		EW	
11/26/2024	1030AM	YES	46 ENE 2 MPH SUNNY	NO	YES			NO		NO		EW	
	2:00 PM	YES	52 ENE2 MPH SUNNY	NO	YES			NO		NO		EW	
11/27/2024	9AM	YES	46 S 7 MPH RAIN	YES	NO			NO		NO		EW	
	3PM	YES	54 S7 MPH RAIN	YES	NO			NO		NO		EW	
11/28/2024													
11/29/2024	10:00 AM	YES	39 NW 8 MPH SUNNY	NO	NO			NO		NO		EW	
	2PM	YES	44 NW 9 MPH SUNNY	NO	NO			NO		NO		EW	
11/30/2024	10:00 AM	YES	44 SSW 11 MPH CLOUDY	NO	NO			NO		NO		EW	
	2:00 PM	YES	51 SSW 11 MPH CLOUDY	NO	NO			NO		NO		EW	

ATTACHMENT 2

Landfill Inspection Forms

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 12-5-2023	Time: 1:00 PM	Weather: clear/ windy	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		New grass is growing slowly
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		12-5-2023
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 12-12-2023	Time: 2:00 PM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		5709915
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		12-12-2023
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 12-19-2023	Time: 9:00 AM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		New grass growing slow cool wet weather effect
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		5709915
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum Print Name of Inspector Completing Form	Bryan Mangrum Signature		12-19-2023 Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 12-26-2023	Time: 8:30 AM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		New grass is stooling and spreading
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		5709915
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		12-26-2023
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT ENERGY STATION CLASS 3N LANDFILL
Operations Inspection Form**

Inspection Conducted By: John Mayron

Date: 12-26-23

DESCRIPTION	INSPECTION INTERVAL	PASS	FAIL*
Surface Water System			
Drainage Ditches & Culverts	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Berms	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leachate Collection System			
Pumps	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Totalizers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Transmission/Recirculation systems	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage facilities	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Landfill Final Cover System			
Erosion	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ponded Water	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Settlement	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vegetation	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Facility Roads			
Safety	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Routing	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Condition	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mud	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Passable Width	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency Response Equipment			
Fire Extinguisher	Check Quarterly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Test Annually		
Communication System	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
List of Emergency Phone Numbers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
First Aid Kits	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Waste Cell and Plant Grid Markers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Survey Markers	Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring Wells	Semi-Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>

* Explain failure on back of form.

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 1-3-24	Time: 8:30 am	Weather: cloudy	
Inspection Representatives			
Charah: Eddie Wamble			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		5709915.0
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Eddie Wamble Print Name of Inspector Completing Form	Eddie Wamble Signature		1-3-24 Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 1-9-2024	Time: 1:45 PM	Weather: cloudy/ windy	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		New grass is growing on south slope
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		5870425.3
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		1-9-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 1-16-2024	Time: 10:45 AM	Weather: sunny/ cold	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		6458589
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		1-16-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 1-23-2024	Time: 10:45 AM	Weather: cloudy/rain	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		663472
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		1-23-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 1-30-2024	Time: 1: 45 PM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		New growth good considering extreme cold temps
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		6639328
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		Freeze and thaw damaged graded and repaired 1-29-24
6b. Condition of active disposal area access road	x		Freezing temps and weeklong rain damaged repairs being made
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		1-30-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT ENERGY STATION CLASS 3N LANDFILL
Operations Inspection Form**

Inspection Conducted By: Bryan Morgan

Date: 1-25-24

DESCRIPTION	INSPECTION INTERVAL	PASS	FAIL*
Surface Water System			
Drainage Ditches & Culverts	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Berms	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leachate Collection System			
Pumps	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Totalizers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Transmission/Recirculation systems	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage facilities	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Landfill Final Cover System			
Erosion	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ponded Water	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Settlement	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vegetation	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Facility Roads			
Safety	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Routing	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Condition	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mud	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Passable Width	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency Response Equipment			
Fire Extinguisher	Check Quarterly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Test Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Communication System	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
List of Emergency Phone Numbers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
First Aid Kits	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Waste Cell and Plant Grid Markers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Survey Markers	Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring Wells	Semi-Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>

* Explain failure on back of form.

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 2-6-2024	Time: 9: 45 AM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		6639328
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		2-6-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 2-13-2024	Time: 2: 45 PM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		Fixing pot holes with new rock
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		2-13-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 2-20-2024	Time: 2: 00 PM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		7975193.8
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		2-20-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 2-27-2024	Time: 9: 00 AM	Weather: overcast / high winds	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		7975193.8
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		2-27-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT ENERGY STATION CLASS 3N LANDFILL
Operations Inspection Form**

Inspection Conducted By: Mr. Mann

Date: 2-29-24

DESCRIPTION	INSPECTION INTERVAL	PASS	FAIL*
Surface Water System			
Drainage Ditches & Culverts	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Berms	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leachate Collection System			
Pumps	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Totalizers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Transmission/Recirculation systems	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage facilities	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Landfill Final Cover System			
Erosion	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ponded Water	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Settlement	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vegetation	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Facility Roads			
Safety	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Routing	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Condition	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mud	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Passable Width	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency Response Equipment			
Fire Extinguisher	Check Quarterly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Test Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Communication System	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
List of Emergency Phone Numbers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
First Aid Kits	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Waste Cell and Plant Grid Markers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Survey Markers	Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring Wells	Semi-Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>

* Explain failure on back of form.

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 3-5-2024	Time: 2: 20 PM	Weather: overcast	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		7975193.8
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		3-5-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 3-12-2024	Time: 8: 30 PM	Weather: Clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		8264645.4
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		3-12-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 3-19-2024	Time: 8: 30 AM	Weather: Clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		9124105.1
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		3-19-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 3-26-2024	Time: 10: 30 AM	Weather: overcast/clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		9603434.5
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		3-26-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT ENERGY STATION CLASS 3N LANDFILL
Operations Inspection Form**

Inspection Conducted By: Brian M. M...

Date: 3-22-24

DESCRIPTION	INSPECTION INTERVAL	PASS	FAIL*
Surface Water System			
Drainage Ditches & Culverts	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Berns	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leachate Collection System			
Pumps	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Totalizers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Transmission/Recirculation systems	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage facilities	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Landfill Final Cover System			
Erosion	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ponded Water	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Settlement	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vegetation	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Facility Roads			
Safety	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Routing	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Condition	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mud	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Passable Width	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency Response Equipment			
Fire Extinguisher	Check Quarterly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Test Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Communication System	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
List of Emergency Phone Numbers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
First Aid Kits	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Waste Cell and Plant Grid Markers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Survey Markers	Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring Wells	Semi-Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>

* Explain failure on back of form.

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 4-2-2024	Time: 9: 30 AM	Weather: overcast/ rain	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		9603434.5
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		4-2-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 4-9-2024	Time: 11: 30 AM	Weather: overcast/ rain	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		9603434.5
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		4-9-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 4-16-2024	Time: 11: 30 AM	Weather: partly cloudy	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		9603434.5
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		4-16-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 4-23-2024	Time: 10: 00 AM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		9725150.6
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		4-23-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 4-30-2024	Time: 10: 30 AM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		9725150.6
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		4-30-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT ENERGY STATION CLASS 3N LANDFILL
Operations Inspection Form**

Inspection Conducted By: BRYAN MANSRU

Date: 4-25-24

DESCRIPTION	INSPECTION INTERVAL	PASS	FAIL*
Surface Water System			
Drainage Ditches & Culverts	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Berms	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leachate Collection System			
Pumps	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Totalizers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Transmission/Recirculation systems	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage facilities	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Landfill Final Cover System			
Erosion	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ponded Water	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Settlement	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vegetation	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Facility Roads			
Safety	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Routing	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Condition	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mud	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Passable Width	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency Response Equipment			
Fire Extinguisher	Check Quarterly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Test Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Communication System	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
List of Emergency Phone Numbers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
First Aid Kits	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Waste Cell and Plant Grid Markers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Survey Markers	Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring Wells	Semi-Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>

* Explain failure on back of form.

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 5-7-2024	Time: 12: 30 PM	Weather: overcast	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		9725150.6
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		5-7-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 5-14-2024	Time: 10: 30 AM	Weather: cloudy	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		9725150.6
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		Fixed a few pot holes headed up landfill rd
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		5-14-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 5-21-24	Time: 10:00 AM	Weather: sunny	
Inspection Representatives			
Charah: Eddie Wamble			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		9725150.6
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Eddie Wamble Print Name of Inspector Completing Form	Eddie Wamble Signature		5-21-24 Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 5-28-2024	Time: 9: 30 AM	Weather: clear/overcast	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		9725150.6
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		5-28-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT ENERGY STATION CLASS 3N LANDFILL
Operations Inspection Form**

Inspection Conducted By: *D. Marx*

Date: 5-23-24

DESCRIPTION	INSPECTION INTERVAL	PASS	FAIL*
Surface Water System			
Drainage Ditches & Culverts	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Berms	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leachate Collection System			
Pumps	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Totalizers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Transmission/Recirculation systems	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage facilities	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Landfill Final Cover System			
Erosion	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ponded Water	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Settlement	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vegetation	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Facility Roads			
Safety	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Routing	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Condition	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mud	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Passable Width	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency Response Equipment			
Fire Extinguisher	Check Quarterly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Test Annually		
Communication System	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
List of Emergency Phone Numbers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
First Aid Kits	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Waste Cell and Plant Grid Markers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Survey Markers	Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring Wells	Semi-Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>

* Explain failure on back of form.

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 6-4-2024	Time: 12: 30 PM	Weather: overcast	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		9725150.6
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		6-04-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 6-11-2024	Time: 2: 00 PM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		9725150.6
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		Worked on entrance 6-10/ 6-11
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum Print Name of Inspector Completing Form	Bryan Mangrum Signature		6-11-2024 Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 6-18-2024	Time: 8: 30 AM	Weather: cloudy	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		Cell 3 high level light not illuminating
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		9725150.6
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		Repaired landfill entrance road due to rain
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		6-18-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 6-25-2024	Time: 10: 00 AM	Weather: sun/overcast	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		9725150.6
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		6-25-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT ENERGY STATION CLASS 3N LANDFILL
Operations Inspection Form**

Inspection Conducted By: Brian Miller

Date: 6-25-24

DESCRIPTION	INSPECTION INTERVAL	PASS	FAIL*
Surface Water System			
Drainage Ditches & Culverts	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Berms	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leachate Collection System			
Pumps	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Totalizers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Transmission/Recirculation systems	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage facilities	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Landfill Final Cover System			
Erosion	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ponded Water	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Settlement	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vegetation	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Facility Roads			
Safety	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Routing	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Condition	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mud	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Passable Width	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency Response Equipment			
Fire Extinguisher	Check Quarterly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Test Annually		
Communication System	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
List of Emergency Phone Numbers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
First Aid Kits	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Waste Cell and Plant Grid Markers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Survey Markers	Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring Wells	Semi-Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>

* Explain failure on back of form.

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 7-2-2024	Time: 1: 00 PM	Weather: sunny	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		9725150.6
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		7-2-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 7-9-2024	Time: 1: 00 PM	Weather: clouds rain	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		High level light on cell 3 not illuminating in test
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		9725150.6
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		7-9-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 7-16-2024	Time: 10: 00 AM	Weather: clear/ overcast	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		High level light on cell 3 not illuminating in test
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		9725161.4 just started pumping to plant
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum Print Name of Inspector Completing Form	Bryan Mangrum Signature		7-16-2024 Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 7-23-2024	Time: 12: 30 PM	Weather: overcast / rain	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		104330083.3
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		7-23-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 7-30-2024	Time: 1: 00 PM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		10769170.0
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		7-30-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT ENERGY STATION CLASS 3N LANDFILL
Operations Inspection Form**

Inspection Conducted By: *S. M...*

Date: 7-30-24

DESCRIPTION	INSPECTION INTERVAL	PASS	FAIL*
Surface Water System			
Drainage Ditches & Culverts	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Berms	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leachate Collection System			
Pumps	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Totalizers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Transmission/Recirculation systems	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage facilities	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Landfill Final Cover System			
Erosion	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ponded Water	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Settlement	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vegetation	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Facility Roads			
Safety	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Routing	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Condition	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mud	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Passable Width	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency Response Equipment			
Fire Extinguisher	Check Quarterly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Test Annually		
Communication System	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
List of Emergency Phone Numbers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
First Aid Kits	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Waste Cell and Plant Grid Markers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Survey Markers	Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring Wells	Semi-Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>

* Explain failure on back of form.

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 8-6-2024	Time: 9: 00 AM	Weather: clear / Hot/Dry	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation		x	Mowing Slopes
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		10769170.0
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		8-6-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 8-13-2024	Time: 11: 00 AM	Weather: overcast	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation		x	Mowing Slopes
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		10769170.0
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		Mowed ditches on north side of landfill
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		8-13-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 8-20-2024	Time: 11: 00 AM	Weather: clear/sunny	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation		x	Started mowing slope on upper landfill entrance
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		10769170.0
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		8-20-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 8-27-2024	Time: 1: 00 PM	Weather: clear/sunny	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation		x	Mowing lower east slope and around southern side
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		10769170.0
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		8-27-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT ENERGY STATION CLASS 3N LANDFILL
Operations Inspection Form**

Inspection Conducted By: Ben Moxey

Date: 8-28-24

DESCRIPTION	INSPECTION INTERVAL	PASS	FAIL*
Surface Water System			
Drainage Ditches & Culverts	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Berms	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leachate Collection System			
Pumps	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Totalizers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Transmission/Recirculation systems	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage facilities	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Landfill Final Cover System			
Erosion	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ponded Water	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Settlement	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vegetation	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Facility Roads			
Safety	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Routing	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Condition	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mud	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Passable Width	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency Response Equipment			
Fire Extinguisher	Check Quarterly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Test Annually		
Communication System	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
List of Emergency Phone Numbers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
First Aid Kits	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Waste Cell and Plant Grid Markers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Survey Markers	Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring Wells	Semi-Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>

* Explain failure on back of form.

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 9-3-2024	Time: 10: 00 AM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		10769170.0
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		9-3-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 9-10-2024	Time: 9: 30 AM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		10769170.0
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		9-10-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 9-17-2024	Time: 12: 30 PM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		10769170.0
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum Print Name of Inspector Completing Form	Bryan Mangrum Signature		9-17-2024 Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 9-24-2024	Time: 3: 30 PM	Weather: overcast / rain	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		No power to display
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		Graded and rolled 9-23-24
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		9-24-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT ENERGY STATION CLASS 3N LANDFILL
Operations Inspection Form**

Inspection Conducted By: Eddie Wamble

Date: 7-28-24

DESCRIPTION	INSPECTION INTERVAL	PASS	FAIL*
Surface Water System			
Drainage Ditches & Culverts	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Berms	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leachate Collection System			
Pumps	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Totalizers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Transmission/Recirculation systems	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage facilities	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Landfill Final Cover System			
Erosion	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ponded Water	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Settlement	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vegetation	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Facility Roads			
Safety	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Routing	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Condition	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mud	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Passable Width	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency Response Equipment			
Fire Extinguisher	Check Quarterly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Test Annually		
Communication System	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
List of Emergency Phone Numbers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
First Aid Kits	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Waste Cell and Plant Grid Markers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Survey Markers	Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring Wells	Semi-Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>

* Explain failure on back of form.

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 10-1-24	Time: 1:30 pm	Weather: cloudy	
Inspection Representatives			
Charah: Eddie Wamble			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		N/A not operating
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Eddie Wamble Print Name of Inspector Completing Form	Eddie Wamble Signature		10-1-24 Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 10-8-2024	Time: 9:30 AM	Weather: sunny/clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		No power to display
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		10-8-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 10-15-24	Time: 1:30 pm	Weather: cloudy	
Inspection Representatives			
Charah: Eddie Wamble			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		N/A not operating
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Eddie Wamble Print Name of Inspector Completing Form	Eddie Wamble Signature	10-15-24 Date	

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 10-22-2024	Time: 9:30 AM	Weather: sunny/clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		10-22-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 10-29-2024	Time: 10:30 AM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		Pond level is approaching discharge pipes
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		10-29-2024
Print Name of Inspector Completing Form	Signature		Date

PLUM POINT ENERGY STATION CLASS 3N LANDFILL Operations Inspection Form

Inspection Conducted By: *Brian Magnuson*

Date: 10-31-24

DESCRIPTION	INSPECTION INTERVAL	PASS	FAIL*
Surface Water System			
Drainage Ditches & Culverts	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Berms	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leachate Collection System			
Pumps	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Totalizers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Transmission/Recirculation systems	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage facilities	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Landfill Final Cover System			
Erosion	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ponded Water	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Settlement	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vegetation	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Facility Roads			
Safety	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Routing	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Condition	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mud	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Passable Width	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency Response Equipment			
Fire Extinguisher	Check Quarterly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Test Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Communication System	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
List of Emergency Phone Numbers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
First Aid Kits	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Waste Cell and Plant Grid Markers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Survey Markers	Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring Wells	Semi-Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>

* Explain failure on back of form.

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 11-5-2024	Time: 10:00 AM	Weather: cloudy	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		11064891.6
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum Print Name of Inspector Completing Form	Bryan Mangrum Signature		11-5-2024 Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 11-12-2024	Time: 1:00 PM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		11600357.3
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum Print Name of Inspector Completing Form	Bryan Mangrum Signature		11-12-2024 Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 11-19-2024	Time: 1:00 PM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		112272651.6
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		11-19-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 11-26-2024	Time: 12:30 PM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		Installed new chimney drain extension
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		12400205.4
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		11-26-2024
Print Name of Inspector Completing Form	Signature		Date

PLUM POINT ENERGY STATION CLASS 3N LANDFILL

Operations Inspection Form

Inspection Completed By: Bryan Mangrum Date: 11/25/2024

DESCRIPTION	INSPECTION INTERVAL	PASS	FAIL*
Surface Water System			
Drainage Ditches & Culverts	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Berms	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leachate Collection System			
Pumps	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Totalizers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Transmission/Recirculation Systems	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage Pond	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Landfill Final Cover System			
Erosion	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ponded Water	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Settlement	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vegetation	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Facility Roads			
Safety	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Routing	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Condition	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mud	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Passable Width	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency Response Equipment			
Fire Extinguisher	Check Quarterly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Test Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Communication System	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
List of Emergency Phone Numbers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
First Aid Kits	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Waste Cell and Plant Grid Markers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Survey Markers	Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring Wells	Semi-Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>

*Explain failure on back of form

ATTACHMENT 3

Landfill Inspection Photos



Photo 1. Water truck staged in shop parking lot.



Photo 2. Main haul road to landfill looking West with landfill in the



Photo 3. Active working face, fly ash looking North (Cell 3).



Photo 4. Active working face, bottom ash with chimney drain looking South (Cell 3).



Photo 5. Open disposal area, Cells 1 and 3.



Photo 6. Cell 3 East slope intermediate cover and haul road.



Photo 7. Typical perimeter side slope intermediate cover and vegetation.