


MEMO

To:	NRG Energy Services Plum Point Energy Station Attn: Mr. Richard Gry 1200 Ash Street Sutton, NE 68979
From:	Jason Ghidotti, PE 
RE:	2025 Annual Inspection of CCR Dust Control System for PPES CCR Landfill
Date:	December 11, 2025
Project #:	024-07122

Olsson has been contracted by Plum Point Services Company, LLC (PPSC) to prepare the 2025 annual Coal Combustion Residue (CCR) fugitive dust control report for the Plum Point Energy Station (PPES) CCR Landfill located in Osceola, Arkansas. This technical memorandum provides a summary of the assessment of the PPES plant fugitive dust control system from December 2024 through November 2025 and findings from an inspection by Olsson on December 3, 2025.

In accordance with §257.80(c), the purpose of the report is to provide a summary of the:

1. Actions taken by the Owner or Operator to control CCR fugitive dust,
2. Citizen complaints regarding fugitive dust, and
3. Any corrective measures taken during the reporting period.

The PPES facility has a Fugitive Dust Control Plan (FTN Associates, Ltd., October 2015) that provides information on potential sources of dust; fugitive dust control measures; methods for inspection, monitoring, and recordkeeping; and periodic assessment of the plan. A copy of the plan is kept in the office of the PPES Environmental Manager and the offices of the PPES CCR management company, Charah Solutions, Inc. (Charah).

Fugitive Dust Control Measures

NRG Energy Services (NRG), the power plant, and Charah manage fugitive dust at the PPES Landfill in accordance with the CCR Fugitive Dust Control Plan. These measures include:

1. Adhering to the speed limit posted on the haul road from the CCR loading station at the plant to the active disposal area.
2. Using adequate water to blend into the CCR materials in the pug mill to minimize fugitive dust during truck loading operations, but not too much to create excess free liquids.
3. Using a street sweeper with water spraying capability on the paved portion of the haul road at least once per shift. The frequency of sweeping/wetting activities is increased (drier conditions) or decreased (rain or snow) depending on the weather.

4. Applying water on the gravel portion of the haul road. Water is applied at a sufficient rate to control dust, but not to create excessive runoff. Water is applied more frequently in drier or windy conditions.
5. Cleaning out haul truck beds in the active disposal area on an as-needed basis to remove materials left in the truck bed.
6. Wetting ancillary gravel roads not used to haul ash material on an as-needed basis.
7. Wetting CCR material in the active disposal area if the material becomes too dry before grading of the waste.

Charah inspects the CCR loading area and the haul road at least twice daily during active hauling and disposal operations and keeps records of the sweeping and wetting operations. Copies of the records are included as Attachment 1. In addition, Charah performs the weekly inspection of the landfill, which includes assessing the condition of the CCR disposal and grading operations. Copies of these inspections during the reporting period are included as Attachment 2.

An inspection by an Olsson engineer on December 3, 2025, along with an interview of the Landfill Manger, confirmed usage of the fugitive dust control measures listed above. Attachment 3 provides photos of the landfill and haul roads taken during the inspection.

Citizen Complaints During the Reporting Period

There were no citizen complaints regarding fugitive dust from the PPES plant or the Landfill during the reporting period.

Corrective Measures Taken During the Reporting Period

There were no corrective measures implemented by NRG or Charah during the reporting period.

If you have any questions or comments regarding this memorandum, please feel free to contact me or Jonathan Toups, EI, at (501) 225-7779.

ATTACHMENT 1
LOGS OF SWEEPING AND WETTING OF CCR HAUL ROAD

2024

Plum Point

Dust Control Log

Month: DECEMBER

Date	Actively working? ¹		Weather ^{2, 7, 8}	Method(s) Used to Control Dust ³				"Is dust present?" ⁴		"Is erosion present?" ⁵		Preventative or Corrective Action Taken	Initials
	Yes/No		Temperature range, rainfall data, wind speeds, dry/damp, etc.	Currently Precipitating (Y/N)	Water Truck	Alternative Cover	Other	Yes	No	Yes	No	Examples: Added more water, applied additional alternative cover material.	
12/1/2024	YES		36 N 9 MPH CLOUDY	NO	YES			NO		NO			EW
12/2/2024	YES		44 N 7 MPH CLEAR	NO	YES			NO		NO			EW
12/3/2024	YES		45 W 10 MPH CLEAR	NO	YES			NO		NO			EW
12/4/2024	YES		49 NW 8 MPH CLEAR	NO	YES			NO		NO			EW
12/5/2024	YES		28 NE 4 MPH CLEAR	NO	YES			NO		NO			EW
12/6/2024	YES		38 SSE 2 MPH CLEAR	NO	YES			NO		NO			EW
12/7/2024	YES		35 SSW 10 MPH CLOUDY	NO	YES			NO		NO			EW
12/8/2024	YES		51 SSW 16 MPH CLOUDY	NO	YES			NO		NO			EW
12/9/2024	YES		33 N 2 MPH CLOUDY	NO	YES			NO		NO			EW
12/10/2024	YES		41 NNE 2 MPH CLOUDY	NO	YES			NO		NO			EW
12/11/2024	YES		31 NE 2 MPH CLOUDY	NO	YES			NO		NO			EW
12/12/2024	YES		38 WSW 2 MPH CLOUDY	NO	YES			NO		NO			EW
12/13/2024	YES		53 SSW 13 MPH SUNNY	NO	YES			NO		NO			EW
12/14/2024	YES		56 SSW 13 MPH SUNNY	NO	YES			NO		NO			EW
12/15/2024	YES		51 SSW 8 MPH CLOUDY	NO	YES			NO		NO			EW
12/16/2024	YES		60 SSW 8 MPH RAIN	YES	NO			NO		NO		PLANT DOWN	EW
12/17/2024	YES		53 S MPH WSW CLOUDY	NO	YES			NO		NO			EW
12/18/2024	YES		57 S 4 MPH CLOUDY	NO	YES			NO		NO			EW
12/19/2024	YES		51 NNW 8 MPH CLOUDY	NO	YES			NO		NO			EW
12/20/2024	YES		51 N 11 MPH CLOUDY	NO	YES			NO		NO			EW
12/21/2024	YES		13 WNW 9 MPH CLEAR	NO	YES			NO		NO			EW
12/22/2024	YES		45 WNW 15 MPH CLEAR	NO	YES			NO		NO			EW
12/23/2024	NO		53 SSW 14 MPH CLEAR	NO	NO			NO		NO		PLANT DOWN	EW
12/24/2024	NO		55 SSW 14 MPH CLEAR	NO	NO			NO		NO		PLANT DOWN	EW
12/25/2024	NO		40 SE 4 MPH CLOUDY	NO	NO			NO		NO		PLANT DOWN	EW
12/26/2024	NO		52 SE 10 MPH RAIN	YES	NO			NO		NO		PLANT DOWN	EW
12/27/2024	NO		52 SSE 16 MPH RAIN	YES	NO			NO		NO		PLANT DOWN	EW
12/28/2024	NO		56 SE 5 MPH CLOUDY	NO	NO			NO		NO		PLANT DOWN	EW
12/29/2024	NO		59 SSE 6 MPH CLOUDY	NO	NO			NO		NO		PLANT DOWN	EW
12/30/2024	NO		55 SW 12 MPH CLOUDY	NO	NO			NO		NO		PLANT DOWN	EW
12/31/2024	NO		66 SSW 14 MPH CLOUDY	NO	NO			NO		NO		PLANT DOWN	EW
12/1/2024	NO		56 SW 12 MPH CLOUDY	NO	NO			NO		NO		PLANT DOWN	EW
12/2/2024	NO		64 SSW 11 MPH CLOUDY	NO	NO			NO		NO		PLANT DOWN	EW
12/3/2024	YES		48 SW 5 MPH CLOUDY	NO	YES			NO		NO			EW
12/4/2024	YES		53 SE 2 MPH CLOUDY	NO	YES			NO		NO			EW
12/5/2024	YES		43 SE 5 MPH CLOUDY	NO	YES			NO		NO			EW
12/6/2024	YES		49 SW 5 MPH CLOUDY	NO	YES			NO		NO			EW
12/7/2024	YES		10 NNW 18 MPH CLEAR	NO	YES			NO		NO			EW
12/8/2024	YES		39 NNW 19 MPH CLEAR	NO	YES			NO		NO			EW
12/9/2024	YES		38 NNE 7 MPH CLEAR	NO	YES			NO		NO			EW
12/10/2024	YES		41 NNE 6 MPH CLEAR	NO	YES			NO		NO			EW
12/11/2024	YES		30 SE 3 MPH CLEAR	NO	NO			NO		NO			EW
12/12/2024	YES		43 SE 6 MPH CLEAR	NO	YES			NO		NO			EW
12/13/2024	YES		47 S 10 MPH CLOUDY	NO	YES			NO		NO			EW
12/14/2024	YES		51 S 10 MPH CLOUDY	NO	YES			NO		NO			EW
12/15/2024	YES		48 SE 10 MPH CLOUDY	NO	YES			NO		NO			EW
12/16/2024	YES		53 SSE 10 MPH CLOUDY	NO	YES			NO		NO			EW
12/17/2024	YES		57 SSE 9 MPH CLOUDY	NO	YES			NO		NO		CHRISTMAS	EW
12/18/2024	YES		59 SE 7 MPH CLOUDY	NO	YES			NO		NO		CHRISTMAS	EW
12/19/2024	YES		60 SSW 13 MPH CLOUDY	NO	YES			NO		NO			EW
12/20/2024	YES		60 SSW 12 MPH CLOUDY	NO	YES			NO		NO			EW
12/21/2024	YES		58 S 3 MPH CLOUDY	NO	YES			NO		NO			EW
12/22/2024	YES		62 ESE 4 MPH CLOUDY	YES	NO			NO		NO			EW
12/23/2024	YES		56 W 10 MPH CLOUDY	NO	YES			NO		NO			EW
12/24/2024	YES		59 WSW 9 MPH CLOUDY	NO	YES			NO		NO			EW
12/25/2024	YES		47 SE 4 MPH CLOUDY	NO	YES			NO		NO			EW
12/26/2024	YES		63 SSE 13 MPH SUNNY	NO	YES			NO		NO			EW
12/27/2024	YES		50 W 15 MPH CLOUDY	NO	YES			NO		NO			EW
12/28/2024	YES		49 NW 21 MPH CLOUDY	NO	YES			NO		NO			EW

2025

Plum Point

Dust Control Log

Month: JANUARY

Date	Actively working? ¹		Weather ^{2, 7, 8}	Method(s) Used to Control Dust ³				"Is dust present?" ⁴		"Is erosion present?" ⁵		Preventative or Corrective Action Taken	Initials
	Yes/No		Temperature range, rainfall data, wind speeds, dry/damp, etc.	Currently Percipitating (Y/N)	Water Truck	Alternative Cover	Other	Yes	No	Yes	No	Examples: Added more water, applied additional alternative cover material.	
1/1/2025			HOLIDAY										
1/2/2025	11:01 AM	YES	38 NNE 8 MPH SUNNY	NO	YES			NO	NO	NO	NO		EW
	1:01 PM	YES	41 NE 10 MPH SUNNY	NO	YES			NO	NO	NO	NO		EW
1/3/2025	11:01 AM	YES	40 N 12 MPH SUNNY	NO	YES			NO	NO	NO	NO		EW
	1:01 PM	YES	44 NNW 11 SUNNY	NO	YES			NO	NO	NO	NO		EW
1/4/2025	11:01 AM	YES	40 E 6 MPH CLOUDY	NO	YES			NO	NO	NO	NO		EW
	1:01 PM	YES	42 E 6 MPH CLOUDY	NO	YES			NO	NO	NO	NO		EW
1/5/2025	11:01 AM	YES	51 S 15 MPH RAIN	YES	NO			NO	NO	NO	NO		EW
	1:01 PM	YES	55 S 17 MPH RAIN	YES	NO			NO	NO	NO	NO		EW
1/6/2025	11:01 AM	YES	26 NW 19 MPH CLOUDY	NO	NO			NO	NO	NO	NO		EW
	1:01 PM	YES	32 NW 19 MPH CLOUDY	NO	NO			NO	NO	NO	NO		EW
1/7/2025	11:01 AM	YES	28 N 10 MPH CLOUDY	NO	NO			NO	NO	NO	NO		EW
	1:01 PM	YES	30 N 12 MPH CLOUDY	NO	NO			NO	NO	NO	NO		EW
1/8/2025	11:01 AM	YES	27 NW 9 MPH CLOUDY	NO	NO			NO	NO	NO	NO		EW
	1:01 PM	YES	31 NW 10 MPH CLOUDY	NO	NO			NO	NO	NO	NO		EW
1/9/2025	11:01 AM	YES	19 S 3 MPH SUNNY	NO	NO			NO	NO	NO	NO		EW
	1:01 PM	YES	19 S 3 MPH SUNNY	NO	NO			NO	NO	NO	NO		EW
1/10/2025	11:01 AM	NO	31 NE 6 MPH CLOUDY SNOW	YES SNOW	NO			NO	NO	NO	NO		EW
	1:01 PM	NO	32 NE 5 MPH CLOUDY SNOW	YES SNOW	NO			NO	NO	NO	NO		EW
1/11/2025	11:01 AM	YES	19 SSW 7 MPH SUNNY	NO	YES			NO	NO	NO	NO		EW
	1:01 PM	YES	36 SSW 7 MPH SUNNY	NO	YES			NO	NO	NO	NO		EW
1/12/2025	11:01 AM	YES	40 SSW 10 MPH SUNNY	NO	YES			NO	NO	NO	NO		EW
	1:01 PM	YES	46 SSW 9 MPH SUNNY	NO	YES			NO	NO	NO	NO		EW
1/13/2025	11:01 AM	YES	34 NNW 11 SUNNY	NO	NO			NO	NO	NO	NO		EW
	1:01 PM	YES	46 SSW 8 MPH SUNNY	NO	YES			NO	NO	NO	NO		EW
1/14/2025	11:01 AM	YES	43 SW 10 MPH SUNNY	NO	YES			NO	NO	NO	NO		BM
	1:01 PM	YES	46 WSW 9 MPH SUNNY	NO	YES			NO	NO	NO	NO		BM
1/15/2025	11:01 AM	YES	36 ENE 7 MPH SUNNY	NO	YES			NO	NO	NO	NO		EW
	1:01 PM	YES	41 NE 1 MPH SUNNY	NO	YES			NO	NO	NO	NO		EW
1/16/2025	11:01 AM	YES	50 WNW 10 MPH SUNNY	NO	YES			NO	NO	NO	NO		EW
	1:01 PM	YES	54 WNW 11 MPH SUNNY	NO	YES			NO	NO	NO	NO		EW
1/17/2025	11:01 AM	YES	54 SSW 17 MPH CLOUDY	NO	YES			NO	NO	NO	NO		EW
	1:01 PM	YES	56 SSW 17 MPH CLOUDY	NO	YES			NO	NO	NO	NO		EW
1/18/2025	11:01 AM	YES	43 N 20 MPH CLOUDY	NO	YES			NO	NO	NO	NO		EW
	1:01 PM	YES	40 N 18 MPH CLOUDY	NO	YES			NO	NO	NO	NO		EW
1/19/2025	11:01 AM	YES	26 NW 18 MPH SUNNY	NO	NO			NO	NO	NO	NO		EW
	1:01 PM	YES	29 NW 18 MPH SUNNY	NO	NO			NO	NO	NO	NO		EW
1/20/2025	11:01 AM	YES	15 NNW 4 MPH CLOUDY	NO	NO			NO	NO	NO	NO		EW
	1:01 PM	YES	24 NNW 4 MPH CLOUDY	NO	NO			NO	NO	NO	NO		EW
1/21/2025	11:01 AM	YES	18 N 13 MPH CLOUDY	NO	NO			NO	NO	NO	NO		EW
	1:01 PM	YES	22 NNW 10 MPH SUNNY	NO	NO			NO	NO	NO	NO		EW
1/22/2025	11:01 AM	YES	14 SSE 7 MPH SUNNY	NO	NO			NO	NO	NO	NO		EW
	1:01 PM	YES	29 S 11 MPH SUNNY	NO	NO			NO	NO	NO	NO		EW
1/23/2025	11:01 AM	YES	23 WSW 5 MPH SUNNY	NO	NO			NO	NO	NO	NO		EW
	1:01 PM	YES	42 WNW 10 MPH SUNNY	NO	YES			NO	NO	NO	NO		EW
1/24/2025	11:01 AM	YES	31 W 9 MPH SUNNY	NO	NO			NO	NO	NO	NO		EW
	1:01 PM	YES	33 SW 7 MPH SUNNY	NO	YES			NO	NO	NO	NO		EW
1/25/2025	11:01 AM	YES	47 SW 16 MPH CLOUDY	NO	YES			NO	NO	NO	NO		EW
	1:01 PM	YES	50 SW 16 MPH CLOUDY	NO	YES			NO	NO	NO	NO		EW
1/26/2025	11:01 AM	YES	47 WNW 1 MPH CLOUDY	NO	YES			NO	NO	NO	NO		EW
	1:01 PM	YES	49 NNW 2 MPH CLOUDY	NO	YES			NO	NO	NO	NO		EW
1/27/2025	11:01 AM	YES	18 W 8 MPH SUNNY	NO	YES			NO	NO	NO	NO		BM
	1:01 PM	YES	47 WSW 5 MPH SUNNY	NO	YES			NO	NO	NO	NO		BM
1/28/2025	11:01 AM	YES	50 W 3 MPH SUNNY	NO	YES			NO	NO	NO	NO		EW
	1:01 PM	YES	59 WSW 3 MPH SUNNY	NO	YES			NO	NO	NO	NO		EW
1/29/2025	11:01 AM	YES	51 W 4 MPH SUNNY	NO	YES			NO	NO	NO	NO		EW
	1:01 PM	YES	59 WSW 5 MPH SUNNY	NO	YES			NO	NO	NO	NO		EW
1/30/2025	11:01 AM	YES	54 ESE 5 MPH RAIN	YES	NO			NO	NO	NO	NO		EW
	1:01 PM	YES	55 S 7 MPH RAIN	YES	NO			NO	NO	NO	NO		EW
31-Jan	11:01 AM	YES	60 WSW 14 MPH CLOUDY	NO	YES			NO	NO	NO	NO		EW
	1:01 PM	YES	61 WSW 13 MPH CLOUDY	NO	YES			NO	NO	NO	NO		EW

Month: MARCH

2025

Plum Point

Dust Control Log

Actively working? ¹		Weather ^{2, 7, 8}		Method(s) Used to Control Dust ³				*Is dust present? ⁴		*Is erosion present? ⁵		Preventative or Corrective Action Taken	Initials
Date	Yes/No	Temperature range, rainfall data, wind speeds,	Currently Percipitating (Y/N)	Water Truck	Alternative Cover	Other	Yes	No	Yes	No	Examples: Added more water, applied additional alternative cover material,		
3/1/2025	1130AM	YES	49 N 14 MPH CLOUDY	NO				NO		NO		EW	
	9PM	YES	53 N 24 MPH CLOUDY	NO				NO		NO		EW	
3/2/2025	11AM	YES	45 ENE 5 MPH SUNNY	NO				NO		NO		BM	
	9PM	YES	47 ENE 5 MPH SUNNY	NO				NO		NO		BM	
3/3/2025	11:00	YES	48 SE 7 MPH SUNNY	NO				NO		NO		BM	
	9PM	YES	51 SSE 8 MPH CLOUDY	NO				NO		NO		BM	
3/4/2025	1100 AM	NO	47 SSE 7 MPH CLOUDY	NO				NO		NO		EW	
	230 PM	NO	60 SSE 11 MPH SUNNY	NO				NO		NO		EW	
3/5/2025	11AM	NO	42 W 24 MPH CLOUDY	NO				NO		NO		EW	
	1100 PM	NO	43 WNW 27 MPH CLOUDY	NO				NO		NO		EW	
3/6/2025	11:00 AM	YES	43 NW 8 MPH SUNNY	NO				NO		NO		EW	
	2:00 PM	YES	48 NW 7 MPH SUNNY	NO				NO		NO		EW	
3/7/2025	8AM	YES	47 S 10 MPH CLOUDY	NO				NO		NO		EW	
	9PM	YES	59 SSW 18 MPH CLOUDY	NO				NO		NO		EW	
3/8/2025	1130AM	YES	50 NNE 10 MPH CLOUDY	NO				NO		NO		EW	
	9PM	YES	53 NNE 11 MPH CLOUDY	NO				NO		NO		EW	
3/9/2025	10am	YES	52 ENE 11 MPH SUNNY	NO				NO		NO		EW	
	9pm	YES	58 NE 9 MPH CLOUDY	NO				NO		NO		EW	
3/10/2025	11AM	YES	62 WNW 6 MPH SUNNY	NO				NO		NO		EW	
	9PM	YES	68 W 7 MPH SUNNY	NO				NO		NO		EW	
3/11/2025	11:00 AM	YES	65 SW 18 MPH SUNNY	NO				NO		NO		EW	
	230 PM	YES	74 SW 18 MPH SUNNY	NO				NO		NO		EW	
3/12/2025	1130 AM	YES	72 SSW 18 MPH SUNNY	NO				NO		NO		EW	
	230 PM	YES	74 SSW 16 MPH SUNNY	NO				NO		NO		EW	
3/13/2025	11:00 AM	YES	67 SSW 8 MPH SUNNY	NO				NO		NO		EW	
	2:00 PM	YES	73 S 7 MPH SUNNY	NO				NO		NO		EW	
3/14/2025	11AM	YES	76 S 17 MPH SUNNY	NO				NO		NO		EW	
	9PM	YES	79 S 19 MPH SUNNY	YES				NO		NO		EW	
3/15/2025	11AM	YES	57 SSW 11 MPH CLOUDY	YES				NO		NO		EW	
	9PM	YES	61 SW 12 MPH CLOUDY	NO				NO		NO		EW	
3/16/2025	10AM	YES	43 WNW 16 MPH CLOUDY	NO				NO		NO		EW	
	9PM	YES	47 WNW 17 MPH CLOUDY	NO				NO		NO		EW	
3/17/2025	10am	YES	49 SSE 4 MPH CLOUDY	NO				NO		NO		EW	
	9pm	YES	60 S9 SSE 4 MPH CLOUDY	NO				NO		NO		EW	
3/18/2025	11:00 AM	YES	70 S 17 MPH CLOUDY	NO				NO		NO		EW	
	2:00 PM	YES	74 S 19 MPH CLOUDY	NO				NO		NO		EW	
3/19/2025	1130am	YES	72 SSW 27 MPH SUNNY	NO				NO		NO		EW	
	9pm	YES	74 SSW 27 MPH SUNNY	NO				NO		NO		EW	
3/20/2025	1130 am	YES	46 NW 16 MPH CLOUDY	NO				NO		NO		EW	
	9pm	YES	53 WNW 16MPH SUNNY	NO				NO		NO		EW	
3/21/2025	10am	YES	52 S 9 MPH SUNNY	NO				NO		NO		EW	
	9pm	YES	62 SSW 16 MPH CLOUDY	NO				NO		NO		EW	
3/22/2025	11AM	YES	66 NNW 5 MPH SUNNY	NO				NO		NO		EW	
	9PM	YES	68 NNW 19 MPH SUNNY	NO				NO		NO		EW	
3/23/2025	10AM	YES	66 SSW 22 MPH CLOUDY	NO				NO		NO		BM	
	1230PM	YES	68 SSW 19 MPH CLOUDY	NO				NO		NO		BM	
3/24/2025	1130 AM	YES	66 SW 5 MPH SUNNY	NO				NO		NO		BM	
	1:00 PM	YES	68 SW 5 MPH SUNNY	NO				NO		NO		BM	
3/25/2025	10AM	YES	68 NW12 MPH SUNNY	NO				NO		NO		BM	
	9PM	YES	75 NW 13 MPH SUNNY	NO				NO		NO		BM	
3/26/2025	11:00 AM	YES	70 NW 8 MPH SUNNY	NO				NO		NO		EW	
	2:30PM	YES	72 NW 8 MPH SUNNY	NO				NO		NO		EW	
3/27/2025	11AM	YES	75 S 9 MPH SUNNY	NO				NO		NO		EW	
	9PM	YES	80 SSW 12 MPH SUNNY	NO				NO		NO		EW	
3/28/2025	1:00 AM	YES	61 SSE 5 MPH SUNNY	NO				NO		NO		EW	
	9PM	YES	84 SSW 19 MPH CLOUDY	NO				NO		NO		EW	
3/29/2025	10AM	YES	67 SSE 12 MPH CLOUDY	NO				NO		NO		EW	
	130PM	YES	65 S 16 MPH RAIN	YES				NO		NO		EW	
3/30/2025	9AM	YES	68 S 12 MPH CLOUDY	NO				NO		NO		EW	
	9PM	YES	76 S 17 MPH SUNNY	NO				NO		NO		EW	
3/31/2025	1130AM	YES	55 NNW 15 MPH CLOUDY	NO				NO		NO		EW	
	9PM	YES	57 N 14 MPH CLOUDY	NO				NO		NO		EW	

Month: APRIL

2025

Plum Point

Dust Control Log

Date	Actively working? ¹		Weather ^{2, 7, 8}	Method(s) Used to Control Dust ³				*Is dust present? ⁴		*Is erosion present? ⁵		Preventative or Corrective Action Taken	Initials
	Yes/No	Temperature range, rainfall data, wind speeds,	Currently Percipitating (Y/N)	Water Truck	Alternative Cover	Other	Yes	No	Yes	No	Examples: Added more water, applied additional alternative cover material,		
4/1/2025	9AM	YES	60 SE 9 MPH SUNNY	NO	YES			NO		NO		EW	
	2PM	YES	68 SE 10 MPH SUNNY	NO	YES			NO		NO		EW	
4/2/2025	1130AM	YES	82 S 23 MPH CLOUDY	NO	YES			NO		NO		BM	
	230PM	YES	85 SS 27 MPH CLOUDY	NO	YES			NO		NO		BM	
4/3/2025	1130AM	YES	60 E 2 MPH RAIN	YES	NO			NO		NO		BM	
	230PM	YES	63 E 2 MPH RAIN	YES	NO			NO		NO		BM	
4/4/2025	1130AM	YES	82 S 14 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	84 S 14 MPH SUNNY	NO	YES			NO		NO		EW	
4/5/2025	1100AM	NO	58 N 7 MPH RAIN	YES	NO			NO		NO		EW	
	1100PM	NO	54 NNW 18 MPH RAIN	YES	NO			NO		NO		EW	
4/6/2025	8AM	NO	47 NNE6 MPH CLOUDY	NO	NO			NO		NO		EW	
	1200PM	NO	49 NE 11 MPH CLOUDY	NO	NO			NO		NO		EW	
4/7/2025	10AM	NO	50 N 12 MPH CLOUDY	NO	NO			NO		NO		EW	
	2PM	NO	55 N 12 MPH CLOUDY	NO	NO			NO		NO		EW	
4/8/2025	10AM	NO	48 NE 13 MPH SUNNY	NO	NO			NO		NO		BM	
	2PM	NO	51 NNE 10 MPH SUNNY	NO	NO			NO		NO		BM	
4/9/2025	11AM	NO	57 S 11 MPH SUNNY	NO	NO			NO		NO		BM	
	2PM	NO	66 SSW 12 MPH SUNNY	NO	NO			NO		NO		BM	
4/10/2025	11AM	NO	70W/NW 5 MPH SUNNY	NO	NO			NO		NO		EW	
	2PM	NO	75 WNW 7 MPH CLOUDY	NO	NO			NO		NO		EW	
4/11/2025	1130AM	NO	64 N 16 MPH CLOUDY	NO	NO			NO		NO		EW	
	2PM	NO	65 N 18 MPH CLOUDY	NO	NO			NO		NO		EW	
4/12/2025	1030AM	NO	60 N5 MPH SUNNY	NO	NO			NO		NO		EW	
	200PM	NO	63 N 4 MPH SUNNY	NO	NO			NO		NO		EW	
4/13/2025	1130AM	NO	71 S 18 MPH SUNNY	NO	NO			NO		NO		EW	
	2PM	NO	78 S 18 MPH SUNNY	NO	NO			NO		NO		EW	
4/14/2025	1130 AM	NO	76 SW 17 MPH SUNNY	NO	NO			NO		NO		EW	
	2PM	NO	78 SW 17 MPH SUNNY	NO	NO			NO		NO		EW	
4/15/2025	1130AM	YES	62 NNW 14 SUNNY	NO	YES			NO		NO		EW	
	2PM	YES	65 NW 13 SUNNY	NO	YES			NO		NO		EW	
4/16/2025	1130AM	YES	67 ESE 4 MPH SUNNY	NO	YES			NO		NO		EW	
	2PM	YES	71 S 5MPH SUNNY	NO	YES			NO		NO		EW	
4/17/2025	1100AM	NO	79 S 17 MPH SUNNY	NO	NO			NO		NO		EW	
	230PM	NO	81 S 17 MPH SUNNY	NO	NO			NO		NO		EW	
4/18/2025	8AM	NO	71 SSW 20 CLOUDY	NO	NO			NO		NO		EW	
	2PM	NO	78 SSW 21 MPH CLOUDY	NO	NO			NO		NO		EW	
4/19/2025	1130AM	YES	76 SSW 16 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	81 SSW 15 MPH CLOUDY	NO	YES			NO		NO		EW	
4/20/2025	1130AM	YES	80 SSW 18 MPH SUNNY	NO	YES			NO		NO		EW	
	2PM	YES	81 S 18 MPH SUNNY	NO	YES			NO		NO		EW	
4/21/2025	11AM	YES	82 S 11 MPH SUNNY	NO	YES			NO		NO		EW	
	2PM	YES	84 SW 11 MPH SUNNY	NO	YES			NO		NO		EW	
4/22/2025	11AM	YES	77 S 8 MPH CLOUDY	NO	YES			NO		NO		EW	
	130PM	YES	80 S 8 MPH CLOUDY	NO	YES			NO		NO		EW	
4/23/2025	11AM	YES	75 WSW 6 MPH CLOUDY	NO	YES			NO		NO		BM	
	230 PM	YES	77 SW 8 MPH CLOUDY	NO	YES			NO		NO		BM	
4/24/2025	11AM	YES	72 S 5 MPH CLOUDY	NO	YES			NO		NO		BM	
	2PM	YES	78 S 6 MPH CLOUDY	NO	YES			NO		NO		BM	
4/25/2025	1130AM	YES	73 WSW 10 MPH CLOUDY	NO	YES			NO		NO		BM	
	2PM	YES	75 WSW 10 MPH CLOUDY	NO	YES			NO		NO		BM	
4/26/2025	1030AM	YES	65 NNE 12 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	71 NE 10 MPH CLOUDY	NO	YES			NO		NO		EW	
4/27/2025	8AM	YES	60 E 8 MPH CLOUDY	NO	YES			NO		NO		EW	
	1200PM	YES	63 E 8 MPH CLOUDY	NO	YES			NO		NO		EW	
4/28/2025	10AM	YES	71 S 10 MPH CLOUDY	NO	YES			NO		NO		EW	
	130PM	YES	78 SW 10 MPH CLOUDY	NO	YES			NO		NO		EW	
4/29/2025	1130AM	YES	78 SW 12 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	81 SW 13 MPH CLOUDY	NO	YES			NO		NO		EW	
4/30/2025	8AM	YES	75 S 8 MPH SUNNY	NO	YES			NO		NO		EW	
	2PM	YES	83 S 15 MPH SUNNY	NO	YES			NO		NO		EW	

Month: MAY

2025

Plum Point

Dust Control Log

Date	Actively working? ¹	Yes/No	Weather ^{2, 7, 8} Temperature range, rainfall data, wind speeds.	Method(s) Used to Control Dust ³			*Is dust present? ⁴		*Is erosion present? ⁵		Preventative or Corrective Action Examples: Added more water, applied additional alternative cover material.	Initials
				Currently Percipitating (Y/N)	Water Truck	Alternative Cover	Other	Yes	No	Yes		
5/1/2025	11AM	YES	70 SW 14 MPH CLOUDY	NO	YES			NO		NO		EW
	2PM	YES	72 SW 14 MPH CLOUDY	NO	YES			NO		NO		EW
5/2/2025	11AM	NO	61 N 5 MPH RAIN	YES	NO			NO		NO		EW
	1PM	NO	69 SW 8 MPH RAIN	YES	NO			NO		NO		EW
5/3/2025	1130AM	YES	67 NW 17 MPH CLOUDY	NO	YES			NO		NO		EW
	230PM	YES	69 NW 17 MPH CLOUDY	NO	YES			NO		NO		EW
5/4/2025	1030AM	YES	60 NNW 12 MPH CLOUDY	NO	YES			NO		NO		EW
	2PM	YES	65 NW 10 MPH CLOUDY	NO	YES			NO		NO		EW
5/5/2025	1030AM	YES	62 N 7 MPH CLOUDY	NO	YES			NO		NO		BM
	1:00 PM	YES	69 N 7 MPH CLOUDY	NO	YES			NO		NO		BM
5/6/2025	11AM	YES	71 ESE 6 MPH SUNNY	NO	YES			NO		NO		BM
	1230PM	YES	75 ESE 6 MPH SUNNY	NO	YES			NO		NO		BM
5/7/2025	10AM	YES	65 ESE 9 MPH CLOUDY	NO	YES			NO		NO		EW
	1PM	YES	70 ESE 8 MPH CLOUDY	NO	YES			NO		NO		EW
5/8/2025	10AM	YES	67 NW 17 MPH CLOUDY	NO	YES			NO		NO		EW
	1PM	YES	69 NW 17 MPH CLOUDY	NO	YES			NO		NO		EW
5/9/2025	11AM	YES	68 NE 14 MPH CLOUDY	NO	YES			NO		NO		EW
	2PM	YES	71 NE 14 MPH CLOUDY	NO	YES			NO		NO		EW
5/10/2025	11AM	YES	66 NE 15 MPH SUNNY	NO	YES			NO		NO		EW
	2PM	YES	70 NE 16 MPH CLOUDY	NO	YES			NO		NO		EW
5/11/2025	9AM	YES	64 E 10 MPH CLOUDY	NO	YES			NO		NO		EW
	1PM	YES	73 ENE 19 MPH CLOUDY	NO	YES			NO		NO		EW
	1030AM	YES	66 ESE 7 MPH RAIN	YES	NO			NO		NO		EW
5/12/2025	1:00 PM	YES	71 SSE 6 MPH RAIN	YES	NO			NO		NO		EW
	1130AM	YES	72 SSW 6 MPH CLOUDY	NO	YES			NO		NO		EW
5/13/2025	1PM	YES	75 WSW 7 MPH CLOUDY	NO	YES			NO		NO		EW
5/14/2025	1130 AM	YES	80 S 13 MPH CLOUDY	NO	YES			NO		NO		EW
	2PM	YES	82 S 14 MPH CLOUDY	NO	YES			NO		NO		EW
5/15/2025	1130AM	YES	78 SSW 18 MPH SUNNY	NO	YES			NO		NO		EW
	2PM	YES	81 SSW 18 MPH SUNNY	NO	YES			NO		NO		EW
5/16/2025	1130AM	YES	80 SW 18 MPH CLOUDY	NO	YES			NO		NO		EW
	2PM	YES	85 SW 20 MPH CLOUDY	NO	YES			NO		NO		EW
5/17/2025	1030AM	YES	81 WSW 9 MPH CLOUDY	NO	YES			NO		NO		EW
	230PM	YES	86 WSW 10 MPH SUNNY	NO	YES			NO		NO		EW
5/18/2025	9AM	YES	73 SE 6 MPH SUNNY	NO	YES			NO		NO		EW
	1PM	YES	76 SE 7 MPH SUNNY	NO	YES			NO		NO		EW
5/19/2025	1130AM	YES	84 S 13 MPH SUNNY	NO	YES			NO		NO		EW
	2PM	YES	86 S 13 MPH SUNNY	NO	YES			NO		NO		EW
5/20/2025	1130AM	YES	78 SSW 18 MPH SUNNY	NO	YES			NO		NO		EW
	2PM	YES	81 SSW 18 MPH SUNNY	NO	YES			NO		NO		EW
5/21/2025	9:00 AM	YES	66 WSW 7 MPH SUNNY	NO	YES			NO		NO		EW
	1:00 PM	YES	80 WNW 12 MPH SUNNY	NO	YES			NO		NO		EW
5/22/2025	11AM	YES	77 NNW 7 MPH CLOUDY	NO	YES			NO		NO		EW
	130PM	YES	81 NNW 7 MPH CLOUDY	NO	YES			NO		NO		EW
5/23/2025	11AM	YES	68 ENE 8 MPH CLOUDY	NO	YES			NO		NO		BM
	230 PM	YES	71 ENE 5 MPH CLOUDY	NO	YES			NO		NO		BM
5/24/2025	11AM	YES	64 ESE 8 MPH RAIN	YES	NO			NO		NO		BM
	2PM	YES	66 E 8 MPH CLOUDY	NO	NO			NO		NO		BM
5/25/2025	1130AM	YES	68 E 7 MPH CLOUDY	NO	YES			NO		NO		BM
	2PM	YES	69 E 4 MPH CLOUDY	NO	YES			NO		NO		BM
5/26/2025	1030AM	NO	HOLIDAY	HOLIDAY	YES						HOLIDAY	
	2PM	NO	HOLIDAY	HOLIDAY	YES						HOLIDAY	
5/27/2025	1130am	YES	68 NNW 6 MPH CLOUDY	NO	YES			NO		NO		BM
	2pm	YES	71 NNW 6 MPH CLOUDY	NO	YES			NO		NO		BM
5/28/2025	1130am	YES	73 WNW 6 MPH CLOUDY	NO	YES			NO		NO		EW
	2PM	YES	76 WNW 6 MPH CLOUDY	NO	YES			NO		NO		EW
5/29/2025	9:00am	YES	77 WNW 3 MPH CLOUDY	NO	YES			NO		NO		EW
	3:00pm	YES	81 WNW 3 MPH CLOUDY	NO	YES			NO		NO		EW
5/30/2025	9:00 AM	YES	67 NNW 11 MPH SUNNY	NO	YES			NO		NO		EW
	2PM	YES	77 NW 11 MPH SUNNY	NO	YES			NO		NO		EW
31-May	1130am	YES	84 WSW 7 MPH CLOUDY	NO	YES			NO		NO		EW
	2pm	YES	86 WSW 7 MPH CLOUDY	NO	YES			NO		NO		EW

Month: JUNE

2025

Plum Point

Dust Control Log

Date	Actively working? ¹		Weather ^{2, 7, 8}	Method(s) Used to Control Dust ³				*Is dust present? ⁴		*Is erosion present? ⁵		Preventative or Corrective Action Taken	Initials
	Yes/No	Temperature range, rainfall data, wind speeds,	Currently Percipitating (Y/N)	Water Truck	Alternative Cover	Other	Yes	No	Yes	No	Examples: Added more water, applied additional alternative cover material,		
6/1/2025	11AM	YES	84 WSW 7 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	86 WSW 7 MPH CLOUDY	NO	YES			NO		NO		EW	
6/2/2025	1130 AM	YES	85 S 4 MPH SUNNY	NO	YES			NO		NO		EW	
	2PM	YES	87 S 5 MPH CLOUDY	NO	YES			NO		NO		EW	
6/3/2025	1130AM	YES	84 S 13 MPH SUNNY	NO	YES			NO		NO		EW	
	230PM	YES	86 S 14 MPH CLOUDY	NO	YES			NO		NO		EW	
6/4/2025	1100AM	YES	82 S 8 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	85 S 7 MPH CLOUDY	NO	YES			NO		NO		EW	
6/5/2025	1100AM	YES	84 SW 6 MPH CLOUDY	NO	YES			NO		NO		BM	
	1100 PM	YES	85 WSW 6 MPH CLOUDY	NO	YES			NO		NO		BM	
6/6/2025	11AM	YES	81 SW 9 MPH RAIN	YES	NO			NO		NO		BM	
	1200PM	YES	82 SW 11 MPH CLOUDY	NO	NO			NO		NO		BM	
6/7/2025	1130 AM	YES	68 SW 7 MPH RAIN	YES	NO			NO		NO		EW	
	2PM	YES	71 SSW 11 MPH RAIN	YES	NO			NO		NO		EW	
6/8/2025	1130 AM	YES	82 WNW 6 MPH SUNNY	NO	YES			NO		NO		EW	
	2PM	YES	84 WNW 6 MPH CLOUDY	NO	YES			NO		NO		EW	
6/9/2025	11AM	YES	77 NNW 8 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	80 NNW 8 MPH CLOUDY	NO	YES			NO		NO		EW	
6/10/2025	11AM	YES	84 NW 6 MPH SUNNY	NO	YES			NO		NO		EW	
	2PM	YES	86 NW 6 MPH SUNNY	NO	YES			NO		NO		EW	
6/11/2025	9AM	YES	85 S 6 MPH SUNNY	NO	YES			NO		NO		EW	
	2PM	YES	88 SE 6MPH SUNNY	NO	YES			NO		NO		EW	
6/12/2025	1030A11AM	YES	80 S 5 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	83 S 5 MPH CLOUDY	NO	YES			NO		NO		EW	
6/13/2025	1130AM	YES	82 SW 13 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	64 SW 13 MPH CLOUDY	NO	YES			NO		NO		EW	
6/14/2025	1130 AM	YES	78 SW 10 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	82 W 10 MPH CLOUDY	NO	YES			NO		NO		EW	
6/15/2025	1130AM	YES	86 SSW 5 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	88 SSW 5 MPH CLOUDY	NO	YES			NO		NO		EW	
6/16/2025	1130AM	YES	81 SW9 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	83 W 9 MPH CLOUDY	NO	YES			NO		NO		EW	
6/17/2025	1100AM	YES	80 SW 11 MPH CLOUDY	NO	YES			NO		NO		EW	
	230PM	YES	87 SW 11 MPH CLOUDY	NO	YES			NO		NO		EW	
6/18/2025	11AM	YES	83 S 16 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	87 SSW 19 MPH CLOUDY	NO	YES			NO		NO		EW	
6/19/2025	1130AM	YES	85 W 8 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	88 W 8 MPH CLOUDY	NO	YES			NO		NO		EW	
6/20/2025	1130AM	YES	88 SSW 8 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	90 SSW 8 MPH SUNNY	NO	YES			NO		NO		EW	
6/21/2025	1130 AM	YES	90 SW 12 MPH SUNNY	NO	YES			NO		NO		EW	
	2PM	YES	93 SW 12 MPH SUNNY	NO	YES			NO		NO		EW	
6/22/2025	11AM	YES	90 SSW 8 MPH SUNNY	NO	YES			NO		NO		EW	
	1200 PM	YES	93 SSW 8 MPH CLOUDY	NO	YES			NO		NO		EW	
6/23/2025	11AM	YES	90 ESE 4 MPH SUNNY	NO	YES			NO		NO		BM	
	230 PM	YES	93ESE 4 MPH SUNNY	NO	YES			NO		NO		BM	
6/24/2025	11AM	YES	91 SW 6 MPH SUNNY	NO	YES			NO		NO		BM	
	2PM	YES	93 SW 6 MPH SUNNY	NO	YES			NO		NO		BM	
6/25/2025	9AM	YES	84 SW 2 MPH SUNNY	NO	YES			NO		NO		BM	
	2PM	YES	95 S 4 MPH CLOUDY	NO	YES			NO		NO		BM	
6/26/2025	1000 AM	YES	88 S 5 MPH SUNNY	NO	YES			NO		NO		EW	
	2PM	YES	91 SW 7 MPH CLOUDY	NO	YES			NO		NO		EW	
6/27/2025	100AM	YES	84 SW 6 MPH CLOUDY	NO	YES			NO		NO		BM	
	2PM	YES	87 SW 6 MPH CLOUDY	NO	YES			NO		NO		BM	
6/28/2025	1130AM	YES	88 W 9 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	89 WSW 8 MPH CLOUDY	NO	YES			NO		NO		EW	
6/29/2025	1130AM	YES	88 SW 8 MPH CLOUDY	NO	YES			NO		NO		EW	
	3pm	YES	90 SW 8 MPH CLOUDY	NO	YES			NO		NO		EW	
6/30/2025	100 AM	YES	85 WSW 7 MPH SUNNY	NO	YES			NO		NO		BM	
	2PM	YES	91 WSW 7 MPH CLOUDY	NO	YES			NO		NO		BM	

Month: July 2025

2025

Plum Point

Dust Control Log

Date	Actively working? ¹		Weather ^{2, 7, 8}	Method(s) Used to Control Dust ³				*Is dust present? ⁴		*Is erosion present? ⁵		Preventative or Corrective Action Taken	Initials
	Yes/No	Temperature range, rainfall data, wind speeds,	Currently Percipitating (Y/N)	Water Truck	Alternative Cover	Other	Yes	No	Yes	No	Examples: Added more water, applied additional alternative cover material,		
7/1/2025	11AM	YES	88 N 7 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	86 N 7 MPH CLOUDY	NO	YES			NO		NO		EW	
7/2/2025	11AM	YES	82 ENE 3 SUNNY	NO	YES			NO		NO		EW	
	2PM	YES	87 NNW 5 MPH SUNNY	NO	YES			NO		NO		EW	
7/3/2025	1130AM	YES	88 N 3 MPH SUNY	NO	YES			NO		NO		EW	
	2PM	YES	90 N 3 SUNNY	NO	YES			NO		NO		EW	
7/4/2025		HOLIDAY		HOLIDAY									
		HOLIDAY		HOLIDAY									
7/5/2025	11AM	YES	89 SSE 1 MPH SUNNY	NO	YES			NO		NO		BM	
	2PM	YES	91 SSW 5 CLOUDY	NO	YES			NO		NO		BM	
7/6/2025	1130 AM	YES	93WSW 7 MPH SUNNY	NO	YES			NO		NO		BM	
	2PM	YES	93 WSW 7 MPH CLOUDY	NO	YES			NO		NO		BM	
7/7/2025	1130 AM	YES	87 SW 6 MPH CLOUDY	NO	YES			NO		NO		BM	
	2PM	YES	89 WSW 6 MPH CLOUDY	NO	YES			NO		NO		EW	
7/8/2025	1130 AM	YES	79 W2W 5 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	83 WSW 5 MPH CLOUDY	NO	YES			NO		NO		EW	
7/9/2025	1130AM	YES	90 SW 6 MPH SUNNY	NO	YES			NO		NO		EW	
	230PM	YES	91 SW6 MPH SUNNY	NO	YES			NO		NO		EW	
7/10/2025	1130AM	YES	89 WSW 10 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	92 WSW9 MPH CLOUDY	NO	YES			NO		NO		EW	
7/11/2025	1130AM	YES	90 SW10 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	92 SW10 MPH CLOUDY	NO	YES			NO		NO		EW	
7/12/2025	1030 AM	YES	88 SW 15MPH SUNNY	NO	YES			NO		NO		EW	
	2PM	YES	90 SW 15 MPH SUNNY	NO	YES			NO		NO		EW	
7/13/2025	1030 AM	YES	83 SW 10 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	88 SW 11 MPH RAIN	YES	NO			NO		NO		EW	
7/14/2025	11AM	YES	86 SW 7 MPH CLOUDY	NO	YES			NO		NO		EW	
	1230 AM	YES	88 SW 9 MPH CLOUDY	NO	YES			NO		NO		EW	
7/15/2025	12PM	YES	89 S 8 MPH CLOUDY	NO	YES			NO		NO		EW	
	130PM	YES	90 S 9 MPH CLOUDY	NO	YES			NO		NO		EW	
7/16/2025	1130AM	YES	91 WSW 7 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	93 SW 8 MPH CLOUDY	NO	YES			NO		NO		EW	
7/17/2025	1130AM	YES	93 SSW 7 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	95 SSW 7 MPH CLOUDY	NO	YES			NO		NO		EW	
7/18/2025	1130 AM	YES	91 SSW 4 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	93 S 6 MPH CLOUDY	NO	YES			NO		NO		EW	
7/19/2025	1130AM	YES	90 SW 10 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	91 SW 10 MPH CLOUDY	NO	YES			NO		NO		EW	
7/20/2025	11AM	YES	89 SW 10 MPH SUNNY	NO	YES			NO		NO		EW	
	2PM	YES	92 SW 11 MPH SUNNY	NO	YES			NO		NO		EW	
7/21/2025	11AM	YES	95 WSW 10 MPH SUNNY	NO	YES			NO		NO		EW	
	430PM	YES	95 WSW 10 MPH SUNNY	NO	YES			NO		NO		EW	
7/22/2025	1130AM	YES	95 W 4 MPH SUNNY	NO	YES			NO		NO		EW	
	2PM	YES	96 W 5 MPH SUNNY	NO	YES			NO		NO		EW	
7/23/2025	1130AM	YES	96 SSE 4 MPH SUNNY	NO	YES			NO		NO		BM	
	130PM	YES	98 SE 4 SUNNY	NO	YES			NO		NO		BM	
7/24/2025	1130AM	YES	95 SE 7 MPH CLOUDY	NO	YES			NO		NO		BM	
	2PM	YES	96 SE 7 MPH CLOUDY	NO	YES			NO		NO		BM	
7/25/2025	1130 AM	YES	96 SSE 8 MPH CLOUDY	NO	YES			NO		NO		BM	
	430PM	YES	94 SSE 8 MPH CLOUDY	NO	YES			NO		NO		BM	
7/26/2025	1130AM	YES	92 SSW 11 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	93 SSW 12 MPH CLOUDY	NO	YES			NO		NO		EW	
7/27/2025	1130AM	YES	93 SSW 10 MPH CLOUDY	NO	YES			NO		NO		BM	
	130 PM	YES	93 SSW 10 MPH CLOUDY	NO	YES			NO		NO		BM	
7/28/2025	1130AM	YES	90 N 9 MPH CLOUDY	NO	YES			NO		NO		EW	
	2PM	YES	93 N 9 MPH CLOUDY	NO	YES			NO		NO		EW	
7/29/2025	1130AM	YES	97 N 7 MPH SUNNY	NO	YES			NO		NO		EW	
	2PM	YES	99 N6 MPH CLOUDY	NO	YES			NO		NO		EW	
7/30/2025	1130 AM	YES	95 NNE 7 MPH CLOUDY	NO	YES			NO		NO		BM	
	2PM	YES	98 NNE 7 MPH CLOUDY	NO	YES			NO		NO		BM	
31-Jul	1130 AM	YES	93 N 9 MPH CLOUDY	NO	YES			NO		NO		BM	
	2PM	YES	96 N 7 MPH CLOUDY	NO	YES			NO		NO		BM	

2025

Plum Point

Dust Control Log

Month: August

Actively working? ¹		Weather ^{2, 7, 8}		Method(s) Used to Control Dust ³				*Is dust present? ⁴		*Is erosion present? ⁵		Preventative or Corrective Action Taken	
Date	Yes/No	Temperature range, rainfall data, wind speeds,	Currently Percipitating (Y/N)	Water Truck	Alternative Cover	Other	Yes	No	Yes	No	Examples: Added more water, applied additional alternative cover material,		Initials
8/1/2025	11AM	YES	78 NNE 10 MPH CLOUDY	NO	YES			NO		NO			EW
	9PM	YES	80 NNE 10 MPH CLOUDY	NO	YES			NO		NO			EW
8/2/2025	10:30 AM	YES	84 NNE 13 MPH SUNNY	NO	YES			NO		NO			EW
	2:00 PM	YES	86 NNE 13 MPH SUNNY	NO	YES			NO		NO			EW
8/3/2025	11:00 AM	YES	79 NNE 6 MPH SUNNY	NO	YES			NO		NO			EW
	2:00 PM	YES	83 NNE 9 MPH SUNNY	NO	YES			NO		NO			EW
8/4/2025	1:30 AM	YES	75 SE 3 MPH SUNNY	NO	YES			NO		NO			EW
	2:00 PM	YES	83 NE 9 MPH SUNNY	NO	YES			NO		NO			EW
8/5/2025	11:00 AM	YES	74 NE 8 MPH CLOUDY	NO	YES			NO		NO			EW
	2:00 PM	YES	94 NE 8 MPH CLOUDY	NO	YES			NO		NO			EW
8/6/2025	11:30 AM	YES	86 SE 1 MPH CLOUDY	NO	YES			NO		NO			EW
	2:00 PM	YES	89 E 3 MPH CLOUDY	NO	YES			NO		NO			EW
8/7/2025	8:30 AM	YES	77 SE 1 MPH SUNNY	NO	YES			NO		NO			EW
	2:00 PM	YES	93 SE 6 MPH SUNNY	NO	YES			NO		NO			EW
8/8/2025	11:30 AM	YES	91 SSW 6 CLOUDY	NO	YES			NO		NO			EW
	2:00 PM	YES	93 S 6 MPH CLOUDY	NO	YES			NO		NO			EW
8/9/2025	7:00 AM	YES	75 SSE 6 MPH CLOUDY	NO	YES			NO		NO			EW
	2:00 PM	YES	93 SSE 6 MPH CLOUDY	NO	YES			NO		NO			EW
8/10/2025	11:30 AM	YES	88 SSE 4 MPH CLOUDY	NO	YES			NO		NO			EW
	2:00 PM	YES	90 SE 4 MPH CLOUDY	NO	YES			NO		NO			EW
8/11/2025	11:30 AM	YES	89 SE 4 MPH CLOUDY	NO	YES			NO		NO			EW
	2:00 PM	YES	90 SE 4 MPH CLOUDY	NO	YES			NO		NO			EW
8/12/2025	10:00 AM	YES	87SSW 6 MPH SUNNY	NO	YES			NO		NO			EW
	1:00 PM	YES	92 SSW 4 MPH SUNNY	NO	YES			NO		NO			EW
8/13/2025	11:30 AM	YES	90 WNW 6MPH CLOUDY	NO	YES			NO		NO			EW
	2:00 PM	YES	93 N W 6 MPH CLOUDY	NO	YES			NO		NO			EW
8/14/2025	11:30 AM	YES	90 WNW 3MPH CLOUDY	NO	YES			NO		NO			EW
	2:00 PM	YES	92 WNW 3 MPH CLOUDY	NO	YES			NO		NO			EW
8/15/2025	10:00 AM	YES	90 SW 2 MPH SUNNY	NO	YES			NO		NO			EW
	1:00 PM	YES	92 SW 2 MPH SUNNY	NO	YES			NO		NO			EW
8/16/2025	11:00 AM	YES	WSW 3 MPH SUNNY	NO	YES			NO		NO			EW
	2:00 PM	YES	94 WSW 3 MPH SUNNY	NO	YES			NO		NO			EW
8/17/2025	10:00 AM	YES	97 NE 5 MPH CLOUDY	NO	YES			NO		NO			EW
	2:00 PM	YES	100 NNE 7 MPH CLOUDY	NO	YES			NO		NO			EW
8/18/2025	11:00	YES	94 E 5 MPH SUNNY	NO	YES			NO		NO			EW
	2:00	YES	97 NE 6 MPH SUNNY	NO	YES			NO		NO			EW
8/19/2025	11:30	YES	99 NNW 7 MPH SUNNY	NO	YES			NO		NO			EW
	2:00	YES	100 NNW 7 MPH SUNNY	NO	YES			NO		NO			EW
8/20/2025	11:30 AM	YES	90 N 9 MPH CLOUDY	NO	YES			NO		NO			EW
	2:00 PM	YES	93 N 11 MPH CLOUDY	NO	YES			NO		NO			EW
8/21/2025	11:30 AM	YES	85 NNE 12 MPH CLOUDY	NO	YES			NO		NO			EW
	2:00 PM	YES	88 NE 11 MPH CLOUDY	NO	YES			NO		NO			EW
8/22/2025	11:00 AM	YES	86 NNE 13 MPH CLOUDY	NO	YES			NO		NO			EW
	1:00 PM	YES	87 NNE 11 MPH CLOUDY	NO	YES			NO		NO			EW
8/23/2025	11:30 AM	YES	87 N 11 MPH SUNNY	NO	YES			NO		NO			EW
	1:00 PM	YES	89 N 11 MPH SUNNY	NO	YES			NO		NO			EW
8/24/2025	11:30 AM	YES	86 nnw 12 mph sunny	NO	YES			NO		NO			EW
	2:00 PM	YES	88 NNW 12 MPH SUNNY	NO	YES			NO		NO			EW
8/25/2025	11:30 AM	YES	78 N 8 MPH SUNNY	NO	YES			NO		NO			EW
	2:30 PM	YES	80 N 8 MPH SUNNY	NO	YES			NO		NO			EW
8/26/2025	8:00 AM	YES	72 NE 12 MPH SUNNY	NO	YES			NO		NO			EW
	1:00 PM	YES	84 NE 12 MPH SUNNY	NO	YES			NO		NO			EW
8/27/2025	11:00 AM	YES	78 E 6 MPH SUNNY	NO	YES			NO		NO			EW
	1:00 PM	YES	81 ENE 7 MPH SUNNY	NO	YES			NO		NO			EW
8/29/2025	1:30 AM	YES	70 ENE 4 MPH SUNNY	NO	YES			NO		NO			EW
	1:00 PM	YES	84 E 7 MPH SUNNY	NO	YES			NO		NO			EW
8/30/2025	11:30 AM	YES	88 NE 8 MPH CLOUDY	NO	YES			NO		NO			EW
	1:30 PM	YES	90 NE 8 MPH CLOUDY	NO	YES			NO		NO			EW
8/31/2025	11:00 AM	YES	81 ENE 7 MPH SUNNY	NO	YES			NO		NO			EW
	1:00 PM	YES	87 NE 10 MPH SUNNY	NO	YES			NO		NO			EW

Month: September

2025

Plum Point

Dust Control Log

Actively working? ¹		Weather ^{2, 7, 8}		Method(s) Used to Control Dust ³				*Is dust present? ⁴		*Is erosion present? ⁵		Preventative or Corrective Action Taken	
Date	Yes/No	Temperature range, rainfall data, wind speeds,	Currently Percipitating (Y/N)	Water Truck	Alternative Cover	Other	Yes	No	Yes	No	Examples: Added more water, applied additional alternative cover material,		
												Initials	
9/1/2025	11AM	YES	79 NE 3 MPH SUNNY	NO				NO		NO		EW	
	9PM	YES	85 NNE 4 MPH SUNNY	NO				NO		NO		EW	
9/2/2025	11:30 AM	YES	87 N 7 MPH SUNNY	NO				NO		NO		EW	
	2:00 PM	YES	89 N 7 MPH SUNNY	NO				NO		NO		EW	
9/3/2025	11:00 AM	YES	83 WSW 6 MPH CLOUDY	NO				NO		NO		EW	
	12:30	YES	83WSW 6 MPH CLOUDY	NO				NO		NO		EW	
	11:30 AM	YES	83 NNW 6 MPH CLOUDY	NO				NO		NO		EW	
	2:00 PM	YES	86 NW 5 MPH CLOUDY	NO				NO		NO		EW	
9/5/2025	11:30 AM	YES	86 NW 6 MPH CLOUDY	NO				NO		NO		EW	
	2:00 PM	YES	89 NNW 7 MPH CLOUDY	NO				NO		NO		EW	
9/6/2025	11:30 AM	YES	68 NE 7 MPH CLOUDY	NO				NO		NO		EW	
	2:00 PM	YES	74 NNE 5 MPH CLOUDY	NO				NO		NO		EW	
9/7/2025	8:30 AM	YES	78 N 10 MPH SUNNY	NO				NO		NO		EW	
	2:00 PM	YES	81 N 10 MPH SUNNY	NO				NO		NO		EW	
9/8/2025	11:30 AM	YES	73 NE 11 MPH SUNNY	NO				NO		NO		EW	
	2:00 PM	YES	78 NE 10 CLOUDY	NO				NO		NO		EW	
9/9/2025	7:00 AM	YES	78 SSE 7 MPH SUNNY	NO				NO		NO		EW	
	2:00 PM	YES	85 SE 6 MPH SUNNY	NO				NO		NO		EW	
9/10/2025	11:30 AM	YES	87 SW 7 MPH CLOUDY	NO				NO		NO		EW	
	2:00 PM	YES	88 W SW 7 CLOUDY	NO				NO		NO		EW	
9/11/2025	11:30 AM	YES	92 W 5 MPH SUNNY	NO				NO		NO		EW	
	2:00 PM	YES	93 NNW 6 MPH SUNNY	NO				NO		NO		EW	
9/12/2025	10:00 AM	YES	87 E 3 MPH SUNNY	NO				NO		NO		EW	
	1:00 PM	YES	94 NNE 3 SUNNY	NO				NO		NO		EW	
9/13/2025	11:30 AM	YES	88 SSW 6 MPH CLOUDY	NO				NO		NO		EW	
	2:00 PM	YES	92 SE 6 MPH CLOUDY	NO				NO		NO		EW	
9/14/2025	11:30 AM	YES	90 WNW 8 MPH SUNNY	NO				NO		NO		EW	
	2:00 PM	YES	94 WNW 6 MPH CLOUDY	NO				NO		NO		EW	
9/15/2025	10:00 AM	YES	89 WNW 5 MPH CLOUDY	NO				NO		NO		EW	
	1:00 PM	YES	91 WNW 5 MPH CLOUDY	NO				NO		NO		EW	
	11:00 AM	YES	90 SSE 3 MPH SUNNY	NO				NO		NO		EW	
9/16/2025	2:00 PM	YES	93 ESE 4 MPH SUNNY	NO				NO		NO		EW	
	10:00 AM	YES	92 N 6 MPH CLOUDY	NO				NO		NO		EW	
9/17/2025	2:00 PM	YES	95 N 6 MPH CLOUDY	NO				NO		NO		EW	
9/18/2025	11:00	YES	89 SW 5 MPH SUNNY	NO				NO		NO		EW	
	2:00	YES	95 SW 5 MPH SUNNY	NO				NO		NO		EW	
9/19/2025	11:30	YES	79 WNW 11 MPH CLOUDY	NO				NO		NO		EW	
	2:00	YES	84 WNW 10 MPH CLOUDY	NO				NO		NO		EW	
9/20/2025	11:30 AM	YES	83 SW 3 MPH CLOUDY	NO				NO		NO		EW	
	2:00 PM	YES	89 SW 8 MPH CLOUDY	NO				NO		NO		EW	
9/21/2025	11:30 AM	YES	85 S 8 MPH SUNNY	NO				NO		NO		EW	
	2:00 PM	YES	88 SW 8 MPH SUNNY	NO				NO		NO		EW	
9/22/2025	11:00 AM	YES	77 SSW 9 MPH RAIN	NO				NO		NO		EW	
	1:00 PM	YES	80 SW 9 MPH RAIN	NO				NO		NO		EW	
9/23/2025	11:30 AM	YES	84 SW 9 MPH CLOUDY	NO				NO		NO		EW	
	1:00 PM	YES	86 SW 6 MPH CLOUDY	NO				NO		NO		EW	
9/24/2025	11:30 AM	YES	76 SW 8 MPH CLOUDY	NO				NO		NO		EW	
	2:00 PM	YES	77 SW 7 MPH CLOUDY	NO				NO		NO		EW	
9/25/2025	11:30 AM	YES	74 N 11 MPH CLOUDY	NO				NO		NO		EW	
	2:30 PM	YES	76 N 11 MPH CLOUDY	NO				NO		NO		EW	
9/26/2025	11:00 AM	YES	80 N 7 MPH CLOUDY	NO				NO		NO		EW	
	2:00 PM	YES	82 N 7 MPH CLOUDY	NO				NO		NO		EW	
9/27/2025	11:00 AM	YES	82 NNW 6 CLOUDY	NO				NO		NO		EW	
	1:00 PM	YES	83 N 7 MPH CLOUDY	NO				NO		NO		EW	
9/28/2025	11:30 AM	YES	83 NE 6 MPH SUNNY	NO				NO		NO		EW	
	1:00 PM	YES	86 NE 7 MPH SUNNY	NO				NO		NO		EW	
9/29/2025	11:30 AM	YES	79 NE 7 MPH SUNNY	NO				NO		NO		EW	
	1:00 PM	YES	85 NE 9 MPH SUNNY	NO				NO		NO		EW	
9/30/2025	10:00 AM	YES	76 ENE 4 MPH SUNNY	NO				NO		NO		EW	
	1:00 PM	YES	86 NE 6 MPH SUNNY	NO				NO		NO		EW	

2025

Plum Point

Dust Control Log

Month: OCTOBER

Actively working? ¹		Weather ^{2, 7, 8}		Method(s) Used to Control Dust ³				*Is dust present? ⁴		*Is erosion present? ⁵		Preventative or Corrective Action Taken	
Date	Yes/No	Temperature range, rainfall data, wind speeds,	Currently Percipitating (Y/N)	Water Truck	Alternative Cover	Other	Yes	No	Yes	No	Examples: Added more water, applied additional alternative cover material,		
												Initials	
10/1/2025	9:00AM	YES	71 NE 4 MPH SUNNY	NO	YES			NO		NO		EW	
	2:00 PM	YES	88 ENE 7 MPH SUNNY	NO	YES			NO		NO		EW	
10/2/2025	10:00 AM	YES	82 ESE 7 MPH SUNNY	NO	YES			NO		NO		EW	
	1:00 PM	YES	88 ESE 7 MPH SUNNY	NO	YES			NO		NO		EW	
10/3/2025	7:30	YES	78 ESE 7 MPH SUNNY	NO	YES			NO		NO		EW	
	10:00	YES	85 SE 3 MPH SUNNY	NO	YES			NO		NO		EW	
10/4/2025	11:00 AM	YES	78 SE 7 SUNNY	NO	YES			NO		NO		EW	
	2:00 PM	YES	83 SE 9 MPH CLOUDY	NO	YES			NO		NO		EW	
10/5/2025	10:00 AM	YES	73 SE 10 MPH CLOUDY	NO	YES			NO		NO		EW	
	1:00 PM	YES	84 SE 9 MPH CLOUDY	NO	YES			NO		NO		EW	
10/6/2025	11:30 AM	YES	72 E 5 MPH RAIN	NO	NO			NO		NO		EW	
	2:00 PM	YES	72 E 5 MPH RAIN	NO	NO			NO		NO		EW	
10/7/2025	11:30AM	YES	76 NNW 13 MPH CLOUDY	NO	YES			NO		NO		EW	
	2:00 PM	YES	79 NNW 9 MPH CLOUDY	NO	YES			NO		NO		EW	
10/8/2025	10:00 AM	YES	67 NNE 13 MPH CLOUDY	NO	YES			NO		NO		EW	
	2:00 PM	YES	73 NNE 12 MPH SUNNY	NO	YES			NO		NO		EW	
10/9/2025	11:05 AM	YES	69 NNE 9 MPH SUNNY	NO	YES			NO		NO		EW	
	2:00 PM	YES	74 NE 8 MPH SUNNY	NO	YES			NO		NO		EW	
10/10/2025	11:30 AM	YES	70 NE 12 MPH SUNNY	NO	YES			NO		NO		EW	
	2:00 PM	YES	74 NE 12 MPH SUNNY	NO	YES			NO		NO		EW	
10/11/2025	11:30 AM	YES	68 ENE 3 MPH SUNNY	NO	YES			NO		NO		EW	
	2:00 PM	YES	75 ENE 3 MPH SUNNY	NO	YES			NO		NO		EW	
10/12/2025	10:00 AM	YES	73 ENE 3 MPH SUNNY	NO	YES			NO		NO		EW	
	1:00 PM	YES	78 ENE 4 MPH SUNNY	NO	YES			NO		NO		EW	
10/13/2025	11:30 AM	YES	78 S 2 MPH SUNNY	NO	YES			NO		NO		EW	
	2:00 PM	YES	80 SE 2 MPH SUNNY	NO	YES			NO		NO		EW	
10/14/2025	10:00 AM	YES	74 NE 6 MPH SUNNY	NO	YES			NO		NO		EW	
	2:00 PM	YES	80 NNE 9 SUNNY	NO	YES			NO		NO		EW	
10/15/2025	9:00	YES	61 ENE 4 SUNNY	NO	YES			NO		NO		EW	
	2:00PM	YES	81 ENE 10 MPH SUNNY	NO	YES			NO		NO		EW	
10/16/2025	7:30	YES	63 ENE 4 SUNNY	NO	YES			NO		NO		EW	
	2:00 PM	YES	84 E 8 MPH SUNNY	NO	YES			NO		NO		EW	
10/17/2025	10:00 AM	YES	74 S 6 MPH SUNNY	NO	YES			NO		NO		EW	
	2:00 PM	YES	82 SSW 6 CLOUDY	NO	YES			NO		NO		EW	
10/18/2025	11:00	YES	82 SSW 16 MPH SUNNY	NO	YES			NO		NO		EW	
	2:00	YES	84 SSW 16 MPH CLOUDS	NO	YES			NO		NO		EW	
10/19/2025	9:00 AM	YES	58 NW 16 SUNNY	NO	YES			NO		NO		EW	
	2:00	YES	67 NW 14 MPH SUNNY	NO	YES			NO		NO		EW	
10/20/2025	11:30 AM	YES	66 S 13 MPH SUNNY	NO	YES			NO		NO		EW	
	2:00 PM	YES	72 SSW 15 SUNNY	NO	YES			NO		NO		EW	
10/21/2025	11:30 AM	YES	68 NW 8 SUNNY	NO	YES			NO		NO		EW	
	2:00 PM	YES	74 WNW 14 MPH SUNNY	NO	YES			NO		NO		EW	
10/22/2025	8:00 AM	YES	47 S W SUNNY	NO	NO			NO		NO		EW	
	2:00 PM	YES	71 WNW 8 SUNNY	NO	NO			NO		NO		EW	
10/23/2025	7:30 AM	YES	57 SW 5 MPH SUNNY	NO	YES			NO		NO		EW	
	1:00 PM	YES	75 SW 9 MPH SUNNY	NO	YES			NO		NO		EW	
10/24/2025	11:30 AM	YES	49 W 1 MPH CLEAR	NO	YES			NO		NO		EW	
	2:00 PM	YES	75 W 1 MPH CLEAR	NO	YES			NO		NO		EW	
10/25/2025	11:30 AM	YES	62 SSE 9 MPH CLOUDS	NO	YES			NO		NO		EW	
	2:30 PM	YES	67 SSE 9 MPH CLOUDS	NO	YES			NO		NO		EW	
10/26/2025	11:30 AM	YES	56 ESE 10 MPH RAIN	NO	NO			NO		NO		EW	
	2:00 PM	YES	57 ESE 8 MPH RAIN	NO	NO			NO		NO		EW	
10/27/2025	11:00 AM	YES	57 NNW 2 MPH CLOUDY	NO	YES			NO		NO		EW	
	1:00 PM	YES	59 NNE 4 CLOUDY	NO	YES			NO		NO		EW	
10/28/2025	11:30 AM	YES	55 ENE 1 MPH RAIN	NO	NO			NO		NO		EW	
	1:00 PM	YES	60 ENE 2 MPH RAIN	NO	NO			NO		NO		EW	
10/29/2025	11:30 AM	YES	50 W 11 MPH RAIN	NO	NO			NO		NO		EW	
	1:30PM	YES	52 NW 10 MPH RAIN	NO	NO			NO		NO		EW	
10/30/2025	10:00 AM	YES	58 NNW 10 MPH CLOUDY	NO	NO			NO		NO		EW	
	1:00 PM	YES	60 NNW 10 MPH CLOUDY	NO	YES			NO		NO		EW	
10/31/2025	1:00 AM	YES	40 SW 6 MPH CLEAR	NO	YES			NO		NO		EW	
	2:00 PM	YES	56 WSW 6 CLEAR	NO	YES			NO		NO		EW	

ATTACHMENT 2
LANDFILL INSPECTION FORMS

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 12-3-2024	Time: 1:30 PM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		12400205.4
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		12-3-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 12-10-2024	Time: 12:30 PM	Weather: over cast	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		12400205.4
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		12-10-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 12-17-2024	Time: 9:30 AM	Weather: over cast	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		12400205.4
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		12-17-2024
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 12-24-2024	Time: 8:30 AM	Weather: over cast	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		1299196.6
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum Print Name of Inspector Completing Form	Bryan Mangrum Signature		12-24-2024 Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 12-31-2024	Time: 9:30 AM	Weather: overcast	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		13857817.2
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		12-31-2024
Print Name of Inspector Completing Form	Signature		Date

PLUM POINT ENERGY STATION CLASS 3N LANDFILL

Operations Inspection Form

Inspection Completed By: Bryan Mangrum Date: 12/24/2024

DESCRIPTION	INSPECTION INTERVAL	PASS	FAIL*
Surface Water System			
Drainage Ditches & Culverts	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Berms	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leachate Collection System			
Pumps	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Totalizers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Transmission/Recirculation Systems	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage Pond	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Landfill Final Cover System			
Erosion	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ponded Water	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Settlement	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vegetation	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Facility Roads			
Safety	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Routing	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Condition	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mud	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Passable Width	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency Response Equipment			
Fire Extinguisher	Check Quarterly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Test Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Communication System	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
List of Emergency Phone Numbers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
First Aid Kits	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Waste Cell and Plant Grid Markers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Survey Markers	Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring Wells	Semi-Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>

*Explain failure on back of form

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 1-7-2025	Time: 9:30 AM	Weather: cloudy/ spitting snow	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		14336091.2
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		1-7-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 1-14-2025	Time: 10:00 AM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		14660512.2
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum Print Name of Inspector Completing Form	Bryan Mangrum Signature		1-14-2025 Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 1-21-25	Time: 1:00 PM	Weather: clear / below freezing temps	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		14660512.2
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		1-21-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 1-28-25	Time: 9:00 AM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		14660512.2
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		1-28-2025
Print Name of Inspector Completing Form	Signature		Date

PLUM POINT ENERGY STATION CLASS 3N LANDFILL

Operations Inspection Form

Inspection Completed By: Bryan Mangrum Date: 1/29/2025

DESCRIPTION	INSPECTION INTERVAL	PASS	FAIL*
Surface Water System			
Drainage Ditches & Culverts	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Berms	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leachate Collection System			
Pumps	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Totalizers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Transmission/Recirculation Systems	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage Pond	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Landfill Final Cover System			
Erosion	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ponded Water	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Settlement	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vegetation	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Facility Roads			
Safety	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Routing	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Condition	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mud	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Passable Width	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency Response Equipment			
Fire Extinguisher	Check Quarterly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Test Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Communication System	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
List of Emergency Phone Numbers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
First Aid Kits	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Waste Cell and Plant Grid Markers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Survey Markers	Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring Wells	Semi-Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>

*Explain failure on back of form

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 2-4-2025	Time: 2: 30 PM	Weather: overcast	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		Levels normal
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		15137640.4
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		2-4-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 2-11-2025	Time: 12: 30 PM	Weather: Rain	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		Repaired haul Rd up to cell 3
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		Levels normal cell 1 and 3
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		15918852.7
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		Repaired RD up to cell 3
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		2-11-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 2-18-2025	Time: 8: 00 AM	Weather: overcast/cold windy	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		Levels normal cell 1&3
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		16628333.5
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		2-18-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 2-25-2025	Time: 10: 00 AM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		Levels normal cell 1&3
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		2-25-2025
Print Name of Inspector Completing Form	Signature		Date

PLUM POINT ENERGY STATION CLASS 3N LANDFILL

Operations Inspection Form

Inspection Completed By: Bryan Mangrum Date: 2/25/2025

DESCRIPTION	INSPECTION INTERVAL	PASS	FAIL*
Surface Water System			
Drainage Ditches & Culverts	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Berms	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leachate Collection System			
Pumps	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Totalizers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Transmission/Recirculation Systems	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage Pond	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Landfill Final Cover System			
Erosion	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ponded Water	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Settlement	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vegetation	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Facility Roads			
Safety	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Routing	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Condition	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mud	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Passable Width	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency Response Equipment			
Fire Extinguisher	Check Quarterly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Test Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Communication System	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
List of Emergency Phone Numbers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
First Aid Kits	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Waste Cell and Plant Grid Markers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Survey Markers	Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring Wells	Semi-Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>

*Explain failure on back of form

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 3-4-2025	Time: 9:00 AM	Weather: rain/wind	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		Levels normal cell 1&3
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		3-4-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 3-11-2025	Time: 9:00 AM	Weather: sunny/ clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		Levels normal cell 1&3 / cell 3 making good progress
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		19529314.6
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		3-11-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 3-18-2025	Time: 10:00 AM	Weather: sunny/ clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		Levels normal cell 1&3 / cell 2 making good progress
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		20094191.6
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		3-18-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 3-25-2025	Time: 2:30 PM	Weather: sunny/ clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		Levels normal cell 1&3
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		Pond level still high
3h. Leachate Totalizer Flow Reading in gallons	x		20573273.2
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum Print Name of Inspector Completing Form	Bryan Mangrum Signature		3-25-2025 Date

PLUM POINT ENERGY STATION CLASS 3N LANDFILL

Operations Inspection Form

Inspection Completed By: Bryan Mangrum Date: 3/26/2025

DESCRIPTION	INSPECTION INTERVAL	PASS	FAIL*
Surface Water System			
Drainage Ditches & Culverts	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Berms	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leachate Collection System			
Pumps	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Totalizers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Transmission/Recirculation Systems	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage Pond	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Landfill Final Cover System			
Erosion	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ponded Water	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Settlement	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vegetation	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Facility Roads			
Safety	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Routing	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Condition	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mud	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Passable Width	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency Response Equipment			
Fire Extinguisher	Check Quarterly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Test Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Communication System	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
List of Emergency Phone Numbers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
First Aid Kits	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Waste Cell and Plant Grid Markers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Survey Markers	Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring Wells	Semi-Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>

*Explain failure on back of form

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 4-1-2025	Time: 1:30 PM	Weather: sunny/ clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		Levels normal cell 1&3
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		Pond level still high
3h. Leachate Totalizer Flow Reading in gallons	x		20995616.4
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum Print Name of Inspector Completing Form	Bryan Mangrum Signature		4-1-2025 Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 4-8-2025	Time: 9:00 AM	Weather: sunny/ clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		Levels normal cell 1&3
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		Pond level still high
3h. Leachate Totalizer Flow Reading in gallons	x		No power to read out
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		4-8-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 4-15-2025	Time: 2:00 PM	Weather: sunny/ clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		Levels normal cell 1&3
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		Pond level still high
3h. Leachate Totalizer Flow Reading in gallons	x		No power to read out
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		4-15-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 4-22-2025	Time: 1:00 PM	Weather: sunny/ clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		Levels normal cell 1&3
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		No power to read out
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		4-22-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 4-29-2025	Time: 9:00 AM	Weather: sunny/ clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		Levels normal cell 1&3 started on pumping cell 2
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		Pond still high
3h. Leachate Totalizer Flow Reading in gallons	x		No power to read out
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum Print Name of Inspector Completing Form	Bryan Mangrum Signature		4-29-2025 Date

PLUM POINT ENERGY STATION CLASS 3N LANDFILL

Operations Inspection Form

Inspection Completed By: Bryan Mangrum Date: 4/29/2025

DESCRIPTION	INSPECTION INTERVAL	PASS	FAIL*
Surface Water System			
Drainage Ditches & Culverts	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Berms	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leachate Collection System			
Pumps	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Totalizers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Transmission/Recirculation Systems	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage Pond	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Landfill Final Cover System			
Erosion	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ponded Water	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Settlement	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vegetation	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Facility Roads			
Safety	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Routing	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Condition	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mud	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Passable Width	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency Response Equipment			
Fire Extinguisher	Check Quarterly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Test Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Communication System	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
List of Emergency Phone Numbers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
First Aid Kits	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Waste Cell and Plant Grid Markers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Survey Markers	Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring Wells	Semi-Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>

*Explain failure on back of form

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 5-6-2025	Time: 9:00 AM	Weather: sunny/ clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		Levels normal cell 1&3 cell 2 off
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		Pond still high
3h. Leachate Totalizer Flow Reading in gallons	x		No power to read out
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum Print Name of Inspector Completing Form	Bryan Mangrum Signature		5-6-2025 Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 5-13-2025	Time: 10:00 AM	Weather: over cast light rain	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		Levels normal cell 1&3 cell 2 pumping
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		No power to read out
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		5-13-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 5-20-2025	Time: 9:00 AM	Weather: over cast scattered rain / afternoon storms	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		Levels normal cell 1&3 cell 2 pumping
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		21742772.4
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		5-20-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 5-27-2025	Time: 8:00 AM	Weather: overcast scattered rain	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		Cell 3 pumping continually
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		22361228.4
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		Placed 4 loads of slag today
6b. Condition of active disposal area access road	x		good
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		5-27-2025
Print Name of Inspector Completing Form	Signature		Date

PLUM POINT ENERGY STATION CLASS 3N LANDFILL

Operations Inspection Form

Inspection Completed By: Bryan Mangrum Date: 5/27/2025

DESCRIPTION	INSPECTION INTERVAL	PASS	FAIL*
Surface Water System			
Drainage Ditches & Culverts	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Berms	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leachate Collection System			
Pumps	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Totalizers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Transmission/Recirculation Systems	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage Pond	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Landfill Final Cover System			
Erosion	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ponded Water	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Settlement	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vegetation	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Facility Roads			
Safety	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Routing	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Condition	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mud	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Passable Width	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency Response Equipment			
Fire Extinguisher	Check Quarterly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Test Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Communication System	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
List of Emergency Phone Numbers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
First Aid Kits	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Waste Cell and Plant Grid Markers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Survey Markers	Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring Wells	Semi-Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>

*Explain failure on back of form

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 6-3-2025	Time: 12:00 pm	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		Cell 3 still pumping continually
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		23102538.6
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		6-3-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 6-10-2025	Time: 2:00 pm	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		Cell 3 not pumping reading 4.4
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		23640450.6 gal per minute reading 0.0
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		6-10-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 6-17-2025	Time: 2:00 pm	Weather: overcast	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		Cell 3 high level light is out not working
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		24386556.7
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		6-17-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 6-24-2025	Time: 10:00 AM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		Cell 3 high level light is out not working
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		24915293.0
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		6-24-2025
Print Name of Inspector Completing Form	Signature		Date

PLUM POINT ENERGY STATION CLASS 3N LANDFILL

Operations Inspection Form

Inspection Completed By: Bryan Mangrum Date: 6/17/2025

DESCRIPTION	INSPECTION INTERVAL	PASS	FAIL*
Surface Water System			
Drainage Ditches & Culverts	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Berms	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leachate Collection System			
Pumps	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Totalizers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Transmission/Recirculation Systems	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage Pond	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Landfill Final Cover System			
Erosion	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ponded Water	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Settlement	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vegetation	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Facility Roads			
Safety	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Routing	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Condition	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mud	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Passable Width	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency Response Equipment			
Fire Extinguisher	Check Quarterly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Test Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Communication System	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
List of Emergency Phone Numbers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
First Aid Kits	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Waste Cell and Plant Grid Markers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Survey Markers	Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring Wells	Semi-Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>

*Explain failure on back of form

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 7-1-2025	Time: 1:30 PM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		Cell 3 high level light is out not working
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		25674385.2
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		7-1-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 7-8-2025	Time: 8:30 AM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		26576275.4
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		7-8-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 7-15-2025	Time: 2:30 PM	Weather: clear/ and hazey	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		Cell 3 still malfunctioning
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		27505860.0
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		7-15-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 7-22-2025	Time: 9:30 AM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		Cell 3 still malfunctioning
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		28414509.7
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum Print Name of Inspector Completing Form	Bryan Mangrum Signature		7-22-2025 Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 7-29-2025	Time: 8:30 AM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		293227944.8
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		7-22-2025
Print Name of Inspector Completing Form	Signature		Date

PLUM POINT ENERGY STATION CLASS 3N LANDFILL

Operations Inspection Form

Inspection Completed By: Bryan Mangrum Date: 7/29/2025

DESCRIPTION	INSPECTION INTERVAL	PASS	FAIL*
Surface Water System			
Drainage Ditches & Culverts	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Berms	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leachate Collection System			
Pumps	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Totalizers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Transmission/Recirculation Systems	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage Pond	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Landfill Final Cover System			
Erosion	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ponded Water	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Settlement	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vegetation	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Facility Roads			
Safety	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Routing	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Condition	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mud	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Passable Width	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency Response Equipment			
Fire Extinguisher	Check Quarterly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Test Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Communication System	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
List of Emergency Phone Numbers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
First Aid Kits	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Waste Cell and Plant Grid Markers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Survey Markers	Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring Wells	Semi-Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>

*Explain failure on back of form

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 8-05-2025	Time: 8:30 AM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		29563798.9
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		8-05-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 8-12-2025	Time: 8:00 AM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		29563798.9
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		8-12-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 8-19-2025	Time: 8:00 AM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		29563798.9
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		8-19-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 8-26-2025	Time: 10:00 AM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		29563798.9
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		8-26-2025
Print Name of Inspector Completing Form	Signature		Date

PLUM POINT ENERGY STATION CLASS 3N LANDFILL

Operations Inspection Form

Inspection Completed By: Bryan Mangrum Date: 8/26/2025

DESCRIPTION	INSPECTION INTERVAL	PASS	FAIL*
Surface Water System			
Drainage Ditches & Culverts	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Berms	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leachate Collection System			
Pumps	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Totalizers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Transmission/Recirculation Systems	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage Pond	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Landfill Final Cover System			
Erosion	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ponded Water	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Settlement	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vegetation	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Facility Roads			
Safety	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Routing	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Condition	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mud	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Passable Width	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency Response Equipment			
Fire Extinguisher	Check Quarterly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Test Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Communication System	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
List of Emergency Phone Numbers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
First Aid Kits	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Waste Cell and Plant Grid Markers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Survey Markers	Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring Wells	Semi-Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>

*Explain failure on back of form

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 9-2-2025	Time: 10:00 AM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		29563798.9
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		9-2-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 9-9-2025	Time: 1:00 PM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		29563798.9
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		9-9-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 9-16-2025	Time: 10:00 AM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		29563798.9
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		9-16-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 9-23-2025	Time: 8:00 AM	Weather: overcast storm threats	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		29563798.9
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		9-23-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 9-30-2025	Time: 10:00 AM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		30576545.2
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		9-20-2025
Print Name of Inspector Completing Form	Signature		Date

PLUM POINT ENERGY STATION CLASS 3N LANDFILL

Operations Inspection Form

Inspection Completed By: Bryan Mangrum Date: 9/22/2025

DESCRIPTION	INSPECTION INTERVAL	PASS	FAIL*
Surface Water System			
Drainage Ditches & Culverts	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Berms	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leachate Collection System			
Pumps	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Totalizers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Transmission/Recirculation Systems	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage Pond	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Landfill Final Cover System			
Erosion	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ponded Water	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Settlement	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vegetation	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Facility Roads			
Safety	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Routing	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Condition	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mud	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Passable Width	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency Response Equipment			
Fire Extinguisher	Check Quarterly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Test Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Communication System	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
List of Emergency Phone Numbers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
First Aid Kits	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Waste Cell and Plant Grid Markers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Survey Markers	Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring Wells	Semi-Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>

*Explain failure on back of form

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 10-7-2025	Time: 10:00 AM	Weather: overcast	
Inspection Representatives			
Charah: Eddie Wamble			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		31741759.1
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Eddie Wamble	Eddie Wamble		10-7--2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 10-14-2025	Time: 10:00 AM	Weather: sunny/ clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		32591800.4
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum Print Name of Inspector Completing Form	Bryan Mangrum Signature		10-14-2025 Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 10-21-2025	Time: 8:30 AM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		33096734.7
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		10-21-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 10-28-2025	Time: 10:30 AM	Weather: cloudy	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		33608393.1
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		10-28-2025
Print Name of Inspector Completing Form	Signature		Date

PLUM POINT ENERGY STATION CLASS 3N LANDFILL

Operations Inspection Form

Inspection Completed By: Bryan Mangrum Date: 10/14/2025

DESCRIPTION	INSPECTION INTERVAL	PASS	FAIL*
Surface Water System			
Drainage Ditches & Culverts	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Berms	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leachate Collection System			
Pumps	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Totalizers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Transmission/Recirculation Systems	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage Pond	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Landfill Final Cover System			
Erosion	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ponded Water	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Settlement	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vegetation	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Facility Roads			
Safety	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Routing	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Condition	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mud	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Passable Width	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency Response Equipment			
Fire Extinguisher	Check Quarterly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Test Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Communication System	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
List of Emergency Phone Numbers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
First Aid Kits	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Waste Cell and Plant Grid Markers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Survey Markers	Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring Wells	Semi-Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>

*Explain failure on back of form

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 11-4-2025	Time: 1:00 PM	Weather: clear	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		33997058.9
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		11-4-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 11-11-2025	Time: 9:00 AM	Weather: clear	
Inspection Representatives			
Charah: Eddie Wamble			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		33997058.9
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Eddie Wamble	Eddie Wamble		11-11-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 11-18-2025	Time: 2:00 PM	Weather: overcast	
Inspection Representatives			
Charah: Eddie Wamble			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		33997058.9
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum	Bryan Mangrum		11-18-2025
Print Name of Inspector Completing Form	Signature		Date

**PLUM POINT SERVICES COMPANY CLASS 3N LANDFILL
WEEKLY LANDFILL INSPECTION FORM**

Facility Name: Plum Point Energy Station, Class 3N Landfill			
Facility Address: 2732 South County Road 623, Osceola, AR 72370			
Date: 11-25-2025	Time: 1:00 PM	Weather: overcast / rain	
Inspection Representatives			
Charah: Bryan Mangrum			
Others:			
Weekly Inspection Observations			
	Acceptable	Needs Improvement	Comments (See page 2 for Additional Comments)
1. General Operating Issues			
1a. General Stability of landfill slopes	x		
1b. Condition of exposed waste slopes	x		
1c. Condition of exposed waste grading	x		
1d. Signs of erosion or washouts	x		
1e. Signs of leachate seeps	x		
1g. Condition of landfill signage	x		
2. Cover System			
2a. Condition of interim cover	x		
2b. Condition of final cover	N/A		
2c. Condition of vegetation	x		
2d. Condition of erosion control devices	x		
3. Leachate Collection and Storage System			
3a. Condition of leachate pumps	x		
3b. Condition of leachate control panels	x		
3c. Status of leachate levels in disposal cells	x		
3d. Condition of leachate collection piping	x		
3e. Condition of cleanouts and headwalls	x		
3f. Condition of leachate transmission piping	x		
3g. Condition of leachate storage system	x		
3h. Leachate Totalizer Flow Reading in gallons	x		33997058.9
4. Stormwater Control Facilities			
4a. Condition of culverts	x		
4b. Condition of ditches	x		
4c. Condition of Diversion Berms	x		
4d. Condition of letdowns	N/A		
4e. Condition of stormwater ponds	x		
5. Groundwater Monitoring Wells			
5a. Condition of well casing and locks	x		
5b. Condition of well pads and pipe bollards	x		
5c. Access to wells	x		
6. Landfill Access Road			
6a. Condition of main access road	x		
6b. Condition of active disposal area access road	x		
6c. Acceptable dust control measures	x		
7. Other items			
7a.			
7b.			
Bryan Mangrum Print Name of Inspector Completing Form	Bryan Mangrum Signature		11-25-2025 Date

PLUM POINT ENERGY STATION CLASS 3N LANDFILL

Operations Inspection Form

Inspection Completed By: Bryan Mangrum Date: 11/25/2025

DESCRIPTION	INSPECTION INTERVAL	PASS	FAIL*
Surface Water System			
Drainage Ditches & Culverts	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Berms	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Leachate Collection System			
Pumps	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Totalizers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Transmission/Recirculation Systems	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage Pond	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Landfill Final Cover System			
Erosion	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ponded Water	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Settlement	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vegetation	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Facility Roads			
Safety	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Routing	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Condition	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mud	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Passable Width	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Emergency Response Equipment			
Fire Extinguisher	Check Quarterly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Test Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Communication System	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
List of Emergency Phone Numbers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
First Aid Kits	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Waste Cell and Plant Grid Markers	Monthly	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Survey Markers	Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring Wells	Semi-Annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>

*Explain failure on back of form

ATTACHMENT 3
LANDFILL INSPECTION PHOTOS



Photo 1. Water truck staged in shop parking lot.



Photo 2. Main haul road to landfill looking West with landfill in the



Photo 3. Active working face, bottom ash with chimney drain looking West (Cell 2).



Photo 4. Open disposal area, Cell 2.



Photo 5. Typical perimeter side slope intermediate cover and vegetation.