HAZARD POTENTIAL CLASSIFICATION ASSESSMENT REPORT ASH PONDS 1N AND 1S WILL COUNTY STATION SEPTEMBER 2021

This initial Hazard Potential Classification Assessment Report has been prepared pursuant to the coal combustion residuals (CCR) rule codified in Title 35 of the Illinois Administrative Code, Section 845.440(a) effective as of April 21, 2021 for Ash Ponds 1N and 1S at Will County Station in Romeoville, Illinois (Station). The purpose of this project is to perform the hazard potential classification assessment by a licensed professional engineer to document the hazard potential classification as either a Class 1 or a Class 2 surface impoundment including the basis for the determination. The site is a coal-fired power station owned and operated by Midwest Generation, LLC (Midwest Generation).

1.0 SUMMARY

The following sections provide a description of physical and operational features followed by an evaluation of the potential failure scenarios of the Ponds 1N and 1S. Based on the results of the analyses provided in this report, Ponds 1N and 1S are classified as a Class 2 CCR surface impoundment because their failure would not result in probable loss of life but could result in potential economic and environmental damages.

2.0 **REGULATION REQUIREMENTS**

According to Section 845.120 of the CCR regulations:

- "Hazard potential classification" means the possible adverse incremental consequences that result from the release of water or stored contents due to failure of the diked CCR surface impoundment or mis-operation of the diked CCR surface impoundment or its appurtenances. The hazardous potential classifications include Class 1 and Class 2, defined as follows:
- Class 1 CCR surface impoundment means a diked surface impoundment where failure or mis-operation will probably cause loss of human life.
- Class 2 CCR surface impoundment means a diked surface impoundment where failure or mis-operation results in no probable loss of human life, but can cause economic loss, environmental damage, disruption of lifeline facilities, or impact other concerns.

3.0 SITE PLAN

Due to geographic constraints, the watershed area for the site is limited. Ponds 1N and 1S can be identified as well as important building and other surface impoundments on the site plan attached as Figure 1. The ponds are located along the eastern banks of the Des Plaines River and west of an electrical substation area.

The information for the ponds was obtained through available construction documents. From these documents, it was determined the ponds were constructed with elevated embankments surrounding the ponds, so run-on into the ponds is limited to the embankment's crests. Light detection and ranging (LiDAR) information for the impoundment breach modeling was obtained through Will County GIS Data Services. The capacity and embankment height of the ponds are shown in Table 1 below.

	Pond 1N	Pond 1S	
Estimated Capacity	14.06 acre-ft	12.63 acre-ft	
Estimated Maximum Depth	8 ft	8 ft	

 Table 1: Estimated Capacity and Maximum Depth

4.0 POND FAILURE IMPACT EVALUATION

To classify the hazard potential of the ponds, impacts of potential failures must be evaluated. Due to the proximity of the ponds to the Des Plaines River on the western side, a failure of the western embankment(s) of the pond(s) could result in potential economic and environmental damages.

The next step is to evaluate the potential loss of life due to failure or mis-operation. Occupied buildings, including the main power block, are located over 800 feet southeast of the ponds; no occupied buildings are located north or south of the ponds. Detailed modeling discussed in Section 5.0 was used to assess the impact on human life of a potential eastern embankment breach on the surrounding eastern buildings.

5.0 EASTERN EMBANKMENT FAILURE MODELING

Pond 1N and 1S were both analyzed for breach scenarios associated with failure of the eastern pond embankments while containing maximum storage with no rainfall event associated. No rainfall event was necessary as the study was to show the effects of a maximum storage breach. The ponds were breached using United States Army Corps of Engineers (USACE) Hydrologic Engineering Center's Hydrologic Modeling System (HEC-HMS) to generate flows. The resulting flood was routed in USACE Hydrologic Engineering Center's River Analysis System (HEC-RAS) to show the effects the breach would have on the site.

The hydrologic modeling process selected by Civil & Environmental Consultants, Inc. (CEC) utilizes the USACE HEC-HMS software to perform the breach analyses. HEC-HMS version 4.8 was used to simulate the impoundment breach hydrographs for Ponds 1N and 1S.

The hydraulic analysis follows standard engineering practices and utilizes GeoHECRAS which is an AutoCAD, Micro Station, and ESRI ArcGIS compatible interactive two-dimensional and threedimensional graphical user interface data wrapper to the USACE HEC-RAS software. GeoHECRAS was developed by Civil Geo, Inc. and performs one-dimensional and two-dimensional hydraulic analyses using the HEC-RAS v5.0.7 engine. Hydrographs were developed in HEC-HMS and were then routed with two-dimensional GeoHECRAS functions.

LiDAR elevation data from Will County GIS Data Services, dated 2014, served as the basis of the terrain model for the entire study area. Two-dimensional surface mesh was created in GeoHECRAS to capture the elevation data in the terrain underneath for the NRG power station located between the Des-Plaines and the shipping canal. A hexagonal mesh of 50-foot grid sizes was selected as the final two-dimensional geometry of the two-dimensional model area.

Manning's 'n' values for the unsteady flow analysis were estimated from a combination of aerial imagery, National Land Cover Database land cover data, and engineering judgment. It was determined for this analysis a general manning's 'n' of 0.06 would be used for the site.

The minimum flow at the upstream ends of the analysis was set at 0 cubic feet per second. Ponds 1N and 1S were set to the normal pool elevation of 590.5 feet as the starting elevation for the simulations.

As a part of a breach evaluation, CEC performed a drawdown calculation to determine if Ponds 1N and 1S acted as a dynamic breach or level pool breach. By performing this calculation, CEC was able to determine what program to recreate the breach in (dynamic routing requires HEC-RAS, level pool can be performed in HEC-HMS). These calculations also gave us the selected breach width (BR) and time to failure (TFH).

A sensitivity analysis was conducted to evaluate the effects of changes in the breach width and full breach formation time on the peak discharge from the dam breach. The breach side slopes were held at a constant value to independently evaluate the effects of the breach width and full breach formation time on the peak discharges. Calibration of the start time of the breach was also performed to calculate the most conservative result with the maximum peak discharge. Table 2 and Table 3 below summarizes the results of the minimum and maximum parameters.

WILL COUNTY STATION POND 1N					
Breach	Selected	Breach Width Sensitivity		Time to Failure Sensitivity	
Parameter		Minimum	Maximum	Minimum	Maximum
BR (ft)	29.81	8	40	29.81	29.81
Z (H:V)	1 to 1	1 to 1	1 to 1	1 to 1	1 to 1
TFH (hrs)	0.3	0.3	0.3	0.1	1.0
Breach Scenario	Discharge at Dam (cfs)	Discharge at Dam (cfs)	Discharge at Dam (cfs)	Discharge at Dam (cfs)	Discharge at Dam (cfs)
Sunny Day Breach	646.4	422.5	699.9	1220.8	254.2

Table 2: Pond 1N Sensitivity Analysis Results

Table 3: Pond 1S Sensitivity Analysis Results

WILL COUNTY STATION POND 1S					
Breach Parameter	Selected	Breach Width Sensitivity		Time to Failure Sensitivity	
		Minimum	Maximum	Minimum	Maximum
BR (ft)	28.76	8	40	28.76	28.76
Z (H:V)	1 to 1	1 to 1	1 to 1	1 to 1	1 to 1
TFH (hrs)	0.29	0.3	0.3	0.1	1.0
Breach Scenario	Discharge at Dam (cfs)	Discharge at Dam (cfs)	Discharge at Dam (cfs)	Discharge at Dam (cfs)	Discharge at Dam (cfs)
Sunny Day Breach	609.2	407.8	666.1	1136	254.2

6.0 EASTERN EMBANKMENT FAILURE RESULTS

A summary of the results for the selected breach parameters are listed in Table 4 and Table 5 below.

Civil & Environmental Consultants, Inc.

POND IN				
Scenario	Sunny Day			
Ducch Trigger	Time			
Breach Trigger	4:00			
Pool Elevation at Breach, Initial (ft)	590.5			
Time Breach Occurs	4:00			
Breach Type	Piping			
Starting Pool Elevation (ft)	590.5			
Storage Volume at Breach (ac- ft)	14.06			
Breach Invert Elevation, Final (ft)	582.5			
Discharge at Dam, Peak (cfs)	646.4			

 Table 4: Summary of 1N Impoundment Breach Results

Table 5: Summary of 1S Impoundment Breach Results

POND 1S				
Scenario	Sunny Day			
Duccab Triggon	Time			
breach i rigger	4:00			
Pool Elevation at Breach, Initial (ft)	590.5			
Time Breach Occurs	4:00			
Breach Type	Piping			
Starting Pool Elevation (ft)	590.5			
Storage Volume at Breach (ac- ft)	12.63			
Breach Invert Elevation, Final (ft)	582.5			
Discharge at Dam, Peak (cfs)	609.2			

Calculated maximum flow depth and maximum velocity from Ponds 1N and 1S can be found in Figures 2 through 5.

The result of the GeoHECRAS model for Pond 1N shows that the flow through the modeled breach travels from Pond 1N towards the north, south, and east, with the majority traveling to the northeast and releasing into the Shipping Canal. Estimated water depths near the buildings range from 0-1.0 foot with velocities less than 1.0 foot per second

The result of the GeoHECRAS model for Pond 1S shows that the flow through the modeled breach travels from Pond 1S towards the north, south, and east, with the majority traveling to the southeast. Estimated water depths near the buildings range from 0-1.75 feet with velocities less than 1.50 feet per second.

7.0 HAZARD CLASSIFICATION ASSESSMENT

As discussed in Section 1, a CCR surface impoundment is classified as Class 1 if failure or misoperation will probably cause loss of human life. Guidelines for evaluating potential loss of life during flood conditions are provide in USBR [1998]. Attachment B presents a relationship between flood flow depth and velocity for buildings on foundations that could cause potential loss of human life. Both Pond 1N and 1S' eastern embankment breaches plot in the "low danger zone". This indicates that a breach of either pond will not result in probable loss of human life.

Based on the results of the analysis provided in this report, Ponds 1N and 1S are classified as a Class 2 CCR impoundment because their failure would not result in probable loss of life but could result in impacts to the Des Plaines River creating potential economic loss, environmental damage, disruption of lifeline facilities, or impact other concerns.

8.0 LIMITATIONS AND CERTIFICATIONS

The findings and opinions presented are relative to the dates of the referenced and hydraulic data sets and should not be relied on to represent conditions at substantially later dates. The opinions included herein are based on information obtained during the study of CEC's experience. If additional information becomes available that might impact CEC's conclusions, CEC requests the opportunity to review the information, reassess the potential concerns, and modify CEC's opinions, if warranted. If our services included a review or use of documents or data sources prepared by others, CEC has no responsibility for accuracy of information contained therein.

CEC has relied on the accuracy of models and calculations enclosed by the regulatory authorities. Their analyses are in general accordance with industry standards. CEC makes no warrants or representations as to the accuracy or quality of these methods.

This initial Hazard Potential Classification Assessment Report has been prepared pursuant to the CCR rule codified in Title 35 of the Illinois Administrative Code, Section 845.440(a) and was prepared under the direction of Mr. M. Dean Jones, P.E.

By affixing my seal to this, I do hereby certify to the best of my knowledge, information, and belief that the information contained in this report is true and correct. I further certify I am licensed to practice in the State of Illinois and that it is within my professional expertise to verify the

correctness of the information. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment.



Signature: Daw Joner
Name: M. Dean Jones, P.E.
Date of Certification: <u>September 23, 2021</u>
Illinois Professional Engineer No.: <u>062-051317</u>
Expiration Date: <u>November 30, 2021</u>

Enclosures: Figures:

Figure 1 - Site Map Figure 2 - Pond 1N Maximum Flow Depth Figure 3 - Pond 1N Maximum Velocity Figure 4 - Pond 1S Maximum Flow Depth Figure 5 - Pond 1S Maximum Velocity Attachments: Attachment A - Storage Tables Attachment B - USBR Loss of Life Graph

FIGURES









1S Depth Map.mxd - 9/23/2021 - 8:55:29 AM (shonigford) **WR01** SHONIGFORD\Share\312-192\GIS\312-192



ATTACHMENT A

STORAGE TABLES

Stage-Area-Storage for Pond 1P: 1N CCR Basin

Elevation	Surface	Storage	Elevation	Surface	Storage
(feet)	(acres)	(acre-feet)	(feet)	(acres)	(acre-feet)
582.50	1.456	0.000	587.70	1.841	8.572
582.60	1.463	0.146	587.80	1.848	8.756
582.70	1.471	0.293	587.90	1.856	8.941
582.80	1.478	0.440	588.00	1.863	9.127
582.90	1.486	0.588	588.10	1.870	9.314
583.00	1.493	0.737	588.20	1.878	9.501
583.10	1.500	0.887	588.30	1.885	9.689
583.20 592.20	1.508	1.037	588.40	1.893	9.878
583.30	1.010	1.100	588.60	1.900	10.000
583.40	1.525	1.340	588 70	1.907	10.250
583.60	1.530	1.435	588.80	1 922	10.443
583 70	1.545	1.040	588.90	1 930	10.834
583.80	1.552	1.955	589.00	1.937	11.027
583.90	1.560	2.111	589.10	1.944	11.221
584.00	1.567	2.267	589.20	1.952	11.416
584.10	1.574	2.424	589.30	1.959	11.612
584.20	1.582	2.582	589.40	1.967	11.808
584.30	1.589	2.741	589.50	1.974	12.005
584.40	1.597	2.900	589.60	1.981	12.203
584.50	1.604	3.060	589.70	1.989	12.401
584.60	1.611	3.221	589.80	1.996	12.601
584.70	1.619	3.382	589.90	2.004	12.801
584.80	1.626	3.545	590.00	2.011	13.001
585.00	1.034	3.700	590.10	2.010	13.203
585.00	1.041	3.07 T 4.036	590.20	2.020	13.405
585 20	1.656	4 201	590.50	2.033	13 812
585.30	1.663	4 367	590.50	2.048	14.016
585.40	1.671	4.534	000.00		
585.50	1.678	4.701			
585.60	1.685	4.869			
585.70	1.693	5.038			
585.80	1.700	5.208			
585.90	1.708	5.378			
586.00	1.715	5.549			
586.10	1.722	5.721			
586.20	1.730	5.894			
586.30	1.737	0.007 6.241			
586 50	1.740	0.241			
586.60	1.752	6 592			
586 70	1 767	6 768			
586.80	1.774	6.945			
586.90	1.782	7.123			
587.00	1.789	7.301			
587.10	1.796	7.481			
587.20	1.804	7.661			
587.30	1.811	7.841			
587.40	1.819	8.023			
587.50	1.826	8.205			
507.60	1.833	8.388			

Pond 1P: 1N CCR Basin



Stage-Area-Storage for Pond 2P: 1S CCR Basin

Elevation	Surface	Storage	Elevation	Surface	Storage
582.50	1.298	0.000	587.70	1.663	7.698
582.60	1.305	0.130	587.80	1.670	7.864
582.70	1.312	0.261	587.90	1.677	8.032
582.80	1.319	0.393	588.00	1.684	8.200
582.90	1.326	0.525	588.10	1.691	8.368
583.00	1.333	0.658	588.20	1.698	8.538
583.10	1.340	0.791	588.30	1.705	8.708
583.20	1.347	0.926	588.40	1.712	8.879
583.30	1.354	1.061	588.50	1.719	9.050
583.40	1.361	1.197	588.60	1.726	9.222
583.50	1.368	1.333	588.70	1.733	9.395
583.60	1.375	1.470	588.80	1.740	9.569
583.70	1.382	1.608	588.90	1.747	9.743
583.80	1.389	1.747	589.00	1.754	9.918
583.90	1.396	1.886	589.10	1.761	10.094
584.00	1.403	2.026	589.20	1.768	10.271
584.10	1.410	2.167	589.30	1.775	10.448
584.20	1.417	2.308	589.40	1.782	10.626
584.30	1.424	2.450	589.50	1.789	10.804
584.40	1.431	2.593	589.60	1.796	10.983
584.50	1.438	2.736	589.70	1.803	11.163
584.60	1.445	2.880	589.80	1.810	11.344
584.70	1.452	3.025	589.90	1.817	11.525
584.80	1.459	3.171	590.00	1.824	11.707
584.90	1.466	3.317	590.10	1.831	11.890
585.00	1.473	3.464	590.20	1.838	12.073
585.10	1.480	3.612	590.30	1.845	12.258
585.20	1.487	3.760	590.40	1.852	12.442
585.30	1.494	3.909	590.50	1.859	12.628
585.40	1.501	4.059			
585.50	1.508	4.210			
585.60	1.515	4.361			
585.70	1.522	4.513			
585.80	1.529	4.665			
585.90	1.536	4.819			
586.00	1.543	4.973			
586.10	1.550	5.127			
586.20	1.557	5.283			
586.30	1.564	5.439			
586.40	1.571	5.596			
586.50	1.578	5.753			
586.60	1.586	5.911			
586.70	1.593	6.070			
586.80	1.600	6.230			
586.90	1.607	6.390			
587.00	1.614	6.551			
587.10	1.621	6.713			
587.20	1.628	6.875			
587.30	1.635	7.038			
587.40	1.642	7.202			
587.50	1.649	1.367			
587.60	1.656	7.532			
		I			

Pond 2P: 1S CCR Basin



ATTACHMENT B

USBR LOSS OF LIFE GRAPH



