

DATA SUMMARY POSTING

Station: Midwest Generation Will County Generating Station

Regulated Unit(s): Pond 1N (IEPA ID No. W1978100011-01)
 Pond 1S (IEPA ID No. W1978100011-02)

In accordance with the new Ill. Adm. Code Title 35, Part 845: Standards for the Disposal of Coal Combustion Residuals in Surface Impoundments (State CCR Rule) groundwater monitoring was completed during the 1st quarter 2025 which includes the entire list of parameters specified under Section 845.600(a)(1) and (b). Table 1 is a summary table of all available CCR monitoring data to date. In addition, Table 2 provides a summary of turbidity data which was collected as part of State CCR Rule requirements.

No background statistics or proposed Groundwater Protection Standards are included on these tables. The background statistics and proposed Groundwater Protection Standards were submitted to Illinois Environmental Protection Agency (EPA) as part of the Application for Initial Operating Permit for Ponds 1N and 1S dated March 31, 2022. Upon Illinois EPA approval of the Operating Permit and Proposed Groundwater Protection Standards, the approved comparison values will be included on the tables for subsequent data comparisons/evaluations.

Table 1A. Groundwater Analytical Results-Midwest Generation, LLC, Will County Station, Romeoville, IL. Pond 1N.

Well	Date	Boron	Calcium	Chloride	Fluoride	pH	Sulfate	Total Dissolved Solids	Antimony	Arsenic	Barium	Beryllium	Cadmium	Chromium	Cobalt	Lead	Lithium	Mercury	Molybdenum	Radium 226 + 228 Combined	Selenium	Thallium
MW-01 up gradient	5/3/2021	2.6	170	F1 21	0.62	6.83	390	1200	< 0.003	< 0.001	0.095	< 0.001	< 0.0005	< 0.005	< 0.001	< 0.0005	0.034	< 0.0002	0.012	0.623	0.0093	< 0.002
	5/24/2021	2.5	200	18	0.63	6.86	350	1100	< 0.003	< 0.001	0.093	^1+ < 0.001	< 0.0005	< 0.005	< 0.001	< 0.0005	0.036	< 0.0002	F1 < 0.012	0.953	0.012	< 0.002
	6/7/2021	3.0	200	18	0.63	6.52	380	510	< 0.003	< 0.001	0.096	< 0.001	< 0.0005	< 0.005	< 0.001	< 0.0005	0.037	< 0.0002	0.013	< 0.372	0.01	< 0.002
	6/25/2021	B 2.6	200	20	0.59	6.64	410	1200	^+ < 0.003	< 0.001	0.097	< 0.001	< 0.0005	< 0.005	< 0.001	< 0.0005	0.037	< 0.0002	0.014	0.672	0.0042	< 0.002
	7/12/2021	2.4	190	16	0.60	6.55	320	1000	< 0.003	0.0012	0.100	< 0.001	< 0.0005	< 0.005	< 0.001	< 0.0005	0.045	< 0.0002	0.013	0.457	0.012	< 0.002
	8/2/2021	2.4	200	18	0.65	6.57	410	1300	< 0.003	0.001	0.100	< 0.001	< 0.0005	< 0.005	< 0.001	< 0.0005	0.044	< 0.0002	0.014	0.478	0.0095	< 0.002
	8/23/2021	2.4	200	18	0.61	6.99	400	1100	< 0.003	< 0.001	0.100	< 0.001	< 0.0005	< 0.005	< 0.001	< 0.0005	0.044	< 0.0002	0.014	0.697	0.0058	< 0.002
	11/19/2021	2.0	170	29	0.56	6.62	260	970	< 0.003	< 0.001	0.090	^1+ < 0.001	< 0.0005	< 0.005	< 0.001	< 0.0005	0.038	< 0.0002	0.0098	1.16	0.017	< 0.002
	2/21/2022	2.0	190	26	0.55	6.63	370	1200	< 0.003	< 0.001	0.086	< 0.001	< 0.0005	< 0.005	< 0.001	< 0.0005	0.032	< 0.0002	0.011	0.773	0.0079	< 0.002
	6/15/2022	2.6	180	33	0.61	6.43	350	1100	< 0.003	< 0.001	0.09	< 0.001	0.00054	< 0.005	< 0.001	< 0.0005	0.033	< 0.0002	0.015	0.945	0.0087	< 0.002
	8/24/2022	2.7	180	24	0.61	6.51	370	1400	< 0.003	< 0.001	0.093	< 0.001	^1+ 0.00092	< 0.005	0.0016	0.00078	0.038	< 0.0002	0.015	0.581	0.0047	< 0.002
	11/15/2022	2.9	190	22	1.00	6.59	360	1100	< 0.003	0.0011	0.097	^+ < 0.001	0.00052	< 0.005	0.001	0.00057	0.039	< 0.0002	0.014	< 0.63	0.0085	< 0.002
	2/22/2023	2	170	29	0.49	6.93	360	1000	< 0.003	< 0.001	0.082	< 0.001	< 0.0005	< 0.005	< 0.001	< 0.0005	0.031	< 0.0002	0.013	< 0.544	0.0092	< 0.002
	4/27/2023	2.4	120	77	0.69	6.79	400	1100	< 0.0030	< 0.0010	0.065	< 0.0010	< 0.0050	< 0.0050	< 0.0010	< 0.0050	0.028	< 0.00020	0.041	0.824	< 0.0025	< 0.0020
	7/27/2023	2.3	170	29	0.58	6.54	320	1000	< 0.0030	< 0.0010	0.088	^+ < 0.0010	< 0.0050	< 0.0050	< 0.0010	< 0.0050	0.036	< 0.00020	0.016	1.92	0.013	< 0.0020
	10/23/2023	2.1	160	21	0.55	6.47	240	1000	< 0.0030	< 0.0010	B 0.087	< 0.0010	< 0.0050	< 0.0050	< 0.0010	< 0.0050	0.038	< 0.00020	0.012	< 0.625	0.0099	< 0.0020
	2/6/2024	2.8	120	72	0.75	6.83	400	1100	^1+ < 0.0030	< 0.0010	0.076	^+ < 0.0010	< 0.0050	< 0.0050	< 0.0010	< 0.0050	< 0.10	< 0.00020	0.049	0.686	0.0032	< 0.0020
	5/7/2024	2.7	100	78	0.75	7.39	400	980	< 0.0030	< 0.0010	0.063	< 0.0010	< 0.0050	< 0.0050	< 0.0010	< 0.0050	0.025	< 0.00020	0.058	1.17	< 0.0025	< 0.0020
	8/6/2024	2.8	88	87	0.83	7.01	420	1100	< 0.0030	< 0.0010	0.063	< 0.0010	< 0.0050	< 0.0050	0.0014	< 0.0050	0.024	< 0.00020	0.065	< 0.504	< 0.0025	< 0.0020
	11/5/2024	2.8	120	67	0.69	7.12	380	1100	< 0.0030	< 0.0010	0.082	< 0.0010	< 0.0050	< 0.0050	< 0.0010	< 0.0050	0.027	< 0.00020	0.042	0.715	< 0.0025	< 0.0020
	2/5/2025	2.5	98	94	0.71	7.09	420	1000	< 0.0030	< 0.0010	0.063	< 0.0010	< 0.0050	< 0.0050	< 0.0010	< 0.0050	0.023	< 0.00020	0.060	1.16	0.0068	< 0.0020
MW-02 up gradient	5/3/2021	5.3	87	28	0.41	7.76	500	1100	< 0.003	0.009	0.058	< 0.001	< 0.0005	< 0.005	< 0.001	< 0.0005	0.046	< 0.0002	0.072	1.3	< 0.0025	< 0.002
	5/24/2021	5.2	88	24	0.41	7.77	550	1100	< 0.003	0.0099	0.059	^1+ < 0.001	< 0.0005	< 0.005	< 0.001	< 0.0005	0.047	< 0.0002	0.07	1.19	< 0.0025	< 0.002
	6/7/2021	6.5	100	25	0.4	7.60	540	1100	< 0.003	0.011	0.057	< 0.001	< 0.0005	< 0.005	< 0.001	< 0.0005	0.045	< 0.0002	0.081	0.54	< 0.0025	< 0.002
	6/28/2021	B 5.3	95	23	0.36	7.93	500	1200	^+ < 0.003	0.012	0.059	< 0.001	< 0.0005	0.0057	< 0.001	< 0.0005	0.046	< 0.0002	0.075	0.8	< 0.0025	< 0.002
	7/12/2021	5.2	97	21	0.37	7.53	480	970	< 0.003	0.012	0.067	< 0.001	< 0.0005	< 0.005	< 0.001	< 0.0005	0.051	< 0.0002	0.071	1.07	< 0.0025	< 0.002
	8/2/2021	4.8	92	24	0.37	7.54	520	1200	< 0.003	0.011	0.06	< 0.001	< 0.0005	< 0.005	< 0.001	< 0.0005	0.048	< 0.0002	0.073	0.798	< 0.0025	< 0.002
	8/23/2021	5.0	92	26	0.38	8.02	530	830	< 0.003	0.011	0.06	< 0.001	< 0.0005	< 0.005	< 0.001	< 0.0005	0.048	< 0.0002	0.075	0.986	< 0.0025	< 0.002
	11/19/2021	5.2	86	27	0.38	7.72	520	1100	< 0.003	0.014	0.057	^1+ < 0.001	< 0.0005	< 0.005	< 0.001	< 0.0005	0.041	< 0.0002	0.068	1.43	< 0.0025	< 0.002
	2/21/2022	4.9	92	32	0.43	7.65	550	1100	< 0.003	0.01	0.06	< 0.001	< 0.0005	< 0.005	< 0.001	< 0.0005	0.044	< 0.0002	0.083	< 0.848	< 0.0025	< 0.002
	6/15/2022	5.3	91	30	0.39	7.32	460	1100	< 0.003	0.01	0.058	< 0.001	< 0.0005	< 0.005	< 0.001	< 0.0005	0.044	< 0.0002	0.073	1.17	< 0.0025	< 0.002
	8/24/2022	5.6	81	28	0.38	7.73	480	1100	< 0.003	0.015	0.059	< 0.001	^1+ < 0.0005	< 0.005	< 0.001	< 0.0005	0.043	< 0.0002	0.07	0.984	< 0.0025	< 0.002
	11/15/2022	6.5	99	27	0.64	7.64	530	1000	< 0.003	0.017	0.069	^+ < 0.001	< 0.0005	< 0.005	< 0.001	0.00052	0.047	< 0.0002	0.076	2.13	< 0.0025	< 0.002
	2/22/2023	4.6	89	29	0.38	7.86	460	980	< 0.003	0.0095	0.06	< 0.001	< 0.0005	< 0.005	< 0.001	< 0.0005	0.042	< 0.0002	0.075	0.974	< 0.0025	< 0.002
	4/27/2023	4.6	83	29	0.37	7.60	430	100														

Table 1B. Groundwater Analytical Results-Midwest Generation, LLC, Will County Station, Romeoville, IL. Pond 1S.

Well	Date	Boron	Calcium	Chloride	Fluoride	pH	Sulfate	Total Dissolved Solids	Antimony	Arsenic	Barium	Beryllium	Cadmium	Chromium	Cobalt	Lead	Lithium	Mercury	Molybdenum	Radium 226 + 228	Selenium	Thallium	
MW-03 up gradient	5/3/2021	3.3	140	18	0.31	6.90	240	890	< 0.003	0.0011	0.11	< 0.001	< 0.0005	< 0.0005	< 0.001	< 0.0005	0.04	< 0.0002	0.017	0.993	< 0.0025	< 0.002	
	5/24/2021	3.2	120	19	0.34	6.91	270	900	< 0.003	0.001	0.001	^1+< 0.001	< 0.0005	< 0.0005	< 0.001	< 0.0005	0.038	< 0.0002	0.018	0.922	0.0057	< 0.002	
	6/8/2021	3.7	140	21	0.32	6.75	290	940	< 0.003	0.0014	0.10	< 0.001	< 0.0005	< 0.0005	< 0.001	< 0.0005	0.041	< 0.0002	0.017	0.857	< 0.0025	< 0.002	
	6/28/2021	B 3.6	120	23	0.32	7.17	290	930	^1+< 0.003	0.0023	0.091	< 0.001	< 0.0005	< 0.0005	0.001	< 0.0005	0.044	< 0.0002	0.022	1.03	< 0.0025	< 0.002	
	7/12/2021	3.8	120	27	0.33	6.88	270	870	< 0.003	0.0033	0.10	< 0.001	0.00053	< 0.0005	< 0.001	< 0.0005	0.048	< 0.0002	0.028	1.97	< 0.0025	< 0.002	
	8/2/2021	6.2	120	31	0.3	6.86	280	920	< 0.003	0.0053	0.096	< 0.001	< 0.0005	< 0.0005	0.001	< 0.0005	0.043	< 0.0002	0.021	1.16	< 0.0025	< 0.002	
	8/24/2021	3.3	120	F1 F2 50	0.35	7.28	300	890	< 0.003	0.0021	0.091	< 0.001	< 0.0005	< 0.0005	< 0.001	< 0.0005	0.042	< 0.0002	0.022	0.763	< 0.0025	< 0.002	
	11/19/2021	3.7	160	27	0.32	6.67	330	970	< 0.003	0.0016	0.12	^1+< 0.001	< 0.0005	< 0.0005	< 0.001	< 0.0005	0.039	< 0.0002	0.025	2.47	0.0082	< 0.002	
	2/24/2022	2.6	220	18	0.3	6.53	360	1200	< 0.003	0.0015	0.12	^1+< 0.001	< 0.0005	< 0.0005	< 0.001	< 0.0005	0.032	< 0.0002	0.014	1.11	0.046	< 0.002	
	6/16/2022	4.0	140	18	0.31	6.62	300	910	< 0.003	0.0014	0.10	< 0.001	< 0.0005	< 0.0005	< 0.001	< 0.0005	0.045	< 0.0002	0.022	1.38	< 0.0025	< 0.002	
	8/24/2022	3.4	140	35	0.34	6.73	360	1200	< 0.003	< 0.001	0.096	< 0.001	^1+< 0.0005	< 0.0005	0.001	< 0.0005	0.035	< 0.0002	0.018	1.24	< 0.0025	< 0.002	
	11/15/2022	3.5	140	43	F1 0.64	6.79	360	990	< 0.003	0.0039	0.095	^1+< 0.001	< 0.0005	< 0.0005	0.0012	< 0.0005	0.00663	< 0.0002	0.021	1.78	< 0.0025	< 0.002	
	2/22/2023	2.4	180	14	0.29	6.83	330	1000	< 0.003	< 0.001	0.099	< 0.001	< 0.0005	< 0.0005	< 0.001	< 0.0005	0.03	< 0.0002	0.013	0.76	0.03	< 0.002	
	4/27/2023	3.2	150	16	0.28	6.54	320	1000	< 0.0030	0.0013	0.090	< 0.0010	< 0.00050	< 0.00050	< 0.0010	< 0.00050	0.040	< 0.00020	0.021	1.12	0.0057	< 0.0020	
	7/27/2023	3.5	160	16	0.25	6.53	280	930	< 0.0030	0.0010	0.11	^1+< 0.0010	< 0.00050	< 0.00050	0.0010	< 0.00050	0.043	< 0.00020	0.013	1.43	0.0053	< 0.0020	
	10/23/2023	3.7	140	19	0.26	6.63	200	900	< 0.0030	< 0.0010	B 0.10	< 0.0010	< 0.00050	< 0.00050	0.0012	< 0.00050	0.034	< 0.00020	0.011	1.90	0.0042	< 0.0020	
	2/6/2024	3.9	150	14	0.28	6.73	270	890	^1+< 0.0030	< 0.0010	0.097	^1+< 0.0010	< 0.00050	< 0.00050	< 0.0010	< 0.00050	< 0.10	< 0.00020	0.018	1.12	0.0041	< 0.0020	
	5/7/2024	4.2	120	15	0.31	7.10	320	870	< 0.0030	< 0.0010	0.086	< 0.0010	< 0.00050	< 0.00050	< 0.0011	< 0.00050	0.044	< 0.00020	0.028	0.668	< 0.0025	< 0.0020	
	8/6/2024	B 3.7	160	21	0.31	6.66	310	1000	< 0.0030	< 0.0010	0.099	< 0.0010	< 0.00050	< 0.00050	0.0012	< 0.00050	0.038	< 0.00020	0.017	0.865	< 0.0025	< 0.0020	
	11/5/2024	3.2	160	26	0.33	7.06	300	990	< 0.0030	< 0.0010	0.098	< 0.0010	< 0.00050	< 0.00050	0.0013	< 0.00050	0.031	< 0.00020	0.015	1.30	< 0.0025	< 0.0020	
	2/5/2025	2.9	210	16	0.23	6.70	390	1200	< 0.0030	< 0.0010	0.13	< 0.0010	< 0.00050	< 0.00050	< 0.0010	< 0.00050	0.034	< 0.00020	0.011	1.074	0.0061	< 0.0020	
	MW-04 up gradient	5/3/2021	3.5	140	28	0.36	6.76	910	2000	< 0.003	0.003	0.046	< 0.001	< 0.0005	< 0.0005	0.0019	< 0.0005	0.026	< 0.0002	0.026	1.16	< 0.0025	< 0.002
		5/24/2021	5.5	340	24	0.38	6.90	950	2000	< 0.003	0.0039	0.047	^1+< 0.001	< 0.0005	< 0.0005	0.0016	< 0.0005	0.027	< 0.0002	0.028	1.72	0.0051	< 0.002
		6/8/2021	5.7	310	24	0.37	6.58	910	2000	< 0.003	0.0026	0.043	< 0.001	< 0.0005	< 0.0005	0.0016	< 0.0005	0.027	< 0.0002	0.028	< 0.459	0.0076	< 0.002
		6/28/2021	B 5.6	330	20	0.35	6.95	930	2100	^1+< 0.003	0.011	0.047	< 0.001	< 0.0005	< 0.0005	0.0016	< 0.0005	0.025	< 0.0002	0.027	1.12	0.019	< 0.002
		7/12/2021	5.9	320	16	0.38	6.70	970	2100	< 0.003	0.01	0.049	< 0.001	< 0.0005	< 0.0005	0.0016	< 0.0005	0.03	< 0.0002	0.033	1.68	0.0056	< 0.002
		8/2/2021	5.3	310	21	0.38	6.71	1000	2200	< 0.003	0.0039	0.046	< 0.001	< 0.0005	< 0.0005	0.0018	< 0.0005	0.027	< 0.0002	0.032	1.18	< 0.0025	< 0.002
		8/24/2021	6.2	320	90	0.40	7.09	1100	1700	< 0.003	0.0075	0.046	< 0.001	< 0.0005	< 0.0005	0.002	< 0.0005	0.028	< 0.0002	0.035	< 0.642	< 0.0025	< 0.002
11/19/2021		6.1	300	23	0.36	6.69	840	1900	< 0.003	0.0063	0.044	^1+< 0.001	< 0.0005	< 0.0005	0.0022	< 0.0005	0.022	< 0.0002	0.023	1.17	< 0.0025	< 0.002	
2/24/2022		4.7	350	16	0.37	6.50	950	2100	< 0.003	0.02	0.039	^1+< 0.001	< 0.0005	< 0.0005	0.0017	< 0.0005	0.02	< 0.0002	0.028	< 0.424	0.09	< 0.002	
6/16/2022		5.5	310	22	0.37	6.55	980	2200	< 0.003	0.003	0.045	< 0.001	< 0.0005	< 0.0005	0.0021	< 0.0005	0.023	< 0.0002	0.026	1.39	0.0044	< 0.002	
8/24/2022		5.8	280	18	0.40	6.57	810	2000	< 0.003	0.0053	0.044	< 0.001	^1+< 0.0005	< 0.0005	0.003	< 0.0005	0.019	< 0.0002	0.021	1.41	0.003	< 0.002	
11/15/2022		5.6	290	19	0.64	6.64	770	1700	< 0.003	0.011	0.047	^1+< 0.001	< 0.0005	< 0.0005	0.0032	< 0.0005	0.02	< 0.0002	0.021	4.15	0.0061	< 0.002	
2/22/2023		3.7	390	36	0.38	6.77	1200	2500	< 0.003	0.0044	0.035	< 0.001	< 0.0005	< 0.0005	< 0.001	< 0.0005	0.02	< 0.0002	0.032	0.795	0.067	< 0.002	
4/27/2023		4.3	310	25	0.33	6.51	870	2000	< 0.0030	0.0027	0.039	< 0.0010	< 0.00050	< 0.00050	0.0015	< 0.00050	0.021	< 0.00020	0.023	1.19	0.0091	< 0.0020	
7/27/2023		4.9	300	20	0.36	6.49	790	1700	< 0.0030	0.0017	0.041	^1+< 0.0010	< 0.00050	< 0.00050	0.0015	< 0.00050	0.021	< 0.					

Table 2A. Groundwater Turbidity - Pond 1N, Midwest Generation, LLC, Will County Generating Station, Romeoville, IL.

Well ID	Date	Turbidity (NTU)
MW-01	2/23/2021	0.64
	4/10/2021	5.81
	4/25/2021	7.69
	5/3/2021	1.74
	5/24/2021	1.83
	6/7/2021	2.32
	6/25/2021	3.50
	7/12/2021	4.18
	8/2/2021	2.87
	8/23/2021	1.17
	9/24/2021	3.25
	11/19/2021	16.82
	2/21/2022	3.04
	6/15/2022	10.56
	8/24/2022	15.3
	11/15/2022	19.8
	2/22/2023	19.12
	4/27/2023	4.40
	7/27/2023	7.20
	10/23/2023	4.10
	2/6/2024	12.10
	5/7/2024	23.76
MW-02	8/6/2024	17.92
	11/5/2024	5.71
	2/5/2025	39.44
	2/25/2021	8.84
	4/10/2021	9.17
	4/25/2021	12.03
	5/3/2021	2.42
	5/24/2021	2.7
	6/7/2021	1.82
	6/28/2021	3.15
	7/12/2021	4.23
	8/2/2021	3.11
	8/23/2021	1.37
	9/24/2021	4.63
	11/19/2021	2.1
	2/21/2022	0.45
	6/15/2022	2.69
	8/24/2022	8.71
	11/15/2022	8.21
	2/22/2023	6.07
	4/27/2023	2.90
MW-07	7/27/2023	7.40
	10/23/2023	7.00
	2/6/2024	12.70
	5/7/2024	11.18
	8/6/2024	13.32
	11/5/2024	28.86
	2/5/2025	38.07
	3/1/2021	6.11
	4/10/2021	6.19
	4/25/2021	6.98
	5/4/2021	37.65
	5/24/2021	2.54
	6/7/2021	6.21
	6/25/2021	6.02
	7/12/2021	5.13
	8/2/2021	2.45
	8/25/2021	7.7
	9/24/2021	4.13
	11/19/2021	7.35
	2/22/2022	-0.02
	6/15/2022	5.58
	8/25/2022	2.27
MW-14	11/15/2022	41.3
	2/22/2023	13.55
	4/27/2023	8.90
	7/27/2023	1.00
	10/23/2023	8.10
	2/7/2024	0.41
	5/8/2024	17.65
	8/5/2024	50.71
	11/4/2024	3.04
	2/4/2025	30.27
	5/4/2021	6.88
	5/25/2021	3.5
	6/7/2021	2.55
	6/28/2021	7.44
	7/12/2021	4.89
	8/2/2021	9.8
	8/25/2021	11.7
	9/24/2021	6.87
	11/19/2021	5.19
	2/23/2022	45.11
	6/14/2022	3.98
	8/23/2022	2.71
	11/17/2022	2.8
	2/21/2023	6.71
	4/25/2023	5.0
	7/25/2023	3.7
	10/19/2023	1.7
	2/5/2024	2.6
	5/7/2024	7.12
	8/1/2024	3.94
	11/4/2024	5.40
	2/4/2025	32.75

Table 2A. Groundwater Turbidity - Pond 1N, Midwest Generation, LLC, Will County Generating Station, Romeoville, IL.

Well ID	Date	Turbidity (NTU)
MW-15	5/4/2021	28.65
	5/25/2021	8.89
	6/7/2021	8.82
	6/28/2021	6.48
	7/12/2021	8.52
	8/2/2021	22.71
	8/25/2021	12.4
	9/24/2021	11.44
	11/19/2021	10.83
	2/22/2022	17.05
	6/14/2022	11.83
	8/23/2022	33.2
	11/17/2022	148.2
	2/21/2023	41.83
	4/25/2023	11.2
	7/25/2023	35.6
	10/19/2023	55.2
	2/6/2024	20.5
	5/7/2024	89.52
	8/1/2024	59.82
	11/5/2024	40.81
	2/6/2025	55.13

Table 2B. Groundwater Turbidity - Pond 1S, Midwest Generation, LLC, Will County Generating Station, Romeoville, IL.

Well ID	Date	Turbidity (NTU)
MW-03	3/1/2021	0.0
	4/10/2021	1.45
	4/25/2021	3.41
	5/3/2021	1.61
	5/24/2021	2.06
	6/8/2021	2.34
	6/28/2021	2.69
	7/12/2021	4.07
	8/2/2021	1.98
	8/24/2021	5.1
	9/24/2021	4.18
	11/19/2021	0.47
	2/24/2022	-1.1
	6/16/2022	1.7
	8/24/2022	6.4
	11/15/2022	9.7
	2/22/2023	6.9
	4/27/2023	2.00
	7/27/2023	7.20
	10/23/2023	0.50
	2/6/2024	0.20
	5/7/2024	8.73
	8/6/2024	0.75
	11/5/2024	1.42
	2/5/2025	26.84
MW-04	2/22/2021	9.87
	4/10/2021	42.2
	4/25/2021	7.41
	5/3/2021	4.2
	5/24/2021	4.45
	6/8/2021	2.8
	6/28/2021	12.93
	7/12/2021	3.93
	8/2/2021	3.75
	8/24/2021	10.1
	9/24/2021	5.74
	11/19/2021	15.15
	2/24/2022	2.04
	6/16/2022	3.13
	8/24/2022	4.7
	11/15/2022	14.2
	2/22/2023	20.1
	4/27/2023	8.40
	7/27/2023	6.00
	10/23/2023	3.5
	2/6/2024	16.3
	5/8/2024	10.72
	8/6/2024	24.01
	11/5/2024	37.84
	2/5/2025	54.83
MW-08	3/1/2021	2.3
	4/10/2021	270.98
	4/25/2021	26.73
	5/4/2021	6.6
	5/28/2021	6.51
	6/7/2021	4.58
	6/28/2021	5.67
	7/12/2021	6.71
	8/2/2021	14.15
	8/25/2021	8.9
	9/24/2021	7.21
	11/19/2021	2.34
	2/24/2022	40.05
	6/15/2022	5.01
	8/25/2022	9.02
	11/17/2022	13.9
	2/23/2023	43.13
	4/27/2023	29.20
	7/26/2023	16.90
	10/24/2023	11.30
	2/7/2024	39.80
	5/8/2024	51.31
	8/5/2024	3.52
	11/4/2024	18.02
	2/4/2025	48.94
MW-09	3/1/2021	0.86
	4/10/2021	6.91
	4/25/2021	2.08
	5/25/2021	14.12
	6/11/2021	2.39
	6/29/2021	2.97
	7/12/2021	3.94
	8/4/2021	0.0
	8/25/2021	19.9
	9/24/2021	3.67
	11/23/2021	19.07
	2/22/2022	0.59
	6/15/2022	113.77
	8/25/2022	1.93
	11/16/2022	11.73
	2/23/2023	10.34
	4/26/2023	2.90
	7/26/2023	6.50
	10/24/2023	9.50
	2/7/2024	9.30
	5/8/2024	8.90
	8/5/2024	2.67
	11/4/2024	30.58
	2/4/2025	52.73
MW-13	5/4/2021	20.6
	5/25/2021	9.8
	6/7/2021	6.49
	6/28/2021	8.25
	7/12/2021	5.89
	8/2/2021	2.91
	8/26/2021	12.9
	9/24/2021	9.13
	11/23/2021	17.83
	2/23/2022	34.33
	6/14/2022	81.91
	8/23/2022	47.3
	11/16/2022	77.2
	2/21/2023	41.7
	4/25/2023	41.90
	7/25/2023	16.70
	10/19/2023	47.10
	2/5/2024	22.00
	2/5/2024	12.61
	8/1/2024	9.80
	11/4/2024	11.79
	2/3/2025	59.22

ANALYTICAL REPORT

PREPARED FOR

Attn: James Thorne
Midwest Generation EME LLC
1800 Channahon Road
Joliet, Illinois 60436

Generated 2/14/2025 4:14:20 PM

JOB DESCRIPTION

Will County CCR

JOB NUMBER

500-263508-1

Eurofins Chicago

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Chicago Project Manager.

Authorization



Generated
2/14/2025 4:14:20 PM

Authorized for release by
Robin Kintz, Project Manager II
Robin.Kintz@et.eurofinsus.com
Designee for
Diana Mockler, Project Manager I
Diana.Mockler@et.eurofinsus.com
(219)252-7570



Table of Contents

Cover Page	1
Table of Contents	3
Case Narrative	4
Method Summary	5
Sample Summary	6
Client Sample Results	7
Definitions	18
QC Association	19
QC Sample Results	23
Chain of Custody	29
Receipt Checklists	31
Chronicle	32

Case Narrative

Client: Midwest Generation EME LLC
Project: Will County CCR

Job ID: 500-263508-1

Job ID: 500-263508-1

Eurofins Chicago

Job Narrative 500-263508-1

Receipt

The samples were received on 2/4/2025 4:30 PM and 2/6/2025 9:18 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperatures of the 4 coolers at receipt time were -0.9°C, -0.8°C, 0.8°C and 3.3°C.

Metals

Method 6020B - Total Recoverable: The linear range check (LRC) recovered outside of control limits for Lithium. Sample results are within the high calibration standard and have been qualified and reported. (LRC 500-805543/14)

Method 6020B - Total Recoverable: The following sample was diluted to bring the concentration of target analytes within the calibration range: MW-02 (500-263508-8). Elevated reporting limits (RLs) are provided.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

General Chemistry

Method 300.0_28D: Due to the high concentration of Chloride, the matrix spike / matrix spike duplicate (MS/MSD) for analytical batch 500-805352 could not be evaluated for accuracy and precision. The associated laboratory control sample (LCS) met acceptance criteria.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Chicago

Method Summary

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Method	Method Description	Protocol	Laboratory
6020B	Metals (ICP/MS)	SW846	EET CHI
7470A	Mercury (CVAA)	SW846	EET CHI
300.0	Anions, Ion Chromatography	EPA	EET CHI
SM 2540C	Solids, Total Dissolved (TDS)	SM	EET CHI
SM 4500 F C	Fluoride	SM	EET CHI
3005A	Preparation, Total Recoverable or Dissolved Metals	SW846	EET CHI
7470A	Preparation, Mercury	SW846	EET CHI

Protocol References:

EPA = US Environmental Protection Agency

SM = "Standard Methods For The Examination Of Water And Wastewater"

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

EET CHI = Eurofins Chicago, 2417 Bond Street, University Park, IL 60484, TEL (708)534-5200

Sample Summary

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
500-263508-1	MW-07	Water	02/04/25 12:29	02/04/25 16:30
500-263508-2	MW-08	Water	02/04/25 10:57	02/04/25 16:30
500-263508-3	MW-09	Water	02/04/25 09:10	02/04/25 16:30
500-263508-4	MW-13	Water	02/04/25 15:27	02/04/25 16:30
500-263508-5	MW-14	Water	02/04/25 13:33	02/04/25 16:30
500-263508-6	1N/1S Duplicate	Water	02/04/25 00:00	02/04/25 16:30
500-263508-7	MW-01	Water	02/05/25 15:30	02/06/25 09:18
500-263508-8	MW-02	Water	02/05/25 13:52	02/06/25 09:18
500-263508-9	MW-03	Water	02/05/25 12:49	02/06/25 09:18
500-263508-10	MW-04	Water	02/05/25 11:15	02/06/25 09:18
500-263508-11	MW-15	Water	02/05/25 14:51	02/06/25 09:18

Client Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Client Sample ID: MW-07

Lab Sample ID: 500-263508-1

Date Collected: 02/04/25 12:29

Matrix: Water

Date Received: 02/04/25 16:30

Method: SW846 6020B - Metals (ICP/MS) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenic	0.0018		0.0010		mg/L		02/05/25 08:19	02/06/25 13:51	1
Boron	4.0		0.050		mg/L		02/05/25 08:19	02/07/25 12:38	1
Barium	0.097		0.0025		mg/L		02/05/25 08:19	02/06/25 13:51	1
Beryllium	<0.0010		0.0010		mg/L		02/05/25 08:19	02/07/25 12:38	1
Calcium	220		0.20		mg/L		02/05/25 08:19	02/06/25 13:51	1
Cadmium	<0.00050		0.00050		mg/L		02/05/25 08:19	02/06/25 13:51	1
Cobalt	0.0010		0.0010		mg/L		02/05/25 08:19	02/06/25 13:51	1
Chromium	<0.0050		0.0050		mg/L		02/05/25 08:19	02/06/25 13:51	1
Molybdenum	0.051		0.0050		mg/L		02/05/25 08:19	02/06/25 13:51	1
Lead	<0.00050		0.00050		mg/L		02/05/25 08:19	02/06/25 13:51	1
Antimony	<0.0030		0.0030		mg/L		02/05/25 08:19	02/06/25 13:51	1
Selenium	<0.0025		0.0025		mg/L		02/05/25 08:19	02/06/25 13:51	1
Thallium	<0.0020		0.0020		mg/L		02/05/25 08:19	02/06/25 13:51	1
Lithium	0.028	^5-	0.010		mg/L		02/05/25 08:19	02/06/25 13:51	1

Method: SW846 7470A - Mercury (CVAA)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	<0.00020		0.00020		mg/L		02/06/25 15:50	02/07/25 13:04	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride (EPA 300.0)	140		1.0		mg/L			02/06/25 18:52	1
Sulfate (EPA 300.0)	590		20		mg/L			02/08/25 17:20	20
Total Dissolved Solids (SM 2540C)	1500		10		mg/L			02/07/25 01:51	1
Fluoride (SM 4500 F C)	0.47		0.10		mg/L			02/06/25 13:39	1

Client Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Client Sample ID: MW-08

Lab Sample ID: 500-263508-2

Date Collected: 02/04/25 10:57

Matrix: Water

Date Received: 02/04/25 16:30

Method: SW846 6020B - Metals (ICP/MS) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenic	0.0031		0.0010		mg/L		02/05/25 08:19	02/06/25 13:53	1
Boron	2.1		0.050		mg/L		02/05/25 08:19	02/07/25 12:41	1
Barium	0.063		0.0025		mg/L		02/05/25 08:19	02/06/25 13:53	1
Beryllium	<0.0010		0.0010		mg/L		02/05/25 08:19	02/07/25 12:41	1
Calcium	150		0.20		mg/L		02/05/25 08:19	02/06/25 13:53	1
Cadmium	<0.00050		0.00050		mg/L		02/05/25 08:19	02/06/25 13:53	1
Cobalt	<0.0010		0.0010		mg/L		02/05/25 08:19	02/06/25 13:53	1
Chromium	<0.0050		0.0050		mg/L		02/05/25 08:19	02/06/25 13:53	1
Molybdenum	0.029		0.0050		mg/L		02/05/25 08:19	02/06/25 13:53	1
Lead	<0.00050		0.00050		mg/L		02/05/25 08:19	02/06/25 13:53	1
Antimony	<0.0030		0.0030		mg/L		02/05/25 08:19	02/06/25 13:53	1
Selenium	0.0032		0.0025		mg/L		02/05/25 08:19	02/06/25 13:53	1
Thallium	<0.0020		0.0020		mg/L		02/05/25 08:19	02/06/25 13:53	1
Lithium	0.011	^5-	0.010		mg/L		02/05/25 08:19	02/06/25 13:53	1

Method: SW846 7470A - Mercury (CVAA)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	<0.00020		0.00020		mg/L		02/06/25 15:50	02/07/25 13:06	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride (EPA 300.0)	180		1.0		mg/L			02/06/25 19:07	1
Sulfate (EPA 300.0)	280		10		mg/L			02/08/25 17:36	10
Total Dissolved Solids (SM 2540C)	1200		10		mg/L			02/07/25 01:54	1
Fluoride (SM 4500 F C)	0.51		0.10		mg/L			02/06/25 13:43	1

Client Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Client Sample ID: MW-09

Lab Sample ID: 500-263508-3

Date Collected: 02/04/25 09:10

Matrix: Water

Date Received: 02/04/25 16:30

Method: SW846 6020B - Metals (ICP/MS) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenic	0.0094		0.0010		mg/L		02/05/25 08:19	02/06/25 13:56	1
Boron	1.8		0.050		mg/L		02/05/25 08:19	02/07/25 12:43	1
Barium	0.042		0.0025		mg/L		02/05/25 08:19	02/06/25 13:56	1
Beryllium	<0.0010		0.0010		mg/L		02/05/25 08:19	02/07/25 12:43	1
Calcium	40		0.20		mg/L		02/05/25 08:19	02/06/25 13:56	1
Cadmium	<0.00050		0.00050		mg/L		02/05/25 08:19	02/06/25 13:56	1
Cobalt	<0.0010		0.0010		mg/L		02/05/25 08:19	02/06/25 13:56	1
Chromium	<0.0050		0.0050		mg/L		02/05/25 08:19	02/06/25 13:56	1
Molybdenum	0.081		0.0050		mg/L		02/05/25 08:19	02/06/25 13:56	1
Lead	<0.00050		0.00050		mg/L		02/05/25 08:19	02/06/25 13:56	1
Antimony	<0.0030		0.0030		mg/L		02/05/25 08:19	02/06/25 13:56	1
Selenium	<0.0025		0.0025		mg/L		02/05/25 08:19	02/06/25 13:56	1
Thallium	<0.0020		0.0020		mg/L		02/05/25 08:19	02/06/25 13:56	1
Lithium	<0.010	^5-	0.010		mg/L		02/05/25 08:19	02/06/25 13:56	1

Method: SW846 7470A - Mercury (CVAA)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	<0.00020		0.00020		mg/L		02/06/25 15:50	02/07/25 13:08	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride (EPA 300.0)	210		10		mg/L			02/06/25 19:23	10
Sulfate (EPA 300.0)	260		10		mg/L			02/06/25 19:23	10
Total Dissolved Solids (SM 2540C)	770		10		mg/L			02/07/25 01:56	1
Fluoride (SM 4500 F C)	0.53		0.10		mg/L			02/06/25 13:48	1

Client Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Client Sample ID: MW-13

Lab Sample ID: 500-263508-4

Date Collected: 02/04/25 15:27

Matrix: Water

Date Received: 02/04/25 16:30

Method: SW846 6020B - Metals (ICP/MS) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenic	<0.0010		0.0010		mg/L		02/05/25 08:19	02/06/25 13:59	1
Boron	1.1		0.050		mg/L		02/05/25 08:19	02/07/25 12:46	1
Barium	0.095		0.0025		mg/L		02/05/25 08:19	02/06/25 13:59	1
Beryllium	<0.0010		0.0010		mg/L		02/05/25 08:19	02/07/25 12:46	1
Calcium	130		0.20		mg/L		02/05/25 08:19	02/06/25 13:59	1
Cadmium	<0.00050		0.00050		mg/L		02/05/25 08:19	02/06/25 13:59	1
Cobalt	<0.0010		0.0010		mg/L		02/05/25 08:19	02/06/25 13:59	1
Chromium	<0.0050		0.0050		mg/L		02/05/25 08:19	02/06/25 13:59	1
Molybdenum	0.012		0.0050		mg/L		02/05/25 08:19	02/06/25 13:59	1
Lead	0.00072		0.00050		mg/L		02/05/25 08:19	02/06/25 13:59	1
Antimony	<0.0030		0.0030		mg/L		02/05/25 08:19	02/06/25 13:59	1
Selenium	0.0081		0.0025		mg/L		02/05/25 08:19	02/06/25 13:59	1
Thallium	<0.0020		0.0020		mg/L		02/05/25 08:19	02/06/25 13:59	1
Lithium	<0.010	^5-	0.010		mg/L		02/05/25 08:19	02/06/25 13:59	1

Method: SW846 7470A - Mercury (CVAA)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	<0.00020		0.00020		mg/L		02/06/25 15:50	02/07/25 13:10	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride (EPA 300.0)	160		10		mg/L			02/06/25 20:09	10
Sulfate (EPA 300.0)	160		10		mg/L			02/06/25 20:09	10
Total Dissolved Solids (SM 2540C)	840		10		mg/L			02/07/25 01:59	1
Fluoride (SM 4500 F C)	0.35		0.10		mg/L			02/06/25 13:52	1

Client Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Client Sample ID: MW-14

Lab Sample ID: 500-263508-5

Date Collected: 02/04/25 13:33

Matrix: Water

Date Received: 02/04/25 16:30

Method: SW846 6020B - Metals (ICP/MS) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenic	0.0020		0.0010		mg/L		02/05/25 08:19	02/06/25 14:01	1
Boron	2.8		0.050		mg/L		02/05/25 08:19	02/07/25 12:48	1
Barium	0.14		0.0025		mg/L		02/05/25 08:19	02/06/25 14:01	1
Beryllium	<0.0010		0.0010		mg/L		02/05/25 08:19	02/07/25 12:48	1
Calcium	87		0.20		mg/L		02/05/25 08:19	02/06/25 14:01	1
Cadmium	<0.00050		0.00050		mg/L		02/05/25 08:19	02/06/25 14:01	1
Cobalt	<0.0010		0.0010		mg/L		02/05/25 08:19	02/06/25 14:01	1
Chromium	<0.0050		0.0050		mg/L		02/05/25 08:19	02/06/25 14:01	1
Molybdenum	0.075		0.0050		mg/L		02/05/25 08:19	02/06/25 14:01	1
Lead	<0.00050		0.00050		mg/L		02/05/25 08:19	02/06/25 14:01	1
Antimony	<0.0030		0.0030		mg/L		02/05/25 08:19	02/06/25 14:01	1
Selenium	<0.0025		0.0025		mg/L		02/05/25 08:19	02/06/25 14:01	1
Thallium	<0.0020		0.0020		mg/L		02/05/25 08:19	02/06/25 14:01	1
Lithium	0.019	^5-	0.010		mg/L		02/05/25 08:19	02/06/25 14:01	1

Method: SW846 7470A - Mercury (CVAA)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	<0.00020		0.00020		mg/L		02/06/25 15:50	02/07/25 13:13	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride (EPA 300.0)	130		1.0		mg/L			02/06/25 11:59	1
Sulfate (EPA 300.0)	390		10		mg/L			02/08/25 17:51	10
Total Dissolved Solids (SM 2540C)	930		10		mg/L			02/07/25 02:01	1
Fluoride (SM 4500 F C)	0.70		0.10		mg/L			02/06/25 13:56	1

Client Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Client Sample ID: 1N/1S Duplicate

Lab Sample ID: 500-263508-6

Date Collected: 02/04/25 00:00

Matrix: Water

Date Received: 02/04/25 16:30

Method: SW846 6020B - Metals (ICP/MS) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenic	0.0019		0.0010		mg/L		02/05/25 08:19	02/06/25 14:04	1
Boron	2.9	^5-	0.050		mg/L		02/05/25 08:19	02/14/25 01:18	1
Barium	0.11		0.0025		mg/L		02/05/25 08:19	02/06/25 14:04	1
Beryllium	<0.0010		0.0010		mg/L		02/05/25 08:19	02/07/25 13:01	1
Calcium	86		0.20		mg/L		02/05/25 08:19	02/06/25 14:04	1
Cadmium	<0.00050		0.00050		mg/L		02/05/25 08:19	02/06/25 14:04	1
Cobalt	<0.0010		0.0010		mg/L		02/05/25 08:19	02/06/25 14:04	1
Chromium	<0.0050		0.0050		mg/L		02/05/25 08:19	02/06/25 14:04	1
Molybdenum	0.073		0.0050		mg/L		02/05/25 08:19	02/06/25 14:04	1
Lead	<0.00050		0.00050		mg/L		02/05/25 08:19	02/06/25 14:04	1
Antimony	<0.0030		0.0030		mg/L		02/05/25 08:19	02/06/25 14:04	1
Selenium	<0.0025		0.0025		mg/L		02/05/25 08:19	02/06/25 14:04	1
Thallium	<0.0020		0.0020		mg/L		02/05/25 08:19	02/06/25 14:04	1
Lithium	0.019	^5-	0.010		mg/L		02/05/25 08:19	02/06/25 14:04	1

Method: SW846 7470A - Mercury (CVAA)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	<0.00020		0.00020		mg/L		02/06/25 15:50	02/07/25 13:15	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride (EPA 300.0)	130		1.0		mg/L			02/06/25 12:14	1
Sulfate (EPA 300.0)	410		10		mg/L			02/08/25 18:37	10
Total Dissolved Solids (SM 2540C)	960		10		mg/L			02/07/25 02:04	1
Fluoride (SM 4500 F C)	0.68		0.10		mg/L			02/06/25 14:01	1

Client Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Client Sample ID: MW-01

Lab Sample ID: 500-263508-7

Date Collected: 02/05/25 15:30

Matrix: Water

Date Received: 02/06/25 09:18

Method: SW846 6020B - Metals (ICP/MS) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenic	<0.0010		0.0010		mg/L		02/06/25 15:15	02/07/25 14:47	1
Boron	2.5		0.050		mg/L		02/06/25 15:15	02/10/25 17:59	1
Barium	0.063		0.0025		mg/L		02/06/25 15:15	02/07/25 14:47	1
Beryllium	<0.0010		0.0010		mg/L		02/06/25 15:15	02/07/25 14:47	1
Calcium	98		0.20		mg/L		02/06/25 15:15	02/07/25 14:47	1
Cadmium	<0.00050		0.00050		mg/L		02/06/25 15:15	02/07/25 14:47	1
Cobalt	<0.0010		0.0010		mg/L		02/06/25 15:15	02/07/25 14:47	1
Chromium	<0.0050		0.0050		mg/L		02/06/25 15:15	02/07/25 14:47	1
Molybdenum	0.060		0.0050		mg/L		02/06/25 15:15	02/07/25 14:47	1
Lead	<0.00050		0.00050		mg/L		02/06/25 15:15	02/07/25 14:47	1
Antimony	<0.0030		0.0030		mg/L		02/06/25 15:15	02/07/25 14:47	1
Selenium	0.0068		0.0025		mg/L		02/06/25 15:15	02/07/25 14:47	1
Thallium	<0.0020		0.0020		mg/L		02/06/25 15:15	02/07/25 14:47	1
Lithium	0.023		0.010		mg/L		02/06/25 15:15	02/07/25 14:47	1

Method: SW846 7470A - Mercury (CVAA)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	<0.00020		0.00020		mg/L		02/06/25 15:50	02/07/25 13:28	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride (EPA 300.0)	94		5.0		mg/L			02/08/25 18:52	5
Sulfate (EPA 300.0)	420		5.0		mg/L			02/08/25 18:52	5
Total Dissolved Solids (SM 2540C)	1000		10		mg/L			02/10/25 22:53	1
Fluoride (SM 4500 F C)	0.71		0.10		mg/L			02/07/25 11:50	1

Client Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Client Sample ID: MW-02

Lab Sample ID: 500-263508-8

Date Collected: 02/05/25 13:52

Matrix: Water

Date Received: 02/06/25 09:18

Method: SW846 6020B - Metals (ICP/MS) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenic	0.012		0.0010		mg/L		02/06/25 15:15	02/07/25 14:49	1
Boron	4.7		0.25		mg/L		02/06/25 15:15	02/10/25 17:19	5
Barium	0.059		0.0025		mg/L		02/06/25 15:15	02/07/25 14:49	1
Beryllium	<0.0010		0.0010		mg/L		02/06/25 15:15	02/07/25 14:49	1
Calcium	91		0.20		mg/L		02/06/25 15:15	02/07/25 14:49	1
Cadmium	<0.00050		0.00050		mg/L		02/06/25 15:15	02/07/25 14:49	1
Cobalt	<0.0010		0.0010		mg/L		02/06/25 15:15	02/07/25 14:49	1
Chromium	<0.0050		0.0050		mg/L		02/06/25 15:15	02/07/25 14:49	1
Molybdenum	0.072		0.0050		mg/L		02/06/25 15:15	02/07/25 14:49	1
Lead	<0.00050		0.00050		mg/L		02/06/25 15:15	02/07/25 14:49	1
Antimony	<0.0030		0.0030		mg/L		02/06/25 15:15	02/07/25 14:49	1
Selenium	<0.0025		0.0025		mg/L		02/06/25 15:15	02/07/25 14:49	1
Thallium	<0.0020		0.0020		mg/L		02/06/25 15:15	02/07/25 14:49	1
Lithium	0.044		0.010		mg/L		02/06/25 15:15	02/07/25 14:49	1

Method: SW846 7470A - Mercury (CVAA)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	<0.00020		0.00020		mg/L		02/06/25 15:50	02/07/25 13:30	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride (EPA 300.0)	36		1.0		mg/L			02/08/25 19:07	1
Sulfate (EPA 300.0)	430		10		mg/L			02/11/25 12:59	10
Total Dissolved Solids (SM 2540C)	1000		10		mg/L			02/10/25 22:59	1
Fluoride (SM 4500 F C)	0.33		0.10		mg/L			02/07/25 12:04	1

Client Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Client Sample ID: MW-03

Lab Sample ID: 500-263508-9

Date Collected: 02/05/25 12:49

Matrix: Water

Date Received: 02/06/25 09:18

Method: SW846 6020B - Metals (ICP/MS) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenic	<0.0010		0.0010		mg/L		02/06/25 15:15	02/07/25 14:52	1
Boron	2.9		0.050		mg/L		02/06/25 15:15	02/10/25 18:02	1
Barium	0.13		0.0025		mg/L		02/06/25 15:15	02/07/25 14:52	1
Beryllium	<0.0010		0.0010		mg/L		02/06/25 15:15	02/07/25 14:52	1
Calcium	210		0.20		mg/L		02/06/25 15:15	02/07/25 14:52	1
Cadmium	<0.00050		0.00050		mg/L		02/06/25 15:15	02/07/25 14:52	1
Cobalt	<0.0010		0.0010		mg/L		02/06/25 15:15	02/07/25 14:52	1
Chromium	<0.0050		0.0050		mg/L		02/06/25 15:15	02/07/25 14:52	1
Molybdenum	0.011		0.0050		mg/L		02/06/25 15:15	02/07/25 14:52	1
Lead	<0.00050		0.00050		mg/L		02/06/25 15:15	02/07/25 14:52	1
Antimony	<0.0030		0.0030		mg/L		02/06/25 15:15	02/07/25 14:52	1
Selenium	0.0061		0.0025		mg/L		02/06/25 15:15	02/07/25 14:52	1
Thallium	<0.0020		0.0020		mg/L		02/06/25 15:15	02/07/25 14:52	1
Lithium	0.034		0.010		mg/L		02/06/25 15:15	02/07/25 14:52	1

Method: SW846 7470A - Mercury (CVAA)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	<0.00020		0.00020		mg/L		02/06/25 15:50	02/07/25 13:33	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride (EPA 300.0)	16		1.0		mg/L			02/08/25 19:23	1
Sulfate (EPA 300.0)	390		10		mg/L			02/11/25 13:14	10
Total Dissolved Solids (SM 2540C)	1200		10		mg/L			02/10/25 23:01	1
Fluoride (SM 4500 F C)	0.23		0.10		mg/L			02/07/25 12:08	1

Client Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Client Sample ID: MW-04

Lab Sample ID: 500-263508-10

Date Collected: 02/05/25 11:15

Matrix: Water

Date Received: 02/06/25 09:18

Method: SW846 6020B - Metals (ICP/MS) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenic	0.0037		0.0010		mg/L		02/06/25 15:15	02/07/25 14:54	1
Boron	3.3		0.050		mg/L		02/06/25 15:15	02/10/25 18:06	1
Barium	0.054		0.0025		mg/L		02/06/25 15:15	02/07/25 14:54	1
Beryllium	<0.0010		0.0010		mg/L		02/06/25 15:15	02/07/25 14:54	1
Calcium	240		0.20		mg/L		02/06/25 15:15	02/07/25 14:54	1
Cadmium	<0.00050		0.00050		mg/L		02/06/25 15:15	02/07/25 14:54	1
Cobalt	0.0013		0.0010		mg/L		02/06/25 15:15	02/07/25 14:54	1
Chromium	<0.0050		0.0050		mg/L		02/06/25 15:15	02/07/25 14:54	1
Molybdenum	0.016		0.0050		mg/L		02/06/25 15:15	02/07/25 14:54	1
Lead	<0.00050		0.00050		mg/L		02/06/25 15:15	02/07/25 14:54	1
Antimony	<0.0030		0.0030		mg/L		02/06/25 15:15	02/07/25 14:54	1
Selenium	0.021		0.0025		mg/L		02/06/25 15:15	02/07/25 14:54	1
Thallium	<0.0020		0.0020		mg/L		02/06/25 15:15	02/07/25 14:54	1
Lithium	0.017		0.010		mg/L		02/06/25 15:15	02/07/25 14:54	1

Method: SW846 7470A - Mercury (CVAA)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	<0.00020		0.00020		mg/L		02/06/25 15:50	02/07/25 13:35	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride (EPA 300.0)	19		1.0		mg/L			02/08/25 19:38	1
Sulfate (EPA 300.0)	470		10		mg/L			02/11/25 14:00	10
Total Dissolved Solids (SM 2540C)	1300		10		mg/L			02/10/25 23:04	1
Fluoride (SM 4500 F C)	0.32		0.10		mg/L			02/07/25 12:13	1

Client Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Client Sample ID: MW-15

Lab Sample ID: 500-263508-11

Date Collected: 02/05/25 14:51

Matrix: Water

Date Received: 02/06/25 09:18

Method: SW846 6020B - Metals (ICP/MS) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenic	0.0075		0.0010		mg/L		02/06/25 15:15	02/07/25 14:57	1
Boron	3.8		0.050		mg/L		02/06/25 15:15	02/10/25 18:10	1
Barium	0.10		0.0025		mg/L		02/06/25 15:15	02/07/25 14:57	1
Beryllium	<0.0010		0.0010		mg/L		02/06/25 15:15	02/07/25 14:57	1
Calcium	210		0.20		mg/L		02/06/25 15:15	02/07/25 14:57	1
Cadmium	<0.00050		0.00050		mg/L		02/06/25 15:15	02/07/25 14:57	1
Cobalt	0.0010		0.0010		mg/L		02/06/25 15:15	02/07/25 14:57	1
Chromium	<0.0050		0.0050		mg/L		02/06/25 15:15	02/07/25 14:57	1
Molybdenum	0.014		0.0050		mg/L		02/06/25 15:15	02/07/25 14:57	1
Lead	<0.00050		0.00050		mg/L		02/06/25 15:15	02/07/25 14:57	1
Antimony	<0.0030		0.0030		mg/L		02/06/25 15:15	02/07/25 14:57	1
Selenium	<0.0025		0.0025		mg/L		02/06/25 15:15	02/07/25 14:57	1
Thallium	<0.0020		0.0020		mg/L		02/06/25 15:15	02/07/25 14:57	1
Lithium	0.027		0.010		mg/L		02/06/25 15:15	02/07/25 14:57	1

Method: SW846 7470A - Mercury (CVAA)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	<0.00020		0.00020		mg/L		02/06/25 15:50	02/07/25 13:37	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride (EPA 300.0)	120		10		mg/L			02/08/25 19:53	10
Sulfate (EPA 300.0)	660		10		mg/L			02/08/25 19:53	10
Total Dissolved Solids (SM 2540C)	1500		10		mg/L			02/10/25 23:06	1
Fluoride (SM 4500 F C)	0.37		0.10		mg/L			02/07/25 12:17	1

Definitions/Glossary

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Qualifiers

Metals

Qualifier	Qualifier Description
^5-	Linear Range Check (LRC) is outside acceptance limits, low biased.

General Chemistry

Qualifier	Qualifier Description
4	MS, MSD: The analyte present in the original sample is greater than 4 times the matrix spike concentration; therefore, control limits are not applicable.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

QC Association Summary

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Metals

Prep Batch: 805322

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-263508-1	MW-07	Total Recoverable	Water	3005A	
500-263508-2	MW-08	Total Recoverable	Water	3005A	
500-263508-3	MW-09	Total Recoverable	Water	3005A	
500-263508-4	MW-13	Total Recoverable	Water	3005A	
500-263508-5	MW-14	Total Recoverable	Water	3005A	
500-263508-6	1N/1S Duplicate	Total Recoverable	Water	3005A	
MB 500-805322/1-A	Method Blank	Total Recoverable	Water	3005A	
LCS 500-805322/2-A	Lab Control Sample	Total Recoverable	Water	3005A	

Analysis Batch: 805543

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-263508-1	MW-07	Total Recoverable	Water	6020B	805322
500-263508-2	MW-08	Total Recoverable	Water	6020B	805322
500-263508-3	MW-09	Total Recoverable	Water	6020B	805322
500-263508-4	MW-13	Total Recoverable	Water	6020B	805322
500-263508-5	MW-14	Total Recoverable	Water	6020B	805322
500-263508-6	1N/1S Duplicate	Total Recoverable	Water	6020B	805322
MB 500-805322/1-A	Method Blank	Total Recoverable	Water	6020B	805322
LCS 500-805322/2-A	Lab Control Sample	Total Recoverable	Water	6020B	805322

Prep Batch: 805549

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-263508-7	MW-01	Total Recoverable	Water	3005A	
500-263508-8	MW-02	Total Recoverable	Water	3005A	
500-263508-9	MW-03	Total Recoverable	Water	3005A	
500-263508-10	MW-04	Total Recoverable	Water	3005A	
500-263508-11	MW-15	Total Recoverable	Water	3005A	
MB 500-805549/1-A	Method Blank	Total Recoverable	Water	3005A	
LCS 500-805549/2-A	Lab Control Sample	Total Recoverable	Water	3005A	

Prep Batch: 805558

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-263508-1	MW-07	Total/NA	Water	7470A	
500-263508-2	MW-08	Total/NA	Water	7470A	
500-263508-3	MW-09	Total/NA	Water	7470A	
500-263508-4	MW-13	Total/NA	Water	7470A	
500-263508-5	MW-14	Total/NA	Water	7470A	
500-263508-6	1N/1S Duplicate	Total/NA	Water	7470A	
500-263508-7	MW-01	Total/NA	Water	7470A	
500-263508-8	MW-02	Total/NA	Water	7470A	
500-263508-9	MW-03	Total/NA	Water	7470A	
500-263508-10	MW-04	Total/NA	Water	7470A	
500-263508-11	MW-15	Total/NA	Water	7470A	
MB 500-805558/12-A	Method Blank	Total/NA	Water	7470A	
LCS 500-805558/13-A	Lab Control Sample	Total/NA	Water	7470A	
500-263508-6 MS	1N/1S Duplicate	Total/NA	Water	7470A	
500-263508-6 MSD	1N/1S Duplicate	Total/NA	Water	7470A	
500-263508-6 DU	1N/1S Duplicate	Total/NA	Water	7470A	

Eurofins Chicago

QC Association Summary

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Metals

Analysis Batch: 805702

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-263508-1	MW-07	Total/NA	Water	7470A	805558
500-263508-2	MW-08	Total/NA	Water	7470A	805558
500-263508-3	MW-09	Total/NA	Water	7470A	805558
500-263508-4	MW-13	Total/NA	Water	7470A	805558
500-263508-5	MW-14	Total/NA	Water	7470A	805558
500-263508-6	1N/1S Duplicate	Total/NA	Water	7470A	805558
500-263508-7	MW-01	Total/NA	Water	7470A	805558
500-263508-8	MW-02	Total/NA	Water	7470A	805558
500-263508-9	MW-03	Total/NA	Water	7470A	805558
500-263508-10	MW-04	Total/NA	Water	7470A	805558
500-263508-11	MW-15	Total/NA	Water	7470A	805558
MB 500-805558/12-A	Method Blank	Total/NA	Water	7470A	805558
LCS 500-805558/13-A	Lab Control Sample	Total/NA	Water	7470A	805558
500-263508-6 MS	1N/1S Duplicate	Total/NA	Water	7470A	805558
500-263508-6 MSD	1N/1S Duplicate	Total/NA	Water	7470A	805558
500-263508-6 DU	1N/1S Duplicate	Total/NA	Water	7470A	805558

Analysis Batch: 805839

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-263508-1	MW-07	Total Recoverable	Water	6020B	805322
500-263508-2	MW-08	Total Recoverable	Water	6020B	805322
500-263508-3	MW-09	Total Recoverable	Water	6020B	805322
500-263508-4	MW-13	Total Recoverable	Water	6020B	805322
500-263508-5	MW-14	Total Recoverable	Water	6020B	805322
500-263508-6	1N/1S Duplicate	Total Recoverable	Water	6020B	805322
500-263508-7	MW-01	Total Recoverable	Water	6020B	805549
500-263508-8	MW-02	Total Recoverable	Water	6020B	805549
500-263508-9	MW-03	Total Recoverable	Water	6020B	805549
500-263508-10	MW-04	Total Recoverable	Water	6020B	805549
500-263508-11	MW-15	Total Recoverable	Water	6020B	805549
MB 500-805322/1-A	Method Blank	Total Recoverable	Water	6020B	805322
MB 500-805549/1-A	Method Blank	Total Recoverable	Water	6020B	805549
LCS 500-805322/2-A	Lab Control Sample	Total Recoverable	Water	6020B	805322
LCS 500-805549/2-A	Lab Control Sample	Total Recoverable	Water	6020B	805549

Analysis Batch: 806049

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-263508-7	MW-01	Total Recoverable	Water	6020B	805549
500-263508-8	MW-02	Total Recoverable	Water	6020B	805549
500-263508-9	MW-03	Total Recoverable	Water	6020B	805549
500-263508-10	MW-04	Total Recoverable	Water	6020B	805549
500-263508-11	MW-15	Total Recoverable	Water	6020B	805549
MB 500-805549/1-A	Method Blank	Total Recoverable	Water	6020B	805549
LCS 500-805549/2-A	Lab Control Sample	Total Recoverable	Water	6020B	805549

Analysis Batch: 806557

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-263508-6	1N/1S Duplicate	Total Recoverable	Water	6020B	805322

QC Association Summary

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

General Chemistry

Analysis Batch: 805352

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-263508-5	MW-14	Total/NA	Water	300.0	
500-263508-6	1N/1S Duplicate	Total/NA	Water	300.0	
MB 500-805352/3	Method Blank	Total/NA	Water	300.0	
LCS 500-805352/4	Lab Control Sample	Total/NA	Water	300.0	
500-263508-6 MS	1N/1S Duplicate	Total/NA	Water	300.0	
500-263508-6 MSD	1N/1S Duplicate	Total/NA	Water	300.0	

Analysis Batch: 805463

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-263508-1	MW-07	Total/NA	Water	300.0	
500-263508-2	MW-08	Total/NA	Water	300.0	
500-263508-3	MW-09	Total/NA	Water	300.0	
500-263508-4	MW-13	Total/NA	Water	300.0	
MB 500-805463/3	Method Blank	Total/NA	Water	300.0	
LCS 500-805463/4	Lab Control Sample	Total/NA	Water	300.0	
500-263508-4 MS	MW-13	Total/NA	Water	300.0	
500-263508-4 MSD	MW-13	Total/NA	Water	300.0	

Analysis Batch: 805570

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-263508-1	MW-07	Total/NA	Water	SM 2540C	
500-263508-2	MW-08	Total/NA	Water	SM 2540C	
500-263508-3	MW-09	Total/NA	Water	SM 2540C	
500-263508-4	MW-13	Total/NA	Water	SM 2540C	
500-263508-5	MW-14	Total/NA	Water	SM 2540C	
500-263508-6	1N/1S Duplicate	Total/NA	Water	SM 2540C	
MB 500-805570/1	Method Blank	Total/NA	Water	SM 2540C	
LCS 500-805570/2	Lab Control Sample	Total/NA	Water	SM 2540C	

Analysis Batch: 805605

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-263508-1	MW-07	Total/NA	Water	SM 4500 F C	
500-263508-2	MW-08	Total/NA	Water	SM 4500 F C	
500-263508-3	MW-09	Total/NA	Water	SM 4500 F C	
500-263508-4	MW-13	Total/NA	Water	SM 4500 F C	
500-263508-5	MW-14	Total/NA	Water	SM 4500 F C	
500-263508-6	1N/1S Duplicate	Total/NA	Water	SM 4500 F C	
MB 500-805605/3	Method Blank	Total/NA	Water	SM 4500 F C	
LCS 500-805605/4	Lab Control Sample	Total/NA	Water	SM 4500 F C	

Analysis Batch: 805714

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-263508-7	MW-01	Total/NA	Water	SM 4500 F C	
500-263508-8	MW-02	Total/NA	Water	SM 4500 F C	
500-263508-9	MW-03	Total/NA	Water	SM 4500 F C	
500-263508-10	MW-04	Total/NA	Water	SM 4500 F C	
500-263508-11	MW-15	Total/NA	Water	SM 4500 F C	
MB 500-805714/3	Method Blank	Total/NA	Water	SM 4500 F C	
LCS 500-805714/4	Lab Control Sample	Total/NA	Water	SM 4500 F C	

Eurofins Chicago

QC Association Summary

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

General Chemistry

Analysis Batch: 805763

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-263508-1	MW-07	Total/NA	Water	300.0	
500-263508-2	MW-08	Total/NA	Water	300.0	
500-263508-5	MW-14	Total/NA	Water	300.0	
500-263508-6	1N/1S Duplicate	Total/NA	Water	300.0	
500-263508-7	MW-01	Total/NA	Water	300.0	
500-263508-8	MW-02	Total/NA	Water	300.0	
500-263508-9	MW-03	Total/NA	Water	300.0	
500-263508-10	MW-04	Total/NA	Water	300.0	
500-263508-11	MW-15	Total/NA	Water	300.0	
MB 500-805763/3	Method Blank	Total/NA	Water	300.0	
LCS 500-805763/4	Lab Control Sample	Total/NA	Water	300.0	

Analysis Batch: 806006

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-263508-7	MW-01	Total/NA	Water	SM 2540C	
500-263508-8	MW-02	Total/NA	Water	SM 2540C	
500-263508-9	MW-03	Total/NA	Water	SM 2540C	
500-263508-10	MW-04	Total/NA	Water	SM 2540C	
500-263508-11	MW-15	Total/NA	Water	SM 2540C	
MB 500-806006/1	Method Blank	Total/NA	Water	SM 2540C	
LCS 500-806006/2	Lab Control Sample	Total/NA	Water	SM 2540C	
500-263508-7 DU	MW-01	Total/NA	Water	SM 2540C	

Analysis Batch: 806052

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-263508-8	MW-02	Total/NA	Water	300.0	
500-263508-9	MW-03	Total/NA	Water	300.0	
500-263508-10	MW-04	Total/NA	Water	300.0	
MB 500-806052/3	Method Blank	Total/NA	Water	300.0	
LCS 500-806052/4	Lab Control Sample	Total/NA	Water	300.0	

QC Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Method: 6020B - Metals (ICP/MS)

Lab Sample ID: MB 500-805322/1-A

Matrix: Water

Analysis Batch: 805543

Client Sample ID: Method Blank

Prep Type: Total Recoverable

Prep Batch: 805322

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenic	<0.0010		0.0010		mg/L		02/05/25 08:19	02/06/25 13:33	1
Barium	<0.0025		0.0025		mg/L		02/05/25 08:19	02/06/25 13:33	1
Calcium	<0.20		0.20		mg/L		02/05/25 08:19	02/06/25 13:33	1
Cadmium	<0.00050		0.00050		mg/L		02/05/25 08:19	02/06/25 13:33	1
Cobalt	<0.0010		0.0010		mg/L		02/05/25 08:19	02/06/25 13:33	1
Chromium	<0.0050		0.0050		mg/L		02/05/25 08:19	02/06/25 13:33	1
Molybdenum	<0.0050		0.0050		mg/L		02/05/25 08:19	02/06/25 13:33	1
Lead	<0.00050		0.00050		mg/L		02/05/25 08:19	02/06/25 13:33	1
Antimony	<0.0030		0.0030		mg/L		02/05/25 08:19	02/06/25 13:33	1
Selenium	<0.0025		0.0025		mg/L		02/05/25 08:19	02/06/25 13:33	1
Thallium	<0.0020		0.0020		mg/L		02/05/25 08:19	02/06/25 13:33	1
Lithium	<0.010	^5-	0.010		mg/L		02/05/25 08:19	02/06/25 13:33	1

Lab Sample ID: MB 500-805322/1-A

Matrix: Water

Analysis Batch: 805839

Client Sample ID: Method Blank

Prep Type: Total Recoverable

Prep Batch: 805322

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Boron	<0.050		0.050		mg/L		02/05/25 08:19	02/07/25 12:26	1
Beryllium	<0.0010		0.0010		mg/L		02/05/25 08:19	02/07/25 12:26	1

Lab Sample ID: LCS 500-805322/2-A

Matrix: Water

Analysis Batch: 805543

Client Sample ID: Lab Control Sample

Prep Type: Total Recoverable

Prep Batch: 805322

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Arsenic	0.100	0.107		mg/L		107	80 - 120
Barium	0.500	0.551		mg/L		110	80 - 120
Calcium	10.0	9.58		mg/L		96	80 - 120
Cadmium	0.0500	0.0547		mg/L		109	80 - 120
Cobalt	0.500	0.549		mg/L		110	80 - 120
Chromium	0.200	0.216		mg/L		108	80 - 120
Molybdenum	1.00	1.05		mg/L		105	80 - 120
Lead	0.100	0.105		mg/L		105	80 - 120
Antimony	0.500	0.563		mg/L		113	80 - 120
Selenium	0.100	0.111		mg/L		111	80 - 120
Thallium	0.100	0.107		mg/L		107	80 - 120
Lithium	0.100	0.106	^5-	mg/L		106	80 - 120

Lab Sample ID: LCS 500-805322/2-A

Matrix: Water

Analysis Batch: 805839

Client Sample ID: Lab Control Sample

Prep Type: Total Recoverable

Prep Batch: 805322

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Boron	1.00	0.997		mg/L		100	80 - 120
Beryllium	0.0500	0.0514		mg/L		103	80 - 120

Eurofins Chicago

QC Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Method: 6020B - Metals (ICP/MS) (Continued)

Lab Sample ID: MB 500-805549/1-A

Matrix: Water

Analysis Batch: 805839

Client Sample ID: Method Blank

Prep Type: Total Recoverable

Prep Batch: 805549

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenic	<0.0010		0.0010		mg/L		02/06/25 15:15	02/07/25 13:03	1
Barium	<0.0025		0.0025		mg/L		02/06/25 15:15	02/07/25 13:03	1
Beryllium	<0.0010		0.0010		mg/L		02/06/25 15:15	02/07/25 13:03	1
Calcium	<0.20		0.20		mg/L		02/06/25 15:15	02/07/25 13:03	1
Cadmium	<0.00050		0.00050		mg/L		02/06/25 15:15	02/07/25 13:03	1
Cobalt	<0.0010		0.0010		mg/L		02/06/25 15:15	02/07/25 13:03	1
Chromium	<0.0050		0.0050		mg/L		02/06/25 15:15	02/07/25 13:03	1
Molybdenum	<0.0050		0.0050		mg/L		02/06/25 15:15	02/07/25 13:03	1
Lead	<0.00050		0.00050		mg/L		02/06/25 15:15	02/07/25 13:03	1
Antimony	<0.0030		0.0030		mg/L		02/06/25 15:15	02/07/25 13:03	1
Selenium	<0.0025		0.0025		mg/L		02/06/25 15:15	02/07/25 13:03	1
Thallium	<0.0020		0.0020		mg/L		02/06/25 15:15	02/07/25 13:03	1
Lithium	<0.010		0.010		mg/L		02/06/25 15:15	02/07/25 13:03	1

Lab Sample ID: MB 500-805549/1-A

Matrix: Water

Analysis Batch: 806049

Client Sample ID: Method Blank

Prep Type: Total Recoverable

Prep Batch: 805549

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Boron	<0.050		0.050		mg/L		02/06/25 15:15	02/10/25 16:36	1

Lab Sample ID: LCS 500-805549/2-A

Matrix: Water

Analysis Batch: 805839

Client Sample ID: Lab Control Sample

Prep Type: Total Recoverable

Prep Batch: 805549

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Arsenic	0.100	0.0993		mg/L		99	80 - 120
Barium	0.500	0.504		mg/L		101	80 - 120
Beryllium	0.0500	0.0492		mg/L		98	80 - 120
Calcium	10.0	8.42		mg/L		84	80 - 120
Cadmium	0.0500	0.0514		mg/L		103	80 - 120
Cobalt	0.500	0.511		mg/L		102	80 - 120
Chromium	0.200	0.208		mg/L		104	80 - 120
Molybdenum	1.00	0.981		mg/L		98	80 - 120
Lead	0.100	0.0984		mg/L		98	80 - 120
Antimony	0.500	0.519		mg/L		104	80 - 120
Selenium	0.100	0.0998		mg/L		100	80 - 120
Thallium	0.100	0.101		mg/L		101	80 - 120
Lithium	0.100	0.0977		mg/L		98	80 - 120

Lab Sample ID: LCS 500-805549/2-A

Matrix: Water

Analysis Batch: 806049

Client Sample ID: Lab Control Sample

Prep Type: Total Recoverable

Prep Batch: 805549

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Boron	1.00	0.928		mg/L		93	80 - 120

Eurofins Chicago

QC Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Method: 7470A - Mercury (CVAA)

Lab Sample ID: MB 500-805558/12-A
Matrix: Water
Analysis Batch: 805702

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 805558

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	<0.00020		0.00020		mg/L		02/06/25 15:50	02/07/25 12:35	1

Lab Sample ID: LCS 500-805558/13-A
Matrix: Water
Analysis Batch: 805702

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 805558

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Mercury	0.00200	0.00189		mg/L		95	80 - 120

Lab Sample ID: 500-263508-6 MS
Matrix: Water
Analysis Batch: 805702

Client Sample ID: 1N/1S Duplicate
Prep Type: Total/NA
Prep Batch: 805558

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Mercury	<0.00020		0.000999	0.000863		mg/L		86	75 - 125

Lab Sample ID: 500-263508-6 MSD
Matrix: Water
Analysis Batch: 805702

Client Sample ID: 1N/1S Duplicate
Prep Type: Total/NA
Prep Batch: 805558

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Mercury	<0.00020		0.000999	0.000839		mg/L		84	75 - 125	3	20

Lab Sample ID: 500-263508-6 DU
Matrix: Water
Analysis Batch: 805702

Client Sample ID: 1N/1S Duplicate
Prep Type: Total/NA
Prep Batch: 805558

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	RPD Limit
Mercury	<0.00020		<0.00020		mg/L		NC	20

Method: 300.0 - Anions, Ion Chromatography

Lab Sample ID: MB 500-805352/3
Matrix: Water
Analysis Batch: 805352

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	<1.0		1.0		mg/L			02/06/25 05:21	1

Lab Sample ID: LCS 500-805352/4
Matrix: Water
Analysis Batch: 805352

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Chloride	100	102		mg/L		102	90 - 110

QC Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Method: 300.0 - Anions, Ion Chromatography (Continued)

Lab Sample ID: 500-263508-6 MS

Matrix: Water

Analysis Batch: 805352

Client Sample ID: 1N/1S Duplicate

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Chloride	130		10.0	133	4	mg/L		76	80 - 120

Lab Sample ID: 500-263508-6 MSD

Matrix: Water

Analysis Batch: 805352

Client Sample ID: 1N/1S Duplicate

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Chloride	130		10.0	131	4	mg/L		52	80 - 120	2	20

Lab Sample ID: MB 500-805463/3

Matrix: Water

Analysis Batch: 805463

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	<1.0		1.0		mg/L			02/06/25 14:02	1
Sulfate	<1.0		1.0		mg/L			02/06/25 14:02	1

Lab Sample ID: LCS 500-805463/4

Matrix: Water

Analysis Batch: 805463

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Chloride	100	101		mg/L		101	90 - 110
Sulfate	100	104		mg/L		104	90 - 110

Lab Sample ID: 500-263508-4 MS

Matrix: Water

Analysis Batch: 805463

Client Sample ID: MW-13

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Chloride	160		100	252		mg/L		97	80 - 120
Sulfate	160		100	258		mg/L		101	80 - 120

Lab Sample ID: 500-263508-4 MSD

Matrix: Water

Analysis Batch: 805463

Client Sample ID: MW-13

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Chloride	160		100	255		mg/L		100	80 - 120	1	20
Sulfate	160		100	261		mg/L		104	80 - 120	1	20

Lab Sample ID: MB 500-805763/3

Matrix: Water

Analysis Batch: 805763

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	<1.0		1.0		mg/L			02/08/25 15:33	1
Sulfate	<1.0		1.0		mg/L			02/08/25 15:33	1

Eurofins Chicago

QC Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Method: 300.0 - Anions, Ion Chromatography (Continued)

Lab Sample ID: LCS 500-805763/4

Matrix: Water

Analysis Batch: 805763

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Chloride	100	98.8		mg/L		99	90 - 110
Sulfate	100	102		mg/L		102	90 - 110

Lab Sample ID: MB 500-806052/3

Matrix: Water

Analysis Batch: 806052

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Sulfate	<1.0		1.0		mg/L			02/11/25 10:57	1

Lab Sample ID: LCS 500-806052/4

Matrix: Water

Analysis Batch: 806052

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Sulfate	100	104		mg/L		104	90 - 110

Method: SM 2540C - Solids, Total Dissolved (TDS)

Lab Sample ID: MB 500-805570/1

Matrix: Water

Analysis Batch: 805570

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Dissolved Solids	<10		10		mg/L			02/07/25 01:23	1

Lab Sample ID: LCS 500-805570/2

Matrix: Water

Analysis Batch: 805570

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Total Dissolved Solids	250	260		mg/L		104	80 - 120

Lab Sample ID: MB 500-806006/1

Matrix: Water

Analysis Batch: 806006

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Dissolved Solids	<10		10		mg/L			02/10/25 22:41	1

Lab Sample ID: LCS 500-806006/2

Matrix: Water

Analysis Batch: 806006

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Total Dissolved Solids	250	252		mg/L		101	80 - 120

Eurofins Chicago

QC Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Method: SM 2540C - Solids, Total Dissolved (TDS) (Continued)

Lab Sample ID: 500-263508-7 DU

Matrix: Water

Analysis Batch: 806006

Client Sample ID: MW-01

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	RPD Limit
Total Dissolved Solids	1000		1080		mg/L		4	5

Method: SM 4500 F C - Fluoride

Lab Sample ID: MB 500-805605/3

Matrix: Water

Analysis Batch: 805605

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Fluoride	<0.10		0.10		mg/L			02/06/25 12:41	1

Lab Sample ID: LCS 500-805605/4

Matrix: Water

Analysis Batch: 805605

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Fluoride	10.0	9.87		mg/L		99	90 - 119

Lab Sample ID: MB 500-805714/3

Matrix: Water

Analysis Batch: 805714

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Fluoride	<0.10		0.10		mg/L			02/07/25 11:08	1

Lab Sample ID: LCS 500-805714/4

Matrix: Water

Analysis Batch: 805714

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Fluoride	10.0	10.0		mg/L		100	90 - 119

Eurofins Chicago

2417 Bond Street

University Park, IL 60484

Phone 708-534-5200 Fax 708-534-5211

Chain of Custody Record



Environment Testing

Client Information		Sampler: <u>Ian John Howison</u>		Lab PM: Mockler, Diana J		Carrier Tracking No(s):		COC No: 500-132928-45943 1							
Client Contact: Patrick Allenstein		Phone: <u>630 290 6850</u>		E-Mail: Diana.Mockler@et.eurofinsus.com		State of Origin:		Page 1 of 1							
Company: KPRG and Associates, Inc		PWSID:		Analysis Requested						Job #: <u>500-263508</u>					
Address: 14665 West Lisbon Road, Suite 1A City: Brookfield State Zip: WI, 53005 Phone: 500-263508 COC Email: patricka@kprginc.com		Due Date Requested		TAT Requested (days)		Compliance Project. ☐ Yes ☐ No		PO #: 4502187743		WO #:		Preservation Codes: D - HNO3 N - None			
Project Name: Will County 1N/1S Event Desc: Quarterly GW Monitoring <u>CCR</u>		Project #: 50011609		SSOW#:		Field Filtered Sample (Yes or No)		Perform MS/MSD (Yes or No)		Total Number of Containers		Other:			
Site: Illinois		Sample Date		Sample Time		Sample Type (C=comp, G=grab)		Matrix (W=water, S=solid, O=waste/oil, BT=tissue, A=air)		Field Filtered Sample (Yes or No)		Perform MS/MSD (Yes or No)		Special Instructions/Note:	
Sample Identification		Sample Date		Sample Time		Sample Type (C=comp, G=grab)		Matrix (W=water, S=solid, O=waste/oil, BT=tissue, A=air)		Field Filtered Sample (Yes or No)		Perform MS/MSD (Yes or No)		Special Instructions/Note:	
MW-01		—		—		—		Water		—		—		—	
MW-02		—		—		—		Water		—		—		—	
MW-03		—		—		—		Water		—		—		—	
MW-04		—		—		—		Water		—		—		—	
MW-07		2-4-25		12:29		G		Water		N		N		5	
MW-08		2-4-25		10:57		G		Water		N		N		5	
MW-09		2-4-25		09:10		G		Water		N		N		5	
MW-13		2-3-25		15:27		G		Water		N		N		5	
MW-14		2-4-25		13:33		G		Water		N		N		5	
MW-15		—		—		—		Water		—		—		—	
1N/1S Duplicate		2-4-25		—		G		Water		N		N		5	
Possible Hazard Identification ☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☐ Unknown ☐ Radiological										Sample Disposal (A fee may be assessed if samples are retained longer than 1 month) ☐ Return To Client ☐ Disposal By Lab ☐ Archive For Months					
Deliverable Requested I, II, III, IV, Other (specify)										Special Instructions/QC Requirements					
Empty Kit Relinquished by				Date		Time		Method of Shipment:							
Relinquished by: <u>[Signature]</u>				Date/Time: 2-4-25 16:30		Company: KPRG		Received by: <u>[Signature]</u>				Date/Time: 2/4/25 1630		Company: <u>[Signature]</u>	
Relinquished by:				Date/Time:		Company:		Received by:				Date/Time:		Company:	
Relinquished by:				Date/Time:		Company:		Received by:				Date/Time:		Company:	
Custody Seals Intact ☐ Yes ☐ No				Custody Seal No		Cooler Temperature(s) °C and Other Remarks: <u>3.4 → 3.3, 1.1 → 0.8</u>									

Eurofins Chicago

2417 Bond Street
University Park, IL 60484
Phone 708-534-5200 Fax 708-534-5211

Chain of Custody Record

eurofins | Environment Testing

Client Information		Sampler: <u>IAN JOHN HOWESON</u>		Lab PM: Mockler, Diana J		Carrier Tracking No(s)		COC No: 500-126448-45943 1			
Client Contact: Patrick Allenstein		Phone: <u>630-290-6850</u>		E-Mail: Diana Mockler@et.eurofins.com		State of Origin:		Page 1 of 1			
Company: KPRG and Associates, Inc		PWSID:		Analysis Requested						Job #: <u>500-26350 P</u>	
Address: 14665 West Lisbon Road, Suite 1A		Due Date Requested:		Field Filtered Sample (Yes or No) 903.0, 904.0 6010C, 6020A, 7470A 2540C, 4500_F_C, SM4500_Cl_E, SM4500_SO4_E Total Number of Containers						Preservation Codes	
City: Brookfield		TAT Requested (days):								D HNO3	
State Zip: WI, 53005		Compliance Project: ☐ Yes ☐ No								N None	
Phone: 500-263508 COC		PO #: 4502116506									
Email: patricka@kprginc.com		WO #:									
Project Name: Will County 1N/1S Event Desc Quarterly GW Monitoring <u>CCR</u>		Project #: 50011609								Other:	
Site: Illinois		SSOW#:									
Sample Identification		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)		Special Instructions/Note:	
7 MW-01		2-5-25		15:30		G		Water		5	
8 MW-02		2-5-25		13:52		G		Water		5	
9 MW-03		2-5-25		12:49		G		Water		5	
10 MW-04		2-5-25		11:15		G		Water		5	
MW-07		—		—		—		Water			
MW-08		—		—		—		Water			
MW-09		—		—		—		Water			
MW-13		—		—		—		Water			
MW-14		—		—		—		Water			
11 MW-15		2-5-25		1451		—		Water			
1N/1S Duplicate		—		—		—		Water			
Possible Hazard Identification										Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)	
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☐ Unknown ☐ Radiological										☐ Return To Client ☐ Disposal By Lab ☐ Archive For _____ Months	
Deliverable Requested I, II, III, IV, Other (specify)										Special Instructions/QC Requirements	
Empty Kit Relinquished by				Date		Time		Method of Shipment:			
Relinquished by: <u>[Signature]</u>				Date/Time: <u>2-5-25 09:18</u>		Company: <u>KPRG</u>		Received by: <u>Stephanie Hemondy</u>		Date/Time: <u>2/6/25 0918</u>	
Relinquished by:				Date/Time:		Company:		Received by:		Date/Time:	
Relinquished by:				Date/Time:		Company:		Received by:		Date/Time:	
Custody Seals Intact ☐ Yes ☐ No		Custody Seal No		Cooler Temperature(s) °C and Other Remarks: <u>-0.6 -7-0.2, -0.5 -7-0.8</u>							

Login Sample Receipt Checklist

Client: Midwest Generation EME LLC

Job Number: 500-263508-1

Login Number: 263508

List Source: Eurofins Chicago

List Number: 1

Creator: Scott, Sherri L

Question	Answer	Comment
Radioactivity wasn't checked or is $\leq$ background as measured by a survey meter.	True	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	3.3,0.8,-0.9,-0.8 samples not frozen
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is $<6\text{mm}$ (1/4").	N/A	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	

This receipt checklist is generated for all samples received in this Login. It may not be applicable to all Jobs associated with this Login.

Eurofins Chicago

Lab Chronicle

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Client Sample ID: MW-07

Date Collected: 02/04/25 12:29

Date Received: 02/04/25 16:30

Lab Sample ID: 500-263508-1

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total Recoverable	Prep	3005A			805322	BDE	EET CHI	02/05/25 08:19 - 02/05/25 14:19 ¹
Total Recoverable	Analysis	6020B		1	805543	RN	EET CHI	02/06/25 13:51
Total Recoverable	Prep	3005A			805322	BDE	EET CHI	02/05/25 08:19 - 02/05/25 14:19 ¹
Total Recoverable	Analysis	6020B		1	805839	RN	EET CHI	02/07/25 12:38
Total/NA	Prep	7470A			805558	S1Z	EET CHI	02/06/25 15:50 - 02/06/25 17:50 ¹
Total/NA	Analysis	7470A		1	805702	MJG	EET CHI	02/07/25 13:04
Total/NA	Analysis	300.0		1	805463	MM	EET CHI	02/06/25 18:52
Total/NA	Analysis	300.0		20	805763	MM	EET CHI	02/08/25 17:20
Total/NA	Analysis	SM 2540C		1	805570	CLB	EET CHI	02/07/25 01:51
Total/NA	Analysis	SM 4500 F C		1	805605	SO	EET CHI	02/06/25 13:39

Client Sample ID: MW-08

Date Collected: 02/04/25 10:57

Date Received: 02/04/25 16:30

Lab Sample ID: 500-263508-2

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total Recoverable	Prep	3005A			805322	BDE	EET CHI	02/05/25 08:19 - 02/05/25 14:19 ¹
Total Recoverable	Analysis	6020B		1	805543	RN	EET CHI	02/06/25 13:53
Total Recoverable	Prep	3005A			805322	BDE	EET CHI	02/05/25 08:19 - 02/05/25 14:19 ¹
Total Recoverable	Analysis	6020B		1	805839	RN	EET CHI	02/07/25 12:41
Total/NA	Prep	7470A			805558	S1Z	EET CHI	02/06/25 15:50 - 02/06/25 17:50 ¹
Total/NA	Analysis	7470A		1	805702	MJG	EET CHI	02/07/25 13:06
Total/NA	Analysis	300.0		1	805463	MM	EET CHI	02/06/25 19:07
Total/NA	Analysis	300.0		10	805763	MM	EET CHI	02/08/25 17:36
Total/NA	Analysis	SM 2540C		1	805570	CLB	EET CHI	02/07/25 01:54
Total/NA	Analysis	SM 4500 F C		1	805605	SO	EET CHI	02/06/25 13:43

Client Sample ID: MW-09

Date Collected: 02/04/25 09:10

Date Received: 02/04/25 16:30

Lab Sample ID: 500-263508-3

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total Recoverable	Prep	3005A			805322	BDE	EET CHI	02/05/25 08:19 - 02/05/25 14:19 ¹
Total Recoverable	Analysis	6020B		1	805543	RN	EET CHI	02/06/25 13:56
Total Recoverable	Prep	3005A			805322	BDE	EET CHI	02/05/25 08:19 - 02/05/25 14:19 ¹
Total Recoverable	Analysis	6020B		1	805839	RN	EET CHI	02/07/25 12:43
Total/NA	Prep	7470A			805558	S1Z	EET CHI	02/06/25 15:50 - 02/06/25 17:50 ¹
Total/NA	Analysis	7470A		1	805702	MJG	EET CHI	02/07/25 13:08
Total/NA	Analysis	300.0		10	805463	MM	EET CHI	02/06/25 19:23
Total/NA	Analysis	SM 2540C		1	805570	CLB	EET CHI	02/07/25 01:56
Total/NA	Analysis	SM 4500 F C		1	805605	SO	EET CHI	02/06/25 13:48

Eurofins Chicago

Lab Chronicle

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Client Sample ID: MW-13

Date Collected: 02/04/25 15:27

Date Received: 02/04/25 16:30

Lab Sample ID: 500-263508-4

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total Recoverable	Prep	3005A			805322	BDE	EET CHI	02/05/25 08:19 - 02/05/25 14:19 ¹
Total Recoverable	Analysis	6020B		1	805543	RN	EET CHI	02/06/25 13:59
Total Recoverable	Prep	3005A			805322	BDE	EET CHI	02/05/25 08:19 - 02/05/25 14:19 ¹
Total Recoverable	Analysis	6020B		1	805839	RN	EET CHI	02/07/25 12:46
Total/NA	Prep	7470A			805558	S1Z	EET CHI	02/06/25 15:50 - 02/06/25 17:50 ¹
Total/NA	Analysis	7470A		1	805702	MJG	EET CHI	02/07/25 13:10
Total/NA	Analysis	300.0		10	805463	MM	EET CHI	02/06/25 20:09
Total/NA	Analysis	SM 2540C		1	805570	CLB	EET CHI	02/07/25 01:59
Total/NA	Analysis	SM 4500 F C		1	805605	SO	EET CHI	02/06/25 13:52

Client Sample ID: MW-14

Date Collected: 02/04/25 13:33

Date Received: 02/04/25 16:30

Lab Sample ID: 500-263508-5

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total Recoverable	Prep	3005A			805322	BDE	EET CHI	02/05/25 08:19 - 02/05/25 14:19 ¹
Total Recoverable	Analysis	6020B		1	805543	RN	EET CHI	02/06/25 14:01
Total Recoverable	Prep	3005A			805322	BDE	EET CHI	02/05/25 08:19 - 02/05/25 14:19 ¹
Total Recoverable	Analysis	6020B		1	805839	RN	EET CHI	02/07/25 12:48
Total/NA	Prep	7470A			805558	S1Z	EET CHI	02/06/25 15:50 - 02/06/25 17:50 ¹
Total/NA	Analysis	7470A		1	805702	MJG	EET CHI	02/07/25 13:13
Total/NA	Analysis	300.0		1	805352	MM	EET CHI	02/06/25 11:59
Total/NA	Analysis	300.0		10	805763	MM	EET CHI	02/08/25 17:51
Total/NA	Analysis	SM 2540C		1	805570	CLB	EET CHI	02/07/25 02:01
Total/NA	Analysis	SM 4500 F C		1	805605	SO	EET CHI	02/06/25 13:56

Client Sample ID: 1N/1S Duplicate

Date Collected: 02/04/25 00:00

Date Received: 02/04/25 16:30

Lab Sample ID: 500-263508-6

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total Recoverable	Prep	3005A			805322	BDE	EET CHI	02/05/25 08:19 - 02/05/25 14:19 ¹
Total Recoverable	Analysis	6020B		1	806557	S1Z	EET CHI	02/14/25 01:18
Total Recoverable	Prep	3005A			805322	BDE	EET CHI	02/05/25 08:19 - 02/05/25 14:19 ¹
Total Recoverable	Analysis	6020B		1	805543	RN	EET CHI	02/06/25 14:04
Total Recoverable	Prep	3005A			805322	BDE	EET CHI	02/05/25 08:19 - 02/05/25 14:19 ¹
Total Recoverable	Analysis	6020B		1	805839	RN	EET CHI	02/07/25 13:01
Total/NA	Prep	7470A			805558	S1Z	EET CHI	02/06/25 15:50 - 02/06/25 17:50 ¹
Total/NA	Analysis	7470A		1	805702	MJG	EET CHI	02/07/25 13:15
Total/NA	Analysis	300.0		1	805352	MM	EET CHI	02/06/25 12:14
Total/NA	Analysis	300.0		10	805763	MM	EET CHI	02/08/25 18:37
Total/NA	Analysis	SM 2540C		1	805570	CLB	EET CHI	02/07/25 02:04
Total/NA	Analysis	SM 4500 F C		1	805605	SO	EET CHI	02/06/25 14:01

Eurofins Chicago

Lab Chronicle

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Client Sample ID: MW-01

Date Collected: 02/05/25 15:30

Date Received: 02/06/25 09:18

Lab Sample ID: 500-263508-7

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total Recoverable	Prep	3005A			805549	S1Z	EET CHI	02/06/25 15:15 - 02/06/25 21:15 ¹
Total Recoverable	Analysis	6020B		1	806049	S1Z	EET CHI	02/10/25 17:59
Total Recoverable	Prep	3005A			805549	S1Z	EET CHI	02/06/25 15:15 - 02/06/25 21:15 ¹
Total Recoverable	Analysis	6020B		1	805839	RN	EET CHI	02/07/25 14:47
Total/NA	Prep	7470A			805558	S1Z	EET CHI	02/06/25 15:50 - 02/06/25 17:50 ¹
Total/NA	Analysis	7470A		1	805702	MJG	EET CHI	02/07/25 13:28
Total/NA	Analysis	300.0		5	805763	MM	EET CHI	02/08/25 18:52
Total/NA	Analysis	SM 2540C		1	806006	CLB	EET CHI	02/10/25 22:53
Total/NA	Analysis	SM 4500 F C		1	805714	SO	EET CHI	02/07/25 11:50

Client Sample ID: MW-02

Date Collected: 02/05/25 13:52

Date Received: 02/06/25 09:18

Lab Sample ID: 500-263508-8

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total Recoverable	Prep	3005A			805549	S1Z	EET CHI	02/06/25 15:15 - 02/06/25 21:15 ¹
Total Recoverable	Analysis	6020B		5	806049	S1Z	EET CHI	02/10/25 17:19
Total Recoverable	Prep	3005A			805549	S1Z	EET CHI	02/06/25 15:15 - 02/06/25 21:15 ¹
Total Recoverable	Analysis	6020B		1	805839	RN	EET CHI	02/07/25 14:49
Total/NA	Prep	7470A			805558	S1Z	EET CHI	02/06/25 15:50 - 02/06/25 17:50 ¹
Total/NA	Analysis	7470A		1	805702	MJG	EET CHI	02/07/25 13:30
Total/NA	Analysis	300.0		1	805763	MM	EET CHI	02/08/25 19:07
Total/NA	Analysis	300.0		10	806052	MM	EET CHI	02/11/25 12:59
Total/NA	Analysis	SM 2540C		1	806006	CLB	EET CHI	02/10/25 22:59
Total/NA	Analysis	SM 4500 F C		1	805714	SO	EET CHI	02/07/25 12:04

Client Sample ID: MW-03

Date Collected: 02/05/25 12:49

Date Received: 02/06/25 09:18

Lab Sample ID: 500-263508-9

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total Recoverable	Prep	3005A			805549	S1Z	EET CHI	02/06/25 15:15 - 02/06/25 21:15 ¹
Total Recoverable	Analysis	6020B		1	806049	S1Z	EET CHI	02/10/25 18:02
Total Recoverable	Prep	3005A			805549	S1Z	EET CHI	02/06/25 15:15 - 02/06/25 21:15 ¹
Total Recoverable	Analysis	6020B		1	805839	RN	EET CHI	02/07/25 14:52
Total/NA	Prep	7470A			805558	S1Z	EET CHI	02/06/25 15:50 - 02/06/25 17:50 ¹
Total/NA	Analysis	7470A		1	805702	MJG	EET CHI	02/07/25 13:33
Total/NA	Analysis	300.0		1	805763	MM	EET CHI	02/08/25 19:23
Total/NA	Analysis	300.0		10	806052	MM	EET CHI	02/11/25 13:14
Total/NA	Analysis	SM 2540C		1	806006	CLB	EET CHI	02/10/25 23:01
Total/NA	Analysis	SM 4500 F C		1	805714	SO	EET CHI	02/07/25 12:08

Eurofins Chicago

Lab Chronicle

Client: Midwest Generation EME LLC
Project/Site: Will County CCR

Job ID: 500-263508-1

Client Sample ID: MW-04

Date Collected: 02/05/25 11:15

Date Received: 02/06/25 09:18

Lab Sample ID: 500-263508-10

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total Recoverable	Prep	3005A			805549	S1Z	EET CHI	02/06/25 15:15 - 02/06/25 21:15 ¹
Total Recoverable	Analysis	6020B		1	806049	S1Z	EET CHI	02/10/25 18:06
Total Recoverable	Prep	3005A			805549	S1Z	EET CHI	02/06/25 15:15 - 02/06/25 21:15 ¹
Total Recoverable	Analysis	6020B		1	805839	RN	EET CHI	02/07/25 14:54
Total/NA	Prep	7470A			805558	S1Z	EET CHI	02/06/25 15:50 - 02/06/25 17:50 ¹
Total/NA	Analysis	7470A		1	805702	MJG	EET CHI	02/07/25 13:35
Total/NA	Analysis	300.0		1	805763	MM	EET CHI	02/08/25 19:38
Total/NA	Analysis	300.0		10	806052	MM	EET CHI	02/11/25 14:00
Total/NA	Analysis	SM 2540C		1	806006	CLB	EET CHI	02/10/25 23:04
Total/NA	Analysis	SM 4500 F C		1	805714	SO	EET CHI	02/07/25 12:13

Client Sample ID: MW-15

Date Collected: 02/05/25 14:51

Date Received: 02/06/25 09:18

Lab Sample ID: 500-263508-11

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total Recoverable	Prep	3005A			805549	S1Z	EET CHI	02/06/25 15:15 - 02/06/25 21:15 ¹
Total Recoverable	Analysis	6020B		1	806049	S1Z	EET CHI	02/10/25 18:10
Total Recoverable	Prep	3005A			805549	S1Z	EET CHI	02/06/25 15:15 - 02/06/25 21:15 ¹
Total Recoverable	Analysis	6020B		1	805839	RN	EET CHI	02/07/25 14:57
Total/NA	Prep	7470A			805558	S1Z	EET CHI	02/06/25 15:50 - 02/06/25 17:50 ¹
Total/NA	Analysis	7470A		1	805702	MJG	EET CHI	02/07/25 13:37
Total/NA	Analysis	300.0		10	805763	MM	EET CHI	02/08/25 19:53
Total/NA	Analysis	SM 2540C		1	806006	CLB	EET CHI	02/10/25 23:06
Total/NA	Analysis	SM 4500 F C		1	805714	SO	EET CHI	02/07/25 12:17

¹ This procedure uses a method stipulated length of time for the process. Both start and end times are displayed.

Laboratory References:

EET CHI = Eurofins Chicago, 2417 Bond Street, University Park, IL 60484, TEL (708)534-5200

ANALYTICAL REPORT

PREPARED FOR

Attn: James Thorne
Midwest Generation EME LLC
1800 Channahon Road
Joliet, Illinois 60436

Generated 3/10/2025 3:28:45 PM

JOB DESCRIPTION

Will County CCR (RAD)

JOB NUMBER

500-263508-2

Eurofins Chicago

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Chicago Project Manager.

Authorization



Generated
3/10/2025 3:28:45 PM

Authorized for release by
Diana Mockler, Project Manager I
Diana.Mockler@et.eurofinsus.com
(219)252-7570



Table of Contents

Cover Page	1
Table of Contents	3
Case Narrative	4
Method Summary	5
Sample Summary	6
Client Sample Results	7
Definitions	18
QC Association	19
QC Sample Results	20
Chain of Custody	24
Receipt Checklists	27
Chronicle	30
Tracer Carrier Summary	33

Case Narrative

Client: Midwest Generation EME LLC
Project: Will County CCR (RAD)

Job ID: 500-263508-2

Job ID: 500-263508-2

Eurofins Chicago

Job Narrative 500-263508-2

Receipt

The samples were received on 02/04/25 16:30 and 02/06/25 09:18. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperatures of the 4 coolers at receipt time were -0.9°C, -0.8°C, 0.8°C and 3.3°C.

Gas Flow Proportional Counter

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Rad

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Chicago

Method Summary

Client: Midwest Generation EME LLC
Project/Site: Will County CCR (RAD)

Job ID: 500-263508-2

Method	Method Description	Protocol	Laboratory
903.0	Radium-226 (GFPC)	EPA	EET SL
904.0	Radium-228 (GFPC)	EPA	EET SL
Ra226_Ra228	Combined Radium-226 and Radium-228	TAL-STL	EET SL
PrecSep_0	Preparation, Precipitate Separation	None	EET SL
PrecSep-21	Preparation, Precipitate Separation (21-Day In-Growth)	None	EET SL

Protocol References:

EPA = US Environmental Protection Agency

None = None

TAL-STL = TestAmerica Laboratories, St. Louis, Facility Standard Operating Procedure.

Laboratory References:

EET SL = Eurofins St. Louis, 13715 Rider Trail North, Earth City, MO 63045, TEL (314)298-8566

Sample Summary

Client: Midwest Generation EME LLC
Project/Site: Will County CCR (RAD)

Job ID: 500-263508-2

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
500-263508-1	MW-07	Water	02/04/25 12:29	02/04/25 16:30
500-263508-2	MW-08	Water	02/04/25 10:57	02/04/25 16:30
500-263508-3	MW-09	Water	02/04/25 09:10	02/04/25 16:30
500-263508-4	MW-13	Water	02/04/25 15:27	02/04/25 16:30
500-263508-5	MW-14	Water	02/04/25 13:33	02/04/25 16:30
500-263508-6	1N/1S Duplicate	Water	02/04/25 00:00	02/04/25 16:30
500-263508-7	MW-01	Water	02/05/25 15:30	02/06/25 09:18
500-263508-8	MW-02	Water	02/05/25 13:52	02/06/25 09:18
500-263508-9	MW-03	Water	02/05/25 12:49	02/06/25 09:18
500-263508-10	MW-04	Water	02/05/25 11:15	02/06/25 09:18
500-263508-11	MW-15	Water	02/05/25 14:51	02/06/25 09:18

Client Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR (RAD)

Job ID: 500-263508-2

Client Sample ID: MW-07

Lab Sample ID: 500-263508-1

Date Collected: 02/04/25 12:29

Matrix: Water

Date Received: 02/04/25 16:30

Method: EPA 903.0 - Radium-226 (GFPC)

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-226	0.254		0.117	0.119	1.00	0.133	pCi/L	02/10/25 08:58	03/04/25 07:45	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	88.5		30 - 110					02/10/25 08:58	03/04/25 07:45	1

Method: EPA 904.0 - Radium-228 (GFPC)

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-228	0.776		0.489	0.494	1.00	0.710	pCi/L	02/10/25 09:01	02/27/25 14:40	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	88.5		30 - 110					02/10/25 09:01	02/27/25 14:40	1
Y Carrier	80.7		30 - 110					02/10/25 09:01	02/27/25 14:40	1

Method: TAL-STL Ra226_Ra228 - Combined Radium-226 and Radium-228

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Combined Radium 226 + 228	1.03		0.503	0.508	5.00	0.710	pCi/L		03/10/25 12:01	1

Client Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR (RAD)

Job ID: 500-263508-2

Client Sample ID: MW-08

Lab Sample ID: 500-263508-2

Date Collected: 02/04/25 10:57

Matrix: Water

Date Received: 02/04/25 16:30

Method: EPA 903.0 - Radium-226 (GFPC)

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-226	0.0991	U	0.0841	0.0846	1.00	0.123	pCi/L	02/10/25 08:58	03/04/25 07:46	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	89.0		30 - 110					02/10/25 08:58	03/04/25 07:46	1

Method: EPA 904.0 - Radium-228 (GFPC)

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-228	-0.0316	U	0.386	0.386	1.00	0.739	pCi/L	02/10/25 09:01	02/27/25 14:40	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	89.0		30 - 110					02/10/25 09:01	02/27/25 14:40	1
Y Carrier	78.5		30 - 110					02/10/25 09:01	02/27/25 14:40	1

Method: TAL-STL Ra226_Ra228 - Combined Radium-226 and Radium-228

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Combined Radium 226 + 228	0.0675	U	0.395	0.395	5.00	0.739	pCi/L		03/10/25 12:01	1

Client Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR (RAD)

Job ID: 500-263508-2

Client Sample ID: MW-09

Lab Sample ID: 500-263508-3

Date Collected: 02/04/25 09:10

Matrix: Water

Date Received: 02/04/25 16:30

Method: EPA 903.0 - Radium-226 (GFPC)

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-226	0.0582	U	0.0749	0.0750	1.00	0.124	pCi/L	02/10/25 08:58	03/04/25 09:39	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	87.2		30 - 110					02/10/25 08:58	03/04/25 09:39	1

Method: EPA 904.0 - Radium-228 (GFPC)

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-228	0.681	U	0.557	0.561	1.00	0.873	pCi/L	02/10/25 09:01	02/27/25 14:40	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	87.2		30 - 110					02/10/25 09:01	02/27/25 14:40	1
Y Carrier	80.0		30 - 110					02/10/25 09:01	02/27/25 14:40	1

Method: TAL-STL Ra226_Ra228 - Combined Radium-226 and Radium-228

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Combined Radium 226 + 228	0.739	U	0.562	0.566	5.00	0.873	pCi/L		03/10/25 12:01	1

Client Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR (RAD)

Job ID: 500-263508-2

Client Sample ID: MW-13

Lab Sample ID: 500-263508-4

Date Collected: 02/04/25 15:27

Matrix: Water

Date Received: 02/04/25 16:30

Method: EPA 903.0 - Radium-226 (GFPC)

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-226	0.122	U	0.112	0.113	1.00	0.170	pCi/L	02/11/25 07:12	03/05/25 10:24	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	78.6		30 - 110					02/11/25 07:12	03/05/25 10:24	1

Method: EPA 904.0 - Radium-228 (GFPC)

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-228	0.654	U	0.561	0.564	1.00	0.884	pCi/L	02/11/25 07:15	02/27/25 12:17	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	78.6		30 - 110					02/11/25 07:15	02/27/25 12:17	1
Y Carrier	86.0		30 - 110					02/11/25 07:15	02/27/25 12:17	1

Method: TAL-STL Ra226_Ra228 - Combined Radium-226 and Radium-228

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Combined Radium 226 + 228	0.775	U	0.572	0.575	5.00	0.884	pCi/L		03/06/25 11:20	1

Client Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR (RAD)

Job ID: 500-263508-2

Client Sample ID: MW-14

Lab Sample ID: 500-263508-5

Date Collected: 02/04/25 13:33

Matrix: Water

Date Received: 02/04/25 16:30

Method: EPA 903.0 - Radium-226 (GFPC)

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-226	0.588		0.164	0.172	1.00	0.124	pCi/L	02/11/25 07:12	03/05/25 10:24	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	76.5		30 - 110					02/11/25 07:12	03/05/25 10:24	1

Method: EPA 904.0 - Radium-228 (GFPC)

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-228	0.569	U	0.461	0.464	1.00	0.719	pCi/L	02/11/25 07:15	02/27/25 12:17	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	76.5		30 - 110					02/11/25 07:15	02/27/25 12:17	1
Y Carrier	81.9		30 - 110					02/11/25 07:15	02/27/25 12:17	1

Method: TAL-STL Ra226_Ra228 - Combined Radium-226 and Radium-228

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Combined Radium 226 + 228	1.16		0.489	0.495	5.00	0.719	pCi/L		03/06/25 11:20	1

Client Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR (RAD)

Job ID: 500-263508-2

Client Sample ID: 1N/1S Duplicate

Lab Sample ID: 500-263508-6

Date Collected: 02/04/25 00:00

Matrix: Water

Date Received: 02/04/25 16:30

Method: EPA 903.0 - Radium-226 (GFPC)

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-226	0.391		0.129	0.133	1.00	0.112	pCi/L	02/11/25 07:12	03/05/25 10:24	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	88.3		30 - 110					02/11/25 07:12	03/05/25 10:24	1

Method: EPA 904.0 - Radium-228 (GFPC)

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-228	0.807		0.428	0.434	1.00	0.604	pCi/L	02/11/25 07:15	02/27/25 12:18	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	88.3		30 - 110					02/11/25 07:15	02/27/25 12:18	1
Y Carrier	79.3		30 - 110					02/11/25 07:15	02/27/25 12:18	1

Method: TAL-STL Ra226_Ra228 - Combined Radium-226 and Radium-228

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Combined Radium 226 + 228	1.20		0.447	0.454	5.00	0.604	pCi/L		03/06/25 11:20	1

Client Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR (RAD)

Job ID: 500-263508-2

Client Sample ID: MW-01

Lab Sample ID: 500-263508-7

Date Collected: 02/05/25 15:30

Matrix: Water

Date Received: 02/06/25 09:18

Method: EPA 903.0 - Radium-226 (GFPC)

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-226	0.251		0.111	0.113	1.00	0.124	pCi/L	02/11/25 07:12	03/05/25 10:25	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	87.0		30 - 110					02/11/25 07:12	03/05/25 10:25	1

Method: EPA 904.0 - Radium-228 (GFPC)

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-228	0.907		0.419	0.427	1.00	0.564	pCi/L	02/11/25 07:15	02/27/25 12:18	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	87.0		30 - 110					02/11/25 07:15	02/27/25 12:18	1
Y Carrier	83.0		30 - 110					02/11/25 07:15	02/27/25 12:18	1

Method: TAL-STL Ra226_Ra228 - Combined Radium-226 and Radium-228

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Combined Radium 226 + 228	1.16		0.433	0.442	5.00	0.564	pCi/L		03/06/25 11:20	1

Client Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR (RAD)

Job ID: 500-263508-2

Client Sample ID: MW-02

Lab Sample ID: 500-263508-8

Date Collected: 02/05/25 13:52

Matrix: Water

Date Received: 02/06/25 09:18

Method: EPA 903.0 - Radium-226 (GFPC)

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-226	0.414		0.143	0.148	1.00	0.144	pCi/L	02/11/25 07:12	03/05/25 10:25	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	91.3		30 - 110					02/11/25 07:12	03/05/25 10:25	1

Method: EPA 904.0 - Radium-228 (GFPC)

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-228	0.754		0.395	0.401	1.00	0.554	pCi/L	02/11/25 07:15	02/27/25 12:18	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	91.3		30 - 110					02/11/25 07:15	02/27/25 12:18	1
Y Carrier	81.9		30 - 110					02/11/25 07:15	02/27/25 12:18	1

Method: TAL-STL Ra226_Ra228 - Combined Radium-226 and Radium-228

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Combined Radium 226 + 228	1.17		0.420	0.427	5.00	0.554	pCi/L		03/06/25 11:20	1

Client Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR (RAD)

Job ID: 500-263508-2

Client Sample ID: MW-03

Lab Sample ID: 500-263508-9

Date Collected: 02/05/25 12:49

Matrix: Water

Date Received: 02/06/25 09:18

Method: EPA 903.0 - Radium-226 (GFPC)

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-226	0.348		0.175	0.178	1.00	0.225	pCi/L	02/13/25 08:06	03/07/25 17:45	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	82.8		30 - 110					02/13/25 08:06	03/07/25 17:45	1

Method: EPA 904.0 - Radium-228 (GFPC)

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-228	0.718	U	0.579	0.583	1.00	0.907	pCi/L	02/13/25 08:09	03/04/25 14:44	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	82.8		30 - 110					02/13/25 08:09	03/04/25 14:44	1
Y Carrier	81.5		30 - 110					02/13/25 08:09	03/04/25 14:44	1

Method: TAL-STL Ra226_Ra228 - Combined Radium-226 and Radium-228

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Combined Radium 226 + 228	1.07		0.605	0.610	5.00	0.907	pCi/L		03/10/25 12:00	1

Client Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR (RAD)

Job ID: 500-263508-2

Client Sample ID: MW-04

Lab Sample ID: 500-263508-10

Date Collected: 02/05/25 11:15

Matrix: Water

Date Received: 02/06/25 09:18

Method: EPA 903.0 - Radium-226 (GFPC)

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-226	0.522		0.152	0.159	1.00	0.136	pCi/L	02/11/25 07:12	03/05/25 10:25	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	85.2		30 - 110					02/11/25 07:12	03/05/25 10:25	1

Method: EPA 904.0 - Radium-228 (GFPC)

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-228	1.30		0.448	0.464	1.00	0.521	pCi/L	02/11/25 07:15	02/27/25 12:18	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	85.2		30 - 110					02/11/25 07:15	02/27/25 12:18	1
Y Carrier	82.2		30 - 110					02/11/25 07:15	02/27/25 12:18	1

Method: TAL-STL Ra226_Ra228 - Combined Radium-226 and Radium-228

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Combined Radium 226 + 228	1.82		0.473	0.490	5.00	0.521	pCi/L		03/06/25 11:20	1

Client Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR (RAD)

Job ID: 500-263508-2

Client Sample ID: MW-15

Lab Sample ID: 500-263508-11

Date Collected: 02/05/25 14:51

Matrix: Water

Date Received: 02/06/25 09:18

Method: EPA 903.0 - Radium-226 (GFPC)

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-226	0.395		0.149	0.154	1.00	0.174	pCi/L	02/11/25 07:12	03/05/25 10:25	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	85.2		30 - 110					02/11/25 07:12	03/05/25 10:25	1

Method: EPA 904.0 - Radium-228 (GFPC)

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-228	0.865		0.408	0.416	1.00	0.541	pCi/L	02/11/25 07:15	02/27/25 12:18	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	85.2		30 - 110					02/11/25 07:15	02/27/25 12:18	1
Y Carrier	79.6		30 - 110					02/11/25 07:15	02/27/25 12:18	1

Method: TAL-STL Ra226_Ra228 - Combined Radium-226 and Radium-228

Analyte	Result	Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Combined Radium 226 + 228	1.26		0.434	0.444	5.00	0.541	pCi/L		03/06/25 11:20	1

Definitions/Glossary

Client: Midwest Generation EME LLC
Project/Site: Will County CCR (RAD)

Job ID: 500-263508-2

Qualifiers

Rad

Qualifier	Qualifier Description
U	Result is less than the sample detection limit.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

QC Association Summary

Client: Midwest Generation EME LLC
Project/Site: Will County CCR (RAD)

Job ID: 500-263508-2

Rad

Prep Batch: 702255

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-263508-1	MW-07	Total/NA	Water	PrecSep-21	
500-263508-2	MW-08	Total/NA	Water	PrecSep-21	
500-263508-3	MW-09	Total/NA	Water	PrecSep-21	
MB 160-702255/1-A	Method Blank	Total/NA	Water	PrecSep-21	
LCS 160-702255/2-A	Lab Control Sample	Total/NA	Water	PrecSep-21	

Prep Batch: 702256

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-263508-1	MW-07	Total/NA	Water	PrecSep_0	
500-263508-2	MW-08	Total/NA	Water	PrecSep_0	
500-263508-3	MW-09	Total/NA	Water	PrecSep_0	
MB 160-702256/1-A	Method Blank	Total/NA	Water	PrecSep_0	
LCS 160-702256/2-A	Lab Control Sample	Total/NA	Water	PrecSep_0	

Prep Batch: 702327

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-263508-4	MW-13	Total/NA	Water	PrecSep-21	
500-263508-5	MW-14	Total/NA	Water	PrecSep-21	
500-263508-6	1N/1S Duplicate	Total/NA	Water	PrecSep-21	
500-263508-7	MW-01	Total/NA	Water	PrecSep-21	
500-263508-8	MW-02	Total/NA	Water	PrecSep-21	
500-263508-10	MW-04	Total/NA	Water	PrecSep-21	
500-263508-11	MW-15	Total/NA	Water	PrecSep-21	
MB 160-702327/1-A	Method Blank	Total/NA	Water	PrecSep-21	
LCS 160-702327/2-A	Lab Control Sample	Total/NA	Water	PrecSep-21	
500-263508-6 DU	1N/1S Duplicate	Total/NA	Water	PrecSep-21	

Prep Batch: 702328

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-263508-4	MW-13	Total/NA	Water	PrecSep_0	
500-263508-5	MW-14	Total/NA	Water	PrecSep_0	
500-263508-6	1N/1S Duplicate	Total/NA	Water	PrecSep_0	
500-263508-7	MW-01	Total/NA	Water	PrecSep_0	
500-263508-8	MW-02	Total/NA	Water	PrecSep_0	
500-263508-10	MW-04	Total/NA	Water	PrecSep_0	
500-263508-11	MW-15	Total/NA	Water	PrecSep_0	
MB 160-702328/1-A	Method Blank	Total/NA	Water	PrecSep_0	
LCS 160-702328/2-A	Lab Control Sample	Total/NA	Water	PrecSep_0	
500-263508-6 DU	1N/1S Duplicate	Total/NA	Water	PrecSep_0	

Prep Batch: 702743

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-263508-9	MW-03	Total/NA	Water	PrecSep-21	
MB 160-702743/1-A	Method Blank	Total/NA	Water	PrecSep-21	
LCS 160-702743/2-A	Lab Control Sample	Total/NA	Water	PrecSep-21	

Prep Batch: 702744

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
500-263508-9	MW-03	Total/NA	Water	PrecSep_0	
MB 160-702744/1-A	Method Blank	Total/NA	Water	PrecSep_0	
LCS 160-702744/2-A	Lab Control Sample	Total/NA	Water	PrecSep_0	

Eurofins Chicago

QC Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR (RAD)

Job ID: 500-263508-2

Method: 903.0 - Radium-226 (GFPC)

Lab Sample ID: MB 160-702255/1-A

Matrix: Water

Analysis Batch: 705883

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 702255

Analyte	MB Result	MB Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-226	-0.03631	U	0.0530	0.0531	1.00	0.134	pCi/L	02/10/25 08:58	03/04/25 07:48	1
Carrier	MB %Yield	MB Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	91.1		30 - 110					02/10/25 08:58	03/04/25 07:48	1

Lab Sample ID: LCS 160-702255/2-A

Matrix: Water

Analysis Batch: 705883

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 702255

Analyte		Spike Added	LCS Result	LCS Qual	Total Uncert. (2σ+/-)	RL	MDC	Unit	%Rec	%Rec Limits
Radium-226		9.58	9.309		1.02	1.00	0.130	pCi/L	97	75 - 125
Carrier	LCS %Yield	LCS Qualifier	Limits							
Ba Carrier	90.6		30 - 110							

Lab Sample ID: MB 160-702327/1-A

Matrix: Water

Analysis Batch: 706177

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 702327

Analyte	MB Result	MB Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-226	-0.009114	U	0.0607	0.0607	1.00	0.132	pCi/L	02/11/25 07:12	03/05/25 07:37	1
Carrier	MB %Yield	MB Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	82.7		30 - 110					02/11/25 07:12	03/05/25 07:37	1

Lab Sample ID: LCS 160-702327/2-A

Matrix: Water

Analysis Batch: 706177

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 702327

Analyte		Spike Added	LCS Result	LCS Qual	Total Uncert. (2σ+/-)	RL	MDC	Unit	%Rec	%Rec Limits
Radium-226		9.58	9.284		1.02	1.00	0.163	pCi/L	97	75 - 125
Carrier	LCS %Yield	LCS Qualifier	Limits							
Ba Carrier	85.7		30 - 110							

Lab Sample ID: 500-263508-6 DU

Matrix: Water

Analysis Batch: 706176

Client Sample ID: 1N/1S Duplicate

Prep Type: Total/NA

Prep Batch: 702327

Analyte	Sample Result	Sample Qual	DU Result	DU Qual	Total Uncert. (2σ+/-)	RL	MDC	Unit	RER	RER Limit
Radium-226	0.391		0.4474		0.158	1.00	0.163	pCi/L	0.19	1

Eurofins Chicago

QC Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR (RAD)

Job ID: 500-263508-2

Method: 903.0 - Radium-226 (GFPC) (Continued)

Lab Sample ID: 500-263508-6 DU

Matrix: Water

Analysis Batch: 706176

Client Sample ID: 1N/1S Duplicate

Prep Type: Total/NA

Prep Batch: 702327

	DU	DU	
Carrier	%Yield	Qualifier	Limits
Ba Carrier	91.3		30 - 110

Lab Sample ID: MB 160-702743/1-A

Matrix: Water

Analysis Batch: 706559

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 702743

Analyte	MB Result	MB Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-226	0.07888	U	0.0900	0.0903	1.00	0.145	pCi/L	02/13/25 08:06	03/07/25 15:48	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	90.8		30 - 110					02/13/25 08:06	03/07/25 15:48	1

Lab Sample ID: LCS 160-702743/2-A

Matrix: Water

Analysis Batch: 706559

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 702743

Analyte	Spike Added	LCS Result	LCS Qual	Total Uncert. (2σ+/-)	RL	MDC	Unit	%Rec	%Rec Limits
Radium-226	9.58	10.09		1.14	1.00	0.160	pCi/L	105	75 - 125
Carrier	%Yield	Qualifier	Limits						
Ba Carrier	81.8		30 - 110						

Method: 904.0 - Radium-228 (GFPC)

Lab Sample ID: MB 160-702256/1-A

Matrix: Water

Analysis Batch: 705086

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 702256

Analyte	MB Result	MB Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-228	-0.07252	U	0.296	0.296	1.00	0.571	pCi/L	02/10/25 09:01	02/27/25 12:25	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	91.1		30 - 110					02/10/25 09:01	02/27/25 12:25	1
Y Carrier	84.5		30 - 110					02/10/25 09:01	02/27/25 12:25	1

Lab Sample ID: LCS 160-702256/2-A

Matrix: Water

Analysis Batch: 705086

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 702256

Analyte	Spike Added	LCS Result	LCS Qual	Total Uncert. (2σ+/-)	RL	MDC	Unit	%Rec	%Rec Limits
Radium-228	8.06	7.392		1.12	1.00	0.559	pCi/L	92	75 - 125

Eurofins Chicago

QC Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR (RAD)

Job ID: 500-263508-2

Method: 904.0 - Radium-228 (GFPC) (Continued)

Lab Sample ID: LCS 160-702256/2-A
Matrix: Water
Analysis Batch: 705086

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 702256

	LCS	LCS	
Carrier	%Yield	Qualifier	Limits
Ba Carrier	90.6		30 - 110
Y Carrier	79.3		30 - 110

Lab Sample ID: MB 160-702328/1-A
Matrix: Water
Analysis Batch: 705036

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 702328

Analyte	MB Result	MB Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-228	-0.09046	U	0.345	0.346	1.00	0.671	pCi/L	02/11/25 07:15	02/27/25 12:16	1
Carrier	%Yield	Qualifier	Limits					Prepared	Analyzed	Dil Fac
Ba Carrier	82.7		30 - 110					02/11/25 07:15	02/27/25 12:16	1
Y Carrier	77.0		30 - 110					02/11/25 07:15	02/27/25 12:16	1

Lab Sample ID: LCS 160-702328/2-A
Matrix: Water
Analysis Batch: 705036

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 702328

Analyte	Spike Added	LCS Result	LCS Qual	Total Uncert. (2σ+/-)	RL	MDC	Unit	%Rec	%Rec Limits
Radium-228	8.06	8.288		1.24	1.00	0.602	pCi/L	103	75 - 125
Carrier	%Yield	Qualifier	Limits						
Ba Carrier	85.7		30 - 110						
Y Carrier	78.1		30 - 110						

Lab Sample ID: 500-263508-6 DU
Matrix: Water
Analysis Batch: 705036

Client Sample ID: 1N/1S Duplicate
Prep Type: Total/NA
Prep Batch: 702328

Analyte	Sample Result	Sample Qual	DU Result	DU Qual	Total Uncert. (2σ+/-)	RL	MDC	Unit	RER	RER Limit
Radium-228	0.807		0.3969	U	0.327	1.00	0.503	pCi/L	0.54	1
Carrier	%Yield	Qualifier	Limits							
Ba Carrier	91.3		30 - 110							
Y Carrier	86.0		30 - 110							

Lab Sample ID: MB 160-702744/1-A
Matrix: Water
Analysis Batch: 705971

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 702744

Analyte	MB Result	MB Qualifier	Count Uncert. (2σ+/-)	Total Uncert. (2σ+/-)	RL	MDC	Unit	Prepared	Analyzed	Dil Fac
Radium-228	0.3873	U	0.351	0.352	1.00	0.557	pCi/L	02/13/25 08:09	03/04/25 12:21	1

Eurofins Chicago

QC Sample Results

Client: Midwest Generation EME LLC
Project/Site: Will County CCR (RAD)

Job ID: 500-263508-2

Method: 904.0 - Radium-228 (GFPC) (Continued)

Lab Sample ID: MB 160-702744/1-A
Matrix: Water
Analysis Batch: 705971

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 702744

	MB	MB	
Carrier	%Yield	Qualifier	Limits
Ba Carrier	90.8		30 - 110
Y Carrier	83.7		30 - 110

Prepared	Analyzed	Dil Fac
02/13/25 08:09	03/04/25 12:21	1
02/13/25 08:09	03/04/25 12:21	1

Lab Sample ID: LCS 160-702744/2-A
Matrix: Water
Analysis Batch: 705971

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 702744

Analyte	Spike Added	LCS Result	LCS Qual	Total Uncert. (2σ+/-)	RL	MDC	Unit	%Rec	%Rec Limits
Radium-228	8.05	9.950		1.39	1.00	0.546	pCi/L	124	75 - 125

	LCS	LCS	
Carrier	%Yield	Qualifier	Limits
Ba Carrier	81.8		30 - 110
Y Carrier	82.6		30 - 110

Eurofins Chicago

2417 Bond Street

University Park, IL 60484

Phone 708-534-5200 Fax 708-534-5211

Chain of Custody Record



Environment Testing

Client Information		Sampler: <u>Ian John Hawkeson</u>		Lab PM: Mockler, Diana J		Carrier Tracking No(s):		COC No: 500-132928-45943 1							
Client Contact: Patrick Allenstein		Phone: <u>630 290 6850</u>		E-Mail: Diana.Mockler@et.eurofinsus.com		State of Origin:		Page 1 of 1							
Company: KPRG and Associates, Inc		PWSID:		Analysis Requested						Job #: <u>500-263508</u>					
Address: 14665 West Lisbon Road, Suite 1A City: Brookfield State Zip: WI, 53005 Phone: 500-263508 COC Email: patricka@kprginc.com		Due Date Requested		TAT Requested (days)		Compliance Project. ☐ Yes ☐ No		PO #: 4502187743		WO #:		Preservation Codes: D - HNO3 N - None			
Project Name: Will County 1N/1S Event Desc: Quarterly GW Monitoring <u>CCR</u>		Project #: 50011609		SSOW#:		Field Filtered Sample (Yes or No)		Perform MS/MSD (Yes or No)		Total Number of Containers		Other:			
Site: Illinois		Sample Date		Sample Time		Sample Type (C=comp, G=grab)		Matrix (W=water, S=solid, O=waste/oil, BT=tissue, A=air)		Field Filtered Sample (Yes or No)		Perform MS/MSD (Yes or No)		Special Instructions/Note:	
Sample Identification		Sample Date		Sample Time		Sample Type (C=comp, G=grab)		Matrix (W=water, S=solid, O=waste/oil, BT=tissue, A=air)		Field Filtered Sample (Yes or No)		Perform MS/MSD (Yes or No)		Special Instructions/Note:	
MW-01		—		—		—		Water		—		—		—	
MW-02		—		—		—		Water		—		—		—	
MW-03		—		—		—		Water		—		—		—	
MW-04		—		—		—		Water		—		—		—	
MW-07		2-4-25		12:29		G		Water		N		N		5	
MW-08		2-4-25		10:57		G		Water		N		N		5	
MW-09		2-4-25		09:10		G		Water		N		N		5	
MW-13		2-3-25		15:27		G		Water		N		N		5	
MW-14		2-4-25		13:33		G		Water		N		N		5	
MW-15		—		—		—		Water		—		—		—	
1N/1S Duplicate		2-4-25		—		G		Water		N		N		5	
Possible Hazard Identification ☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☐ Unknown ☐ Radiological										Sample Disposal (A fee may be assessed if samples are retained longer than 1 month) ☐ Return To Client ☐ Disposal By Lab ☐ Archive For Months					
Deliverable Requested I, II, III, IV, Other (specify)										Special Instructions/QC Requirements					
Empty Kit Relinquished by				Date		Time		Method of Shipment:							
Relinquished by: <u>[Signature]</u>				Date/Time: 2-4-25 16:30		Company: KPRG		Received by: <u>[Signature]</u>				Date/Time: 2/4/25 1630		Company: <u>[Signature]</u>	
Relinquished by:				Date/Time:		Company:		Received by:				Date/Time:		Company:	
Relinquished by:				Date/Time:		Company:		Received by:				Date/Time:		Company:	
Custody Seals Intact ☐ Yes ☐ No				Custody Seal No		Cooler Temperature(s) °C and Other Remarks: <u>3.4 → 3.3, 1.1 → 0.8</u>									

Eurofins Chicago

2417 Bond Street
University Park, IL 60484
Phone 708-534-5200 Fax 708-534-5211

Chain of Custody Record



Environment Testing

Client Information		Sampler: <u>IAN JOHN HOWESON</u>		Lab PM: Mockler, Diana J		Carrier Tracking No(s)		COC No: 500-126448-45943 1			
Client Contact: Patrick Allenstein		Phone: <u>630-290-6850</u>		E-Mail: Diana Mockler@et.eurofins.com		State of Origin:		Page 1 of 1			
Company: KPRG and Associates, Inc		PWSID:		Analysis Requested						Job #: <u>500-26350 P</u>	
Address: 14665 West Lisbon Road, Suite 1A		Due Date Requested:		Field Filtered Sample (Yes or No) 903.0, 904.0 6010C, 6020A, 7470A 2540C, 4500_F_C, SM4500_Cl_E, SM4500_SO4_E Total Number of Containers						Preservation Codes	
City: Brookfield		TAT Requested (days):								D HNO3	
State Zip: WI, 53005		Compliance Project: ☐ Yes ☐ No								N None	
Phone: 500-263508 COC		PO #: 4502116506									
Email: patricka@kprginc.com		WO #:									
Project Name: Will County 1N/1S Event Desc Quarterly GW Monitoring <u>CCR</u>		Project #: 50011609								Other:	
Site: Illinois		SSOW#:									
Sample Identification		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)		Special Instructions/Note:	
7 MW-01		2-5-25		15:30		G		Water			
8 MW-02		2-5-25		13:52		G		Water			
9 MW-03		2-5-25		12:49		G		Water			
10 MW-04		2-5-25		11:15		G		Water			
MW-07		—		—		—		Water			
MW-08		—		—		—		Water			
MW-09		—		—		—		Water			
MW-13		—		—		—		Water			
MW-14		—		—		—		Water			
11 MW-15		2-5-25		14:51		—		Water			
1N/1S Duplicate		—		—		—		Water			
Possible Hazard Identification										Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)	
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☐ Unknown ☐ Radiological										☐ Return To Client ☐ Disposal By Lab ☐ Archive For _____ Months	
Deliverable Requested I, II, III, IV, Other (specify)										Special Instructions/QC Requirements	
Empty Kit Relinquished by				Date		Time		Method of Shipment:			
Relinquished by: <u>[Signature]</u>				Date/Time: <u>2-5-25 09:18</u>		Company: <u>KPRG</u>		Received by: <u>Stephanie Hemondy</u>		Date/Time: <u>2/10/25 0918</u>	
Relinquished by:				Date/Time:		Company:		Received by:		Date/Time:	
Relinquished by:				Date/Time:		Company:		Received by:		Date/Time:	
Custody Seals Intact ☐ Yes ☐ No		Custody Seal No		Cooler Temperature(s) °C and Other Remarks: <u>-0.6 -7-0.2, -0.5 -7-0.8</u>							



Client Information (Sub Contract Lab)				Lab PW: Mockler, Diana J	Carrier Tracking No(s): N/A	COC No: 500-198021.1					
Client Contact Shipping/Receiving				E-Mail Diana Mockler@eurofins.com	State of Origin Illinois	Page Page 1 of 1					
Company TestAmerica Laboratories, Inc.				Accreditations Required (See note) NELAP - Illinois		Job # 500-263508-2					
Address 13715 Rider Trail North, City Earth City State, Zip MO, 63045 Phone 314-298-8566(Tel) 314-298-8757(Fax) Email N/A Project Name Will County CCR (RAD) Site NRG Midwest Generation Will County				Analysis Requested		Preservation Codes:					
Due Date Requested: 3/6/2025											
TAT Requested (days): N/A											
Sample ID	Sample Date	Sample Time	Sample Type (G=grab)	Matrix (Water, Solid, Overstarch)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	903.0/PrecSep_21 Standard Target List	904.0/PrecSep_0 Standard Target List	Ra226Ra228_GFPc	Total Number of Containers	Special Instructions/Note:
MW-07 (500-263508-1)	2/4/25	12:29 Central	G	Water	X	X	X	X		3	Batch QC must be performed (dup, spikes, etc) - no NCMs concerning limited volume;
MW-08 (500-263508-2)	2/4/25	10:57 Central	G	Water	X	X	X	X		3	Batch QC must be performed (dup, spikes, etc) - no NCMs concerning limited volume;
MW-09 (500-263508-3)	2/4/25	09:10 Central	G	Water	X	X	X	X		3	Batch QC must be performed (dup, spikes, etc) - no NCMs concerning limited volume;
MW-13 (500-263508-4)	2/4/25	15:27 Central	G	Water	X	X	X	X		3	Batch QC must be performed (dup, spikes, etc) - no NCMs concerning limited volume;
MW-14 (500-263508-5)	2/4/25	13:33 Central	G	Water	X	X	X	X		3	Batch QC must be performed (dup, spikes, etc) - no NCMs concerning limited volume;
1N/1S Duplicate (500-263508-6)	2/4/25	Central	G	Water	X	X	X	X		3	Batch QC must be performed (dup, spikes, etc) - no NCMs concerning limited volume;
Note: Since laboratory accreditations are subject to change, Eurofins Chicago places the ownership of method, analyte & accreditation compliance upon our subcontractor laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/test/matrix being analyzed, the samples must be shipped back to the Eurofins Chicago laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Chicago attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Chicago.											
Possible Hazard Identification Unconfirmed Deliverable Requested: I, II, III, IV, Other (specify) _____ Primary Deliverable Rank: 2 Empty Kit Relinquished by: _____ Date: _____ Time: _____ Method of Shipment: _____ Relinquished by: _____ Date/Time: _____ Received by: _____ Date/Time: _____ Relinquished by: _____ Date/Time: _____ Received by: _____ Date/Time: _____ Relinquished by: _____ Date/Time: _____ Received by: _____ Date/Time: _____ Custody Seal Intact: Δ Yes Δ No Custody Seal No.: _____ Cooler Temperature(s) °C and Other Remarks: _____											

Login Sample Receipt Checklist

Client: Midwest Generation EME LLC

Job Number: 500-263508-2

Login Number: 263508

List Number: 1

Creator: Scott, Sherri L

List Source: Eurofins Chicago

Question	Answer	Comment
Radioactivity wasn't checked or is $\leq$ background as measured by a survey meter.	True	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	3.3,0.8,-0.9,-0.8 samples not frozen
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is $<6\text{mm}$ (1/4").	N/A	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	

This receipt checklist is generated for all samples received in this Login. It may not be applicable to all Jobs associated with this Login.

Eurofins Chicago

Login Sample Receipt Checklist

Client: Midwest Generation EME LLC

Job Number: 500-263508-2

Login Number: 263508

List Number: 2

Creator: Forrest, Cheyenne L

List Source: Eurofins St. Louis

List Creation: 02/06/25 12:31 PM

Question	Answer	Comment
Radioactivity wasn't checked or is $\leq$ background as measured by a survey meter.	True	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	N/A	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	N/A	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is $<6\text{mm}$ (1/4").	N/A	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	

This receipt checklist is generated for all samples received in this Login. It may not be applicable to all Jobs associated with this Login.

Login Sample Receipt Checklist

Client: Midwest Generation EME LLC

Job Number: 500-263508-2

Login Number: 263508

List Number: 3

Creator: Forrest, Cheyenne L

List Source: Eurofins St. Louis

List Creation: 02/07/25 01:39 PM

Question	Answer	Comment
Radioactivity wasn't checked or is $\leq$ background as measured by a survey meter.	True	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	N/A	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	N/A	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is $<6\text{mm}$ (1/4").	N/A	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	

This receipt checklist is generated for all samples received in this Login. It may not be applicable to all Jobs associated with this Login.

Lab Chronicle

Client: Midwest Generation EME LLC
Project/Site: Will County CCR (RAD)

Job ID: 500-263508-2

Client Sample ID: MW-07

Date Collected: 02/04/25 12:29

Date Received: 02/04/25 16:30

Lab Sample ID: 500-263508-1

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	PrecSep-21			702255	OGC	EET SL	02/10/25 08:58
Total/NA	Analysis	903.0		1	705882	SRE	EET SL	03/04/25 07:45
Total/NA	Prep	PrecSep_0			702256	OGC	EET SL	02/10/25 09:01
Total/NA	Analysis	904.0		1	705086	SWS	EET SL	02/27/25 14:40
Total/NA	Analysis	Ra226_Ra228		1	706944	SCB	EET SL	03/10/25 12:01

Client Sample ID: MW-08

Date Collected: 02/04/25 10:57

Date Received: 02/04/25 16:30

Lab Sample ID: 500-263508-2

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	PrecSep-21			702255	OGC	EET SL	02/10/25 08:58
Total/NA	Analysis	903.0		1	705882	SRE	EET SL	03/04/25 07:46
Total/NA	Prep	PrecSep_0			702256	OGC	EET SL	02/10/25 09:01
Total/NA	Analysis	904.0		1	705086	SWS	EET SL	02/27/25 14:40
Total/NA	Analysis	Ra226_Ra228		1	706944	SCB	EET SL	03/10/25 12:01

Client Sample ID: MW-09

Date Collected: 02/04/25 09:10

Date Received: 02/04/25 16:30

Lab Sample ID: 500-263508-3

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	PrecSep-21			702255	OGC	EET SL	02/10/25 08:58
Total/NA	Analysis	903.0		1	705882	SRE	EET SL	03/04/25 09:39
Total/NA	Prep	PrecSep_0			702256	OGC	EET SL	02/10/25 09:01
Total/NA	Analysis	904.0		1	705086	SWS	EET SL	02/27/25 14:40
Total/NA	Analysis	Ra226_Ra228		1	706944	SCB	EET SL	03/10/25 12:01

Client Sample ID: MW-13

Date Collected: 02/04/25 15:27

Date Received: 02/04/25 16:30

Lab Sample ID: 500-263508-4

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	PrecSep-21			702327	OGC	EET SL	02/11/25 07:12
Total/NA	Analysis	903.0		1	706176	SWS	EET SL	03/05/25 10:24
Total/NA	Prep	PrecSep_0			702328	OGC	EET SL	02/11/25 07:15
Total/NA	Analysis	904.0		1	705036	SWS	EET SL	02/27/25 12:17
Total/NA	Analysis	Ra226_Ra228		1	706390	EMH	EET SL	03/06/25 11:20

Lab Chronicle

Client: Midwest Generation EME LLC
Project/Site: Will County CCR (RAD)

Job ID: 500-263508-2

Client Sample ID: MW-14

Date Collected: 02/04/25 13:33

Date Received: 02/04/25 16:30

Lab Sample ID: 500-263508-5

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	PrecSep-21			702327	OGC	EET SL	02/11/25 07:12
Total/NA	Analysis	903.0		1	706176	SWS	EET SL	03/05/25 10:24
Total/NA	Prep	PrecSep_0			702328	OGC	EET SL	02/11/25 07:15
Total/NA	Analysis	904.0		1	705036	SWS	EET SL	02/27/25 12:17
Total/NA	Analysis	Ra226_Ra228		1	706390	EMH	EET SL	03/06/25 11:20

Client Sample ID: 1N/1S Duplicate

Date Collected: 02/04/25 00:00

Date Received: 02/04/25 16:30

Lab Sample ID: 500-263508-6

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	PrecSep-21			702327	OGC	EET SL	02/11/25 07:12
Total/NA	Analysis	903.0		1	706176	SWS	EET SL	03/05/25 10:24
Total/NA	Prep	PrecSep_0			702328	OGC	EET SL	02/11/25 07:15
Total/NA	Analysis	904.0		1	705036	SWS	EET SL	02/27/25 12:18
Total/NA	Analysis	Ra226_Ra228		1	706390	EMH	EET SL	03/06/25 11:20

Client Sample ID: MW-01

Date Collected: 02/05/25 15:30

Date Received: 02/06/25 09:18

Lab Sample ID: 500-263508-7

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	PrecSep-21			702327	OGC	EET SL	02/11/25 07:12
Total/NA	Analysis	903.0		1	706176	SWS	EET SL	03/05/25 10:25
Total/NA	Prep	PrecSep_0			702328	OGC	EET SL	02/11/25 07:15
Total/NA	Analysis	904.0		1	705036	SWS	EET SL	02/27/25 12:18
Total/NA	Analysis	Ra226_Ra228		1	706390	EMH	EET SL	03/06/25 11:20

Client Sample ID: MW-02

Date Collected: 02/05/25 13:52

Date Received: 02/06/25 09:18

Lab Sample ID: 500-263508-8

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	PrecSep-21			702327	OGC	EET SL	02/11/25 07:12
Total/NA	Analysis	903.0		1	706176	SWS	EET SL	03/05/25 10:25
Total/NA	Prep	PrecSep_0			702328	OGC	EET SL	02/11/25 07:15
Total/NA	Analysis	904.0		1	705036	SWS	EET SL	02/27/25 12:18
Total/NA	Analysis	Ra226_Ra228		1	706390	EMH	EET SL	03/06/25 11:20

Lab Chronicle

Client: Midwest Generation EME LLC
Project/Site: Will County CCR (RAD)

Job ID: 500-263508-2

Client Sample ID: MW-03

Date Collected: 02/05/25 12:49

Date Received: 02/06/25 09:18

Lab Sample ID: 500-263508-9

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	PrecSep-21			702743	OGC	EET SL	02/13/25 08:06
Total/NA	Analysis	903.0		1	706560	SWS	EET SL	03/07/25 17:45
Total/NA	Prep	PrecSep_0			702744	OGC	EET SL	02/13/25 08:09
Total/NA	Analysis	904.0		1	705971	CMM	EET SL	03/04/25 14:44
Total/NA	Analysis	Ra226_Ra228		1	706943	SCB	EET SL	03/10/25 12:00

Client Sample ID: MW-04

Date Collected: 02/05/25 11:15

Date Received: 02/06/25 09:18

Lab Sample ID: 500-263508-10

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	PrecSep-21			702327	OGC	EET SL	02/11/25 07:12
Total/NA	Analysis	903.0		1	706176	SWS	EET SL	03/05/25 10:25
Total/NA	Prep	PrecSep_0			702328	OGC	EET SL	02/11/25 07:15
Total/NA	Analysis	904.0		1	705036	SWS	EET SL	02/27/25 12:18
Total/NA	Analysis	Ra226_Ra228		1	706390	EMH	EET SL	03/06/25 11:20

Client Sample ID: MW-15

Date Collected: 02/05/25 14:51

Date Received: 02/06/25 09:18

Lab Sample ID: 500-263508-11

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	PrecSep-21			702327	OGC	EET SL	02/11/25 07:12
Total/NA	Analysis	903.0		1	706176	SWS	EET SL	03/05/25 10:25
Total/NA	Prep	PrecSep_0			702328	OGC	EET SL	02/11/25 07:15
Total/NA	Analysis	904.0		1	705036	SWS	EET SL	02/27/25 12:18
Total/NA	Analysis	Ra226_Ra228		1	706390	EMH	EET SL	03/06/25 11:20

Laboratory References:

EET SL = Eurofins St. Louis, 13715 Rider Trail North, Earth City, MO 63045, TEL (314)298-8566

Tracer/Carrier Summary

Client: Midwest Generation EME LLC
Project/Site: Will County CCR (RAD)

Job ID: 500-263508-2

Method: 903.0 - Radium-226 (GFPC)

Matrix: Water

Prep Type: Total/NA

		Percent Yield (Acceptance Limits)				
		Ba				
Lab Sample ID	Client Sample ID	(30-110)				
500-263508-1	MW-07	88.5				
500-263508-2	MW-08	89.0				
500-263508-3	MW-09	87.2				
500-263508-4	MW-13	78.6				
500-263508-5	MW-14	76.5				
500-263508-6	1N/1S Duplicate	88.3				
500-263508-6 DU	1N/1S Duplicate	91.3				
500-263508-7	MW-01	87.0				
500-263508-8	MW-02	91.3				
500-263508-9	MW-03	82.8				
500-263508-10	MW-04	85.2				
500-263508-11	MW-15	85.2				
LCS 160-702255/2-A	Lab Control Sample	90.6				
LCS 160-702327/2-A	Lab Control Sample	85.7				
LCS 160-702743/2-A	Lab Control Sample	81.8				
MB 160-702255/1-A	Method Blank	91.1				
MB 160-702327/1-A	Method Blank	82.7				
MB 160-702743/1-A	Method Blank	90.8				

Tracer/Carrier Legend

Ba = Ba Carrier

Method: 904.0 - Radium-228 (GFPC)

Matrix: Water

Prep Type: Total/NA

		Percent Yield (Acceptance Limits)				
		Ba	Y			
Lab Sample ID	Client Sample ID	(30-110)	(30-110)			
500-263508-1	MW-07	88.5	80.7			
500-263508-2	MW-08	89.0	78.5			
500-263508-3	MW-09	87.2	80.0			
500-263508-4	MW-13	78.6	86.0			
500-263508-5	MW-14	76.5	81.9			
500-263508-6	1N/1S Duplicate	88.3	79.3			
500-263508-6 DU	1N/1S Duplicate	91.3	86.0			
500-263508-7	MW-01	87.0	83.0			
500-263508-8	MW-02	91.3	81.9			
500-263508-9	MW-03	82.8	81.5			
500-263508-10	MW-04	85.2	82.2			
500-263508-11	MW-15	85.2	79.6			
LCS 160-702256/2-A	Lab Control Sample	90.6	79.3			
LCS 160-702328/2-A	Lab Control Sample	85.7	78.1			
LCS 160-702744/2-A	Lab Control Sample	81.8	82.6			
MB 160-702256/1-A	Method Blank	91.1	84.5			
MB 160-702328/1-A	Method Blank	82.7	77.0			
MB 160-702744/1-A	Method Blank	90.8	83.7			

Tracer/Carrier Legend

Ba = Ba Carrier

Y = Y Carrier

Eurofins Chicago

PROJECT NAME	NRG - WILL COUNTY STATION (12313.3)		DATE	2-5-25
Sample Name	MW-01	Start Time	15:15	
Condition of Well	Good			
Water Level	10.65	Total Depth	—	
Well Diameter	PVC - 2 inch	Volume in Well	—	
Method of Purge	Low-Flow	Purge Characteristics	COLORLESS TRACE ODORLESS TURB	
Volume Removed	2.0 Q18.	W L at Sample Time	10.67	
Method of Sample	Low-Flow	Sample Characteristics	APPEARS CLEAR CCA - FILTERED	
Sample Analysis	CCA + CCR	Sample Time	15:30	
Water Quality Meter	YSI ProDss			

Time	Depth to Water (ft)	ph (SU)	Temp (°C)	Spec. Cond (mS/cm).	DO (mg/L)	ORP (mV)	Turbidity (NTU)
15:18	10.68	6.94	6.5	1.481	3.15	-15.2	78.49
15:21	10.69	7.02	10.8	1.378	3.57	-15.1	53.21
15:24	10.69	7.07	11.6	1.360	2.54	-8.2	49.81
15:27	10.68	7.09	11.6	1.348	1.97	-1.2	42.53
15:30	10.67	7.09	11.7	1.346	1.80	-1.5	39.44
—							

SAMPLING NOTES:

Sampler Name and Company:

KPRG and Associates



PROJECT NAME	NRG - WILL COUNTY STATION (12313.3)		DATE	2.5-25
Sample Name	MW-02	Start Time	13:37	
Condition of Well	GOOD.			
Water Level	11.78	Total Depth	—	
Well Diameter	PVC - 2 inch	Volume in Well	—	
Method of Purge	Low-Flow	Purge Characteristics	COLORLESS TRACE SLIGHT ODOR TURB	
Volume Removed	2.25 GGS	W L at Sample Time	11.78	
Method of Sample	Low-Flow	Sample Characteristics	APPEARS CLEAR CCA - FILTERED	
Sample Analysis	CCA + CCR	Sample Time	13:52	
Water Quality Meter	YSI ProDss			

Time	Depth to Water (ft)	ph (SU)	Temp (°C)	Spec. Cond (mS/cm)	DO (mg/L)	ORP (mV)	Turbidity (NTU)
13:40	11.79	7.72	8.2	1.112	7.20	169.3	46.50
13:43	11.78	7.70	10.7	1.153	4.15	161.3	37.97
13:46	11.79	7.72	11.5	1.193	2.76	156.4	39.43
13:49	11.79	7.73	11.9	1.194	2.40	154.0	39.21
13:52	11.78	7.73	11.9	1.195	2.29	152.9	38.07
—							

SAMPLING NOTES:

Sampler Name and Company:

KPRG and Associates

PROJECT NAME	NRG - WILL COUNTY STATION (12313.3)		DATE	2-5-25
Sample Name	MW-03	Start Time	12:34	
Condition of Well	GOOD			
Water Level	11.44	Total Depth	—	
Well Diameter	PVC - 2 inch	Volume in Well	—	
Method of Purge	Low-Flow	Purge Characteristics	COLORLESS TRACE ODORLESS TURB	
Volume Removed	1.75 Q ₉₅	W L at Sample Time	11.53	
Method of Sample	Low-Flow	Sample Characteristics	APPEARS CLEAR CCA - FILTERED	
Sample Analysis	CCA + CCR	Sample Time	12:49	
Water Quality Meter	YSI ProDss			

Time	Depth to Water (ft)	ph (SU)	Temp (°C)	Spec. Cond (mS/cm)	DO (mg/L)	ORP (mV)	Turbidity (NTU)
12:37	11.51	6.69	5.2	1.124	3.58	174.9	130.46
12:40	11.54	6.73	9.7	1.243	4.12	178.2	62.63
12:43	11.61	6.71	9.4	1.260	2.28	183.2	30.26
12:46	11.56	6.71	9.4	1.262	1.85	184.1	28.22
12:49	11.53	6.70	9.3	1.264	1.69	184.7	26.84
—							

SAMPLING NOTES:

Sampler Name and Company:

KPRG and Associates



PROJECT NAME	NRG - WILL COUNTY STATION (12313.3)		DATE	2-5-25
Sample Name	MW-04	Start Time	10:57	
Condition of Well	Good			
Water Level	11.47	Total Depth	—	
Well Diameter	PVC - 2 inch	Volume in Well	—	
Method of Purge	Low-Flow	Purge Characteristics	TAN TINT MOD OVERLIES TURB	
Volume Removed	2.5 QTB.	W L at Sample Time	11.55	
Method of Sample	Low-Flow	Sample Characteristics	APPEARS CLEAR TRACE CCA-FILTERED TURB	
Sample Analysis	CCA + CCR	Sample Time	11:15	
Water Quality Meter	YSI ProDss			

Time	Depth to Water (ft)	ph (SU)	Temp (°C)	Spec. Cond (mS/cm).	DO (mg/L)	ORP (mV)	Turbidity (NTU)
11:00	11.51	6.85	9.2	1.329	8.93	135.4	146.07
11:03	11.54	6.71	9.4	1.388	5.81	143.4	172.31
11:06	11.55	6.69	9.2	1.389	3.70	149.5	109.66
11:09	11.58	6.69	8.7	1.374	3.21	154.9	74.11
11:12	11.56	6.67	8.8	1.351	2.74	159.7	63.92
11:15	11.55	6.67	9.1	1.363	2.65	160.8	54.83
—							

SAMPLING NOTES:

Sampler Name and Company:

KPRG and Associates



PROJECT NAME	NRG - WILL COUNTY STATION (12313.3)		DATE	2-4-25
Sample Name	MW-07	Start Time	2-4-25	
Condition of Well	Good			
Water Level	11.13	Total Depth	—	
Well Diameter	PVC - 2 inch	Volume in Well	—	
Method of Purge	Low-Flow	Purge Characteristics	APPEARS CLEAR ODORLESS TASTE FREE	
Volume Removed	2.5 QRS.	W L at Sample Time	11.41	
Method of Sample	Low-Flow	Sample Characteristics	COLORLESS CCA-FILTERED.	
Sample Analysis	CCA + CCA DUP + CCR ^{INITIALS}	Sample Time	12:29	
Water Quality Meter	YSI ProDss			

Time	Depth to Water (ft)	ph (SU)	Temp (°C)	Spec. Cond (mS/cm).	DO (mg/L)	ORP (mV)	Turbidity (NTU)
12:14	11.17	7.08	8.9	1.532	6.79	124.9	65.12
12:17	11.28	6.75	10.1	1.784	5.26	129.1	46.89
12:20	11.34	6.62	10.4	1.896	3.95	141.5	38.61
12:23	11.39	6.59	10.5	1.980	3.13	148.9	35.38
12:26	11.41	6.59	10.4	1.986	2.72	152.2	30.12
12:29	11.41	6.59	10.6	1.993	2.64	153.4	30.27.
—							

SAMPLING NOTES:

Sampler Name and
Company:

KPRG and Associates



PROJECT NAME	NRG - WILL COUNTY STATION (12313.3)		DATE	2-4-25
Sample Name	MW-08	Start Time	10:39	
Condition of Well	Good			
Water Level	11.49	Total Depth	—	
Well Diameter	PVC - 2 inch	Volume in Well	—	
Method of Purge	Low-Flow	Purge Characteristics	TAN TINT MOD ODORLESS TURB	
Volume Removed	2.75 QRS	W L at Sample Time	11.54	
Method of Sample	Low-Flow	Sample Characteristics	APPROX CECAR THREE CCA-FILTERED TURB	
Sample Analysis	CCA + CCR	Sample Time	10:57	
Water Quality Meter	YSI ProDss			

Time	Depth to Water (ft)	ph (SU)	Temp (°C)	Spec. Cond (mS/cm)	DO (mg/L)	ORP (mV)	Turbidity (NTU)
10:42	11.62	7.31	10.0	1.438	3.90	103.8	210.31
10:45	11.89	7.02	9.8	1.417	1.45	108.4	153.25
10:48	11.69	6.94	8.0	1.379	1.08	108.0	107.15
10:51	11.62	6.91	6.5	1.318	0.96	106.6	84.21
10:54	11.57	6.88	5.2	1.269	0.88	105.8	59.73
10:57	11.54	6.87	4.8	1.253	0.87	105.6	48.94

SAMPLING NOTES:

Sampler Name and Company:

KPRG and Associates

PROJECT NAME	NRG - WILL COUNTY STATION (12313.3)		DATE	2-4-25
Sample Name	MW-9	Start Time	08:55	
Condition of Well	Good			
Water Level	11.81	Total Depth	—	
Well Diameter	PVC - 2 inch	Volume in Well	—	
Method of Purge	Low-Flow	Purge Characteristics	COLORLESS SLIGHT ODORLESS TURB	
Volume Removed	2.5 GALS.	W L at Sample Time	12.10	
Method of Sample	Low-Flow	Sample Characteristics	APPEARS CLEAR CCA - FILTERED	
Sample Analysis	25/35 IN/15 CCA + CCR + CCR	Sample Time	09:10	
Water Quality Meter	YSI ProDss			

Time	Depth to Water (ft)	ph (SU)	Temp (°C)	Spec. Cond (mS/cm).	DO (mg/L)	ORP (mV)	Turbidity (NTU)
08:58	12.11	8.27	9.8	1.061	9.82	55.4	117.11
08:01	12.12	8.48	10.3	1.113	4.08	53.9	101.02
09:04	12.11	8.70	9.8	1.096	1.56	53.8	74.64
09:07	12.11	8.77	9.6	1.093	0.97	52.7	63.22
09:10	12.10	8.79	9.6	1.089	0.78	51.8	52.73
—							

SAMPLING NOTES:

Sampler Name and
Company:

KPRG and Associates

PROJECT NAME	NRG - WILL COUNTY STATION (12313.3)		DATE	2-3-25
Sample Name	MW-13	Start Time	15:08	
Condition of Well	Good			
Water Level	10.89	Total Depth	_____	
Well Diameter	PVC - 2 inch	Volume in Well	_____	
Method of Purge	Low-Flow	Purge Characteristics	TAN TINT HIGH ODORLESS TURB	
Volume Removed	3 QTS.	W L at Sample Time	11.38	
Method of Sample	Low-Flow	Sample Characteristics	APPEARS CLEAR SLIGHT TURB.	
Sample Analysis	CCR	Sample Time	15:27	
Water Quality Meter	YSI ProDss			

Time	Depth to Water (ft)	ph (SU)	Temp (°C)	Spec. Cond (mS/cm).	DO (mg/L)	ORP (mV)	Turbidity (NTU)
15:11	10.92	7.33	9.7	1.153	4.58	98.7	344.78
15:14	11.03	7.29	8.7	1.125	3.76	102.3	279.86
15:17	11.06	7.24	9.0	1.123	3.28	105.2	214.10
15:20	11.18	7.23	9.1	1.122	3.22	108.0	148.34
15:21	11.23	7.23	9.0	1.119	3.23	109.8	124.20
15:24	11.33	7.22	9.1	1.117	3.28	112.6	91.11
15:27	11.38	7.22	9.1	1.116	3.29	113.8	59.22

SAMPLING NOTES:

Sampler Name and
Company:

KPRG and Associates



PROJECT NAME	NRG - WILL COUNTY STATION (12313.3)		DATE	2-4-25
Sample Name	MW-14	Start Time	13:18	
Condition of Well	GOOD			
Water Level	10.83	Total Depth	—	
Well Diameter	PVC - 2 inch	Volume in Well	—	
Method of Purge	Low-Flow	Purge Characteristics	COLORED-SS TRACE SLIGHT ODOR turb	
Volume Removed	2.0 QRS,	W L at Sample Time	10.84	
Method of Sample	Low-Flow	Sample Characteristics	APPEARS CLEAR TRACE turb	
Sample Analysis	CCR + ^{IN/IS} CCR DWA	Sample Time	13:33	
Water Quality Meter	YSI ProDss			

Time	Depth to Water (ft)	ph (SU)	Temp (°C)	Spec. Cond (mS/cm).	DO (mg/L)	ORP (mV)	Turbidity (NTU)
13:21	10.84	6.81	6.7	1.349	5.98	142.0	58.36
13:24	10.83	6.92	6.9	1.168	3.63	138.1	42.65
13:27	10.84	7.32	6.9	1.093	2.70	125.4	37.32
13:30	10.84	7.54	6.7	1.073	2.36	113.2	32.64
13:33	10.84	7.64	6.6	1.067	2.22	110.8	32.75
—							

SAMPLING NOTES:

Sampler Name and Company:

KPRG and Associates



PROJECT NAME	NRG - WILL COUNTY STATION (12313.3)		DATE	2-5-25
Sample Name	MW-15	Start Time	14:33	
Condition of Well	Good			
Water Level	10.22	Total Depth	—	
Well Diameter	PVC - 2 inch	Volume in Well	—	
Method of Purge	Low-Flow	Purge Characteristics	TAN TINT MOD ODORLESS TURB	
Volume Removed	2.75 QTB.	W L at Sample Time	10.88	
Method of Sample	Low-Flow	Sample Characteristics	APPEARS CLEAR TRACE TURB	
Sample Analysis	CCR	Sample Time	14:51	
Water Quality Meter	YSI ProDss			

Time	Depth to Water (ft)	ph (SU)	Temp (°C)	Spec. Cond (mS/cm).	DO (mg/L)	ORP (mV)	Turbidity (NTU)
14:36	10.42	7.64	6.7	1.286	9.82	140.1	202.15
14:39	10.48	6.92	9.4	1.607	5.18	89.3	161.33
14:42	10.59	6.82	9.4	1.628	4.07	50.2	113.16
14:45	10.68	6.79	10.1	1.684	2.45	27.1	81.27
14:48	10.74	6.77	10.3	1.711	1.96	15.0	64.72
14:51	10.88	6.77	10.3	1.713	1.88	13.9	55.13

SAMPLING NOTES:

Sampler Name and Company:

KPRG and Associates

