

**Annual CCR Fugitive Dust Control Report**  
**Will County Generating Station**  
529 East 135th Street/Romeoville, Illinois

## ***1.0 Introduction***

---

On December 19, 2014, the administrator of the U.S. Environmental Protection Agency signed the Disposal of Coal Combustion Residuals (CCR) from Electric Utilities final rule (the Rule). The Rule was published in the Federal Register on April 17, 2015 and became effective on October 19, 2015. The Rule establishes a set of requirements for the disposal of CCR in landfills and surface impoundments at coal-fired power plants under Subtitle D of the Resource Conservation and Recovery Act. These requirements include air criteria specified in Title 40 of the Code of Federal Regulations, §257.80, to address potential pollution caused by windblown dust from CCR units.

The Will County Generating Station, operated by Midwest Generation, LLC (MWG), is located at 529 East 135<sup>th</sup> Street, Romeoville, Will County, Illinois. The facility is a retired coal-fired electric power generating station that occupies approximately 200 acres. The last remaining coal-fired unit at the Station, Unit 4, ceased operation in June 2022. Electrical power was transmitted from the site to the area grid through overhead transmission power lines. The Rule applies to this facility due to the management of CCR that was generated from the combustion of coal. CCR units associated with the station are South Ash Pond 2 and South Ash Pond 3.

According to the Rule, owners or operators of CCR units must adopt measures that will effectively minimize CCR from becoming airborne at the facility by developing and operating in accordance with a Fugitive Dust Control Plan (Plan) with adequate dust control measures. In this regard, a Plan was prepared that complies with the requirements as specified in §257.80(b)(1-7) of the Rule and placed in the Will County facility's operating record on October 19, 2015 per §257.105(g)(1). As required, the Plan was also noticed to the State Director per §257.106(g)(1) and posted to the publicly accessible internet site per §257.107(g)(1).

In addition to the above and per §257.80(c), an Annual Fugitive Dust Control Report (Annual Report) must be completed that includes the following:

- Description of actions taken to control CCR fugitive dust
- Record of all citizen complaints
- Summary of any corrective actions taken

The Annual Report must be completed no later than one year after completion and placement of the previous Report in the facility's operating record. This document represents the 2024 Annual Report for Will County and will also be appropriately placed in the facility's operating record per §257.105(g)(2), noticed to the State Director per §257.106(g)(2), and posted to the publicly accessible internet site per §257.107(g)(2).

**Annual CCR Fugitive Dust Control Report**  
**Will County Generating Station**  
529 East 135th Street/Romeoville, Illinois

## ***2.0 Actions Will County Station Takes to Control CCR Fugitive Dust***

---

As detailed in the Plan and reiterated below, the station has established procedures and inspection requirements which are implemented to minimize/eliminate airborne emissions from the potential fugitive dust sources. The results from inspections conducted and associated observations made during CCR handling activities are documented on logs maintained in the station's Environmental Department.

### ***2.1 South Ash Pond 2 and South Ash Pond 3***

The Ash Ponds contain ash, all of which is below grade, which minimizes any potential fugitive dust emissions. Infrequently, when the ponds need to be dewatered and the sediment removed off site to a licensed landfill, there is the potential for this material to become airborne especially during excessively dry and windy conditions. Loading of this material under these conditions also has the potential for generating fugitive dust. Dewatered ponds are assessed on a quarterly basis or more frequently during excessively dry and windy conditions. To minimize fugitive dust emissions from exposed dry bottom ash and slag, the height of the staged material is minimized and the material piles are either sprayed with water or covered. Loading activities also are limited during such occasions. Haul trucks are covered with tarps once they have been loaded.

There were no ash removal activities from the Ash Ponds conducted during this reporting period.

### ***2.2 Concrete Storage Pad***

The concrete pad only periodically contains bottom ash and slag, fly ash and other ash-related materials generated from decommissioning activities. Typically, these materials are in a wet state but are allowed to partially dry to facilitate removal. When sufficiently dry, the material is promptly removed to an off-site licensed landfill. The concrete pad is assessed on a quarterly basis or more frequently during excessively dry and windy conditions. To minimize fugitive dust emissions from exposed dry bottom ash and slag, fly ash, and other ash related materials, the height of the staged material is minimized, and the material piles are either sprayed with water or covered.

### ***2.3 Ash Transport Roadways***

During CCR hauling activities, truck drivers are instructed on the proper procedure for cleaning trucks and a vehicle speed limit is enforced at the facility. Ash material that may not have been adequately removed from the trucks has the potential to become airborne and ultimately be deposited on haul roads. To minimize fugitive dust emissions, these roads are assessed on a

**Annual CCR Fugitive Dust Control Report**  
**Will County Generating Station**  
529 East 135th Street/Romeoville, Illinois

quarterly basis and any observed accumulated ash material is promptly cleaned up and collected for off-site removal to a licensed landfill.

### ***3.0 Fugitive CCR Dust Assessments***

---

Pursuant to 40 CFR 257.80(b)(4), assessments of the potential fugitive dust emission sources identified in the Will County facility's CCR Fugitive Dust Control Plan (Plan) were conducted to assess the effectiveness of the Plan. The assessment includes observation of ash removal from ponds, temporary storage and transport activities at the facility to confirm the adequacy of the control measures. The assessments are conducted on a quarterly basis by an individual designated by the contact identified below. Observations made during each assessment are recorded on a form similar to the one included in Appendix B of the Will County facility's CCR Fugitive Dust Control Plan.

No issues were identified during this Annual Report's period of record covering November 2023 through November 2024.

**Owner Representative/Responsible Person Contact Information:**

Mr. Phillip Raush  
Plant Manager  
815-207-5412

### ***4.0 Record of Citizen Complaints***

---

Per the Rule, the Annual Report must include a record of all citizen complaints that were received by the Will County station with regard to fugitive dust emission incidents. In line with established protocols and within 24 hours of receipt, the station's environmental coordinator enters the citizen complaint into MWG's Environmental Management Information System (EMIS) database. The EMIS database then automatically forwards notice of the complaint to the station manager, MWG's regional environmental manager, and MWG's corporate environmental department. Following initial evaluation of the complaint, MWG then conducts a thorough investigation to confirm the reported incident/conditions and implement corrective actions as may be warranted.

No complaints were registered during this Annual Report's period of record covering November 2023 through November 2024.

**Annual CCR Fugitive Dust Control Report**  
**Will County Generating Station**  
529 East 135th Street/Romeoville, Illinois

***5.0 Summary of Corrective Actions Taken***

---

For the November 2023 to November 2024 period of record, and based on continued monitoring and inspections as outlined in Section 2.0 and 3.0 and as required under the CCR rules, the currently established control measures remain effective in minimizing potential fugitive dust emissions. Moreover, this assertion is further validated by the lack of citizen complaints logged over this same period. Accordingly, no corrective actions were undertaken during the past year, either as a result of internally identified deficiencies or from resolution of citizen complaints.