

Notice of Statistically Significant Levels – Will County Generating Station – IL0002208

January 30, 2023

This notice is being provided as required by 40 CFR 257.95(g) for Pond 2S and Pond 3S at the Will County Generating Station. The constituents listed below are listed in Appendix IV to 40 CFR Part 257 Subpart D and were detected at statistically significant levels (SSL) at or above the established groundwater protection standards (GWPS).

- Arsenic – 2 downgradient wells
- Selenium – 1 upgradient well

No other constituent listed in Appendix IV was detected at or above statistically significant levels of the established groundwater protection standards. Out of an abundance of caution, MWG has included selenium in this notification, however, because it is detected in an upgradient well and there are no detections above the GWPS in the down gradient wells, whether the selenium concentration from our upgradient well is considered an SSL requiring notification is unclear.

Accordingly, this notification is being made by Midwest Generation, LLC to satisfy the requirements of §257.95(g), including documented placement of this information into the facility's operating record [§257.105(h)(8)]. This notification is being further provided to the State to comply with the obligations of §257.106(h)(6) and will also be posted on the publicly accessible website per §257.107(h)(6). This posting will be available on our public website at <http://www.nrg.com/legal/coal-combustion-residuals>.